

Fan, Zaiming (2016) Investigation on smart bi-directional inverter with quantitative reactive power compensation and interleaved DC/DC converter for micro-grid system. Doctoral thesis, University of Cumbria (awarded by Lancaster University).

Downloaded from: <http://insight.cumbria.ac.uk/id/eprint/3326/>

***Usage of any items from the University of Cumbria's institutional repository 'Insight' must conform to the following fair usage guidelines.***

Any item and its associated metadata held in the University of Cumbria's institutional repository Insight (unless stated otherwise on the metadata record) may be copied, displayed or performed, and stored in line with the JISC fair dealing guidelines (available [here](#)) for educational and not-for-profit activities

**provided that**

- the authors, title and full bibliographic details of the item are cited clearly when any part of the work is referred to verbally or in the written form
- a hyperlink/URL to the original Insight record of that item is included in any citations of the work
- the content is not changed in any way
- all files required for usage of the item are kept together with the main item file.

**You may not**

- sell any part of an item
- refer to any part of an item without citation
- amend any item or contextualise it in a way that will impugn the creator's reputation
- remove or alter the copyright statement on an item.

The full policy can be found [here](#).

Alternatively contact the University of Cumbria Repository Editor by emailing [insight@cumbria.ac.uk](mailto:insight@cumbria.ac.uk).

# **Investigation on Smart Bi-Directional Inverter with Quantitative Reactive Power Compensation and Interleaved DC/DC Converter for Micro-Grid System**

by

**Zaiming Fan**

Thesis submitted for the degree of  
Doctor of Philosophy

of the

Lancaster University (University of Cumbria)

Department of Engineering

November 2016

**All Glory be to God the Father Almighty.**

**Dedicated to my wife, my son and my parents.**

**Thanks for their support and trust.**

## Acknowledgements

First of all, I am extremely happy to be a student of Professor Xiongwei Liu, who is my director of study. I am also rather grateful to his careful and generous guidance and help during my PhD study.

With great pleasure, I also express my gratitude to Professor Diane Cox, Sonia Mason and Sonia Barnes. They were always supporting and helping me at every stage of this work.

In particular, I would like to thank my friend Michael Peak and his wife Zhang Hui for their help. I also thank Dr. Elizabeth Tso, Dr. Mike Peak and Dr. Oyebanji Olusayo for their thorough proof-reading.

My thanks go to all my research office colleagues for a harmonious atmosphere.

Finally, I would like to thank the staff members of the University of Cumbria and Lancaster University for their support for my PhD study.

## Abstract

The PhD project aims to develop a smart grid-connected inverter (SGCI) for a micro-grid, which can be applied in a built environment such as a community, and associated power electronic DC/DC converters. The micro-grid generally includes distributed renewable power generators and battery storage.

The SGCI is a bi-directional DC/AC inverter for distributed generation with battery storage installed at its DC side. In one aspect, it is expected the DC/AC inverter functions as a controlled inverter that can deliver expected real power to the power grid with quantitative reactive power compensation (RPC). In other words, all the SGCI in the community microgrid can share the reactive power of the whole community because a SGCI can quantify its active and reactive power output. It is also expected that the inverter can work in both on-grid and off-grid modes. In other words, the DC/AC inverter functions as a controlled rectifier with high quality power factor correction (PFC), which can deliver expected DC power from the AC power grid at unity power factor. With the above features, battery storage on the DC bus of the SGCI can be charged/discharged through a four-phase, interleaved, bi-directional, boost/buck DC/DC converter (IBDBBC) for distributed renewable power system, either wind or solar PV or hybrid wind/solar PV system. The IBDBBC can discharge power from a low voltage battery to a high voltage DC bus as the IBDBBC operates in boost mode, or it can also draw power from the DC bus to charge the battery as the IBDBBC operates in buck mode.

Based on MATLAB/Simulink, a mathematical model was developed for the grid-connected bi-directional DC/AC inverter that operates as a rectifier with PFC and as a grid-connected inverter (GCI) with expected real power output and quantitative RPC.

In a practical application, the sampling of input signal through AD converter usually has some noise due to common-mode interference; simulation results demonstrate that the second order

generalised integrator (SOGI) has great advantages to prevent interference. Therefore, SOGI can be utilised to construct a pair of orthogonal signals in a single-phase system to instantaneously split grid's active and reactive power to achieve RPC for local community loads. The methodology of the constructed the pair of orthogonal signals was also used to generate the required reference current for the DC/AC inverter when which operated as a single-phase rectifier with PFC.

Using three TI C2000 Solar Inverter DSK Boards, a small lab scale distributed power system was developed. In the lab distributed power system, the operating mode of the inverters could be switched between on-grid and off-grid through instruction from the control centre. The lab test outcomes demonstrate that each distributed power system unit worked properly under loss of power grid signal, simulating grid failure.

# Abbreviations

AC	Alternating Current
AC/DC	Alternating Current to Direct Current
AD	Analogue to Digital
APLL	Analogue PLL
CCS	Code Composer Studio
CCM	Continuous Conduction Mode
CPU	Control Processor Unit
CSI	Current Source Inverters
DCM	Discontinuous Conduction Mode
DPLL	Digital PLL
DSP	Digital Signal Processor
DC	Direction Current
DC/AC	Direction Current to Alternating Current
DC/DC	Direction Current to Direction Current
DG	Distributed Generators
DSK	Development Starter Kit
ESS	Energy Storage System
EV	Electrical Vehicle
FPWM	Fuzzy PWM
FPU	Floating-Point Unit
GCI	Grid-Connected Inverter
GCIS	Grid-Connected Inverter System
HCC	Hysteresis Current Control
IBDBBC	Interleaved Bi-directional Boost/Buck DC/DC Converter

IDE	Integrated Development Environment
IGBT	Insulated-Gate Bipolar Transistor
IO	Input and Output
JTAG	Joint Test Action Group
MPPT	Maximum Power Point Tracking
PCC	Point Common Coupling
PFC	Power Factor Correction
PHS	Pumped Hydroelectricity Storage
PI	Proportional-Integral
PID	Proportional-Integral-Derivative
PLL	Phase-Locked Loop
PV	Photovoltaic
PWM	Pulse Width Modulation
RES	Renewable Energy Source
RMS	Root Mean Square
RPC	Reactive Power Compensation
RTXD	Real-time Exchange Data
SGCI	Smart Grid-Connected Inverter
SDK	Solar Inverter Development Kit
SFPLL	Synchronous Frame PLL
SHEPWM	Selective Harmonic Elimination PWM
SOGI	Second Order Generalised Integrator
SOGIPLL	Second Order Generalised Integrator PLL
SPLL	Software PLL
SPWM	Sinusoidal PWM
SSDG	Small Scale Distributed Generators



STACOM	Static Synchronous Compensator
SVPWM	Space Vector Pulse Width Modulation
THD	Total Harmonic Distortion
UPS	Uninterruptible Power Supply
VAR	Volt Amperes Reactive
VCO	Voltage Controlled Oscillator
VFD	Variable Frequency Drives
VSI	Voltage Source Inverter

## List of Figures

Figure 1- 1 Conventional RPC for solar PV power system .....	2
Figure 1- 2 Proposed the diagram of small-scale GCIS .....	4
Figure 1- 3 Diagram of smart distributed micro-grid .....	5
Figure 1- 4 Topology of single-stage GCI.....	8
Figure 2- 1 Structure of bi-directional three-phase rectifier/inverter topology .....	13
Figure 2- 2 The main board of <i>C2000</i> <sup>TM</sup> SDK.....	14
Figure 2- 3 Control board of <i>C2000</i> <sup>TM</sup> SDK .....	14
Figure 2- 4 Re-designed control board .....	15
Figure 2- 5 Central control board.....	15
Figure 2- 6 IGBT FF75R12RT4 .....	17
Figure 2-7 Sampling circuit of input voltage.....	18
Figure 2- 8 TLP7820 device .....	18
Figure 2- 9 Linear relationship between input and output of TLP7820 .....	19
Figure 2- 10 Sampling Gain.....	20
Figure 3- 1 Diagram of generic PLL.....	28
Figure 3- 2 Linearised conventional SFPLL block diagram.....	29
Figure 3- 3 Open-loop system of SOGI.....	29
Figure 3- 4 Close-loop system of SOGI .....	29
Figure 3- 5 Step responses of a closed-loop SOGIPLL in continuous-time.....	31
Figure 3- 6 Direct Form II structure for IIR filter.....	34
Figure 3- 7 Simulink model of SOGIPLL .....	36
Figure 3- 8 Comparison between input with white noises and PLL output.....	36
Figure 3- 9 Comparison of original input and PLL output .....	37

Figure 4- 1 Basic rectifier topologies with PFC .....	40
Figure 4- 2 Topology of Vienna rectifier .....	41
Figure 4- 3 Topology of three-phase full-bridge inverter .....	42
Figure 4- 4 Topology of three-phase full-bridge active rectifier .....	43
Figure 4- 5 d-component of current-loop control diagram .....	46
Figure 4- 6 Simplified current-loop control .....	47
Figure 4- 7 Final d-component of current-loop control .....	47
Figure 4- 8 Normalised sinusoidal waves of three-phase voltage .....	54
Figure 4- 9 Vector synthesis schematic in sector 1 .....	56
Figure 4- 10 The patterns of voltage vectors .....	58
Figure 4- 11 The principle of PWM generation .....	61
Figure 4- 12 Ideal modulation waveform of SVPWM .....	62
Figure 4- 13 Modelling of current controlled-loop .....	63
Figure 4- 14 Modelling of three-phase SVPWM rectifier with/without PFC .....	64
Figure 4- 15 Generated saddled modulation waveform .....	65
Figure 4- 16 Experiment result of Phase A saddled carried waveform .....	66
Figure 4- 17 Experiment result of Phase B saddled carried waveform .....	66
Figure 4- 18 Experiment result of Phase C saddled carried waveform .....	66
Figure 4- 19 Phase A current and voltage without PFC .....	67
Figure 4- 20 Phase A current and voltage after PFC .....	67
Figure 4- 21 Analysis of harmonic distortion .....	68
Figure 4- 22 Experimental results .....	69
Figure 4- 23 Strategy of single--phase rectifier with PFC .....	70
Figure 4- 24 Model of single-phase rectifier with PFC .....	71
Figure 4- 25 Results of single-phase rectifier .....	72

Figure 4- 26 Harmonic analysis of input current .....	72
Figure 5- 1 Topology of buck converter .....	75
Figure 5- 2 Circuit of boost converter.....	77
Figure 5- 3 Basic interleaved boost topology .....	79
Figure 5- 4 Conventional boost circuit model .....	81
Figure 5- 5 Simulation of four-phase IBDBBC circuit.....	81
Figure 5- 6 Generated PWM signals.....	83
Figure 5- 7 Inductor current of conventional CCM boost circuit .....	83
Figure 5- 8 Inductor currents of IBDBBC circuit.....	84
Figure 5- 9 DC output voltage of conventional boost circuit .....	85
Figure 5- 10 DC output voltage of four-phase IBDBBC circuit.....	85
Figure 5- 11 Simulation of four-phase IBDBBC under buck mode .....	86
Figure 5- 12 Input and output current .....	87
Figure 5- 13 Input and output voltage.....	88
Figure 5- 14 Output voltage ripple.....	88
Figure 6- 1 Topology of half-bridge single-phase VSI.....	93
Figure 6- 2 The topology of full-bridge single-phase VSI .....	94
Figure 6- 3 Structure of DC/AC inverter based on HCC.....	95
Figure 6- 4 Simulation model of conventional PLL for GCI.....	96
Figure 6- 5 Simulation model of full-bridge single-phase GCI.....	97
Figure 6- 6 Simulation results of full-bridge single-phase GCI .....	98
Figure 6- 7 Output current of conventional GCI .....	98
Figure 6- 8 Schematic diagram of GCI.....	99
Figure 6- 9 Vector relationships of GCI .....	100
Figure 6- 10 PCC of single-phases system .....	101

Figure 6- 11 Structure of control algorithm .....	102
Figure 6- 12 Diagram of RPC .....	104
Figure 6- 13 Split instantaneous active and reactive current .....	104
Figure 6- 14 Generated reference current .....	105

# Contents

Acknowledgements.....	II
Abstract.....	III
Abbreviations.....	V
List of Figures.....	VIII
Chapter 1 Introduction .....	1
1.1 Motivation.....	1
1.2 Aims and objectives .....	3
1.3 State of the art technologies .....	6
1.3.1 Techniques related to RPC .....	7
1.3.2 Techniques for energy storage.....	9
1.4 Major contributions.....	9
1.4.1 GCI output with RPC .....	9
1.4.2 Interleaved bi-directional DC/DC converter for charging/discharging battery.....	10
1.4.3 MRes dissertation and publications.....	10
1.5 Outline of the thesis.....	10
Chapter 2 Experimental Environment .....	12
2.1 Introduction .....	12
2.2 Hardware environment.....	16
2.2.1 C2000 Solar PV inverter development board.....	16
2.2.2 NXP LPC 2132 ARM.....	16

2.2.3 TMS320F28335 DSP .....	16
2.2.4 Insulated-gate bipolar transistor (IGBT) .....	17
2.2.5 Voltage and current transducers .....	18
2.3 Software environment .....	20
2.3.1 MATLAB/Simulink.....	20
2.3.2 Keil uVision.....	20
2.3.3 Code composer studio .....	21
2.4 Mathematical tools .....	21
2.4.1 Clarke's transformation .....	21
2.4.2 Inverter Clarke's transformation .....	23
2.4.3 Park's transformation .....	23
2.4.4 Inverse Park's transformation.....	24
2.4.5 P-Q theory.....	25
2.5 Summary .....	26
Chapter 3 Phase-Locked Loop.....	27
3.1 Introduction .....	27
3.2 Generic PLL .....	28
3.3 SOGISPLL mathematical model.....	29
3.4 Discrete Implementation of SOGIPLL .....	34
3.5 Simulation .....	35
3.6 Summary .....	37

Chapter 4 AC to DC Rectifier.....	38
4.1 Introduction .....	38
4.2 Mathematical model of three-phase active rectifier.....	43
4.3 Current loop design .....	46
4.4 Voltage loop design.....	49
4.5 Simulation of a three-phase SVPWM active rectifier .....	53
4.5.1 Identify sector .....	54
4.5.2 Determine firing time for switching devices .....	56
4.5.3 Over modulation .....	60
4.5.4 Generating controlled PWM for SVPWM .....	61
4.6 Modelling three-phase SVPWM rectifier .....	62
4.6.1 Modelling identify area and firing time.....	63
4.7 Modelling single-phase rectifier.....	70
4.8 Summary .....	72
Chapter 5 Bi-directional interleaved boost/buck DC/DC converter .....	74
5.1 Introduction .....	74
5.2 Buck converter .....	75
5.3 Boost converter .....	77
5.4 Interleaved boost circuit .....	79
5.5 Modelling four-phase IBDBBC under boost mode.....	80
5.6 Modelling four-phase IBDBBC under buck mode .....	86



5.7 Summary .....	89
Chapter 6 GCI with RPC .....	90
6.1 Introduction .....	90
6.2 Topologies of a GCI.....	92
6.3 GCI based on HCC.....	94
6.4 Simulation of conventional single-phase GCI .....	95
6.5 RPC .....	99
6.5.1 Control strategies .....	101
6.6 Simulation of single-phase GCI with RPC .....	105
6.7 Simulation of three-phase GCI with RPC .....	112
6.8 Modelling of multi-inverter with RPC .....	114
6.9 Experimental verification of off-grid inverters .....	118
6.9.1 Generating synchronous signal.....	119
6.9.2 Frequency synchronisation .....	121
6.9.3 Experiment and results .....	121
6.10 Summary .....	123
Chapter 7 Conclusions and Future Work.....	124
7.1 Conclusions and Discussion.....	124
7.2 Future work .....	126
Appendix A Schematic Of Control Board For Single-Phase Inverter .....	127
Appendix B Schematic Of Sensors.....	128

Appendix C Schematic Of Main Control For Rectifier .....	129
Appendix D Schematic Of Signal Pre-Processing .....	130
Appendix E MATLAB Function Program .....	131
E.1 Clarke's transformation .....	131
E.2 Park's transformation.....	131
E.3 Inverse Park's transformation.....	131
E.4 Identify area .....	131
E.5 Firing time calculation .....	132
Appendix F Central Control Program.....	134
F.1 Main function codes.....	134
F.2 Configure PLL .....	134
F.3 Timer 0 codes.....	135
Appendix G Inverter Program .....	137
G.1 Main function codes .....	137
G.2 Extern interrupts codes .....	141
G.3 Timer 0 codes .....	144
G.4 PWM generator codes .....	148
Appendix H Three-phase SVPWM Rectifier Program.....	151
H.1 Three-phase rectifier with PFC codes .....	151
H.2 SVPWM generation .....	166
H.3 ADC sampling codes.....	170

References.....	174
-----------------	-----


# Chapter 1 Introduction

## 1.1 Motivation

In the past two decades, renewable power generation, such as wind and solar power, have experienced a considerable growth due to the problems the world faces in the dual challenges of fossil fuel depletion and carbon dioxide emissions (Fthenakis, et al., 2009). However the intermittent nature of renewable energy sources (typically wind and solar energy sources) is a major issue for the renewable power industry. DC/AC inverters play a key role in renewable power generation, which interfaces renewable power generators with the grid. However, a conventional GCI injects power from the renewable power generator directly into the grid, which fluctuates with the intermittent and unstable renewable energy sources.

Furthermore, the increase in generation uncertainty created by intermittent sources, such as photovoltaic (PV) cells and wind turbines, presents a challenge to the system stability of large power grids (Eltawil & Zhao, 2010). Renewable energy sources such as solar and wind are intermittent energy resources, especially as wind speeds and cloud movements cannot be accurately forecast in real time. For the solar energy, the maximum solar radiation occurs at around 13:00 hours each day. That means the power output of a solar PV panel theoretically reaches its maximum at this time despite the domestic demand being minimum. Therefore renewable power systems may operate in troughs of power demand, however the GCIs with an MPPT still output power into the grid in accordance with the code of compliance. Therefore, this may cause a voltage rise in the utility grid, which could result in the generation system being forced to be disconnected from the power grid when the voltage of the utility grid reaches its top limit.

Moreover, for a utility grid to operate properly, it is a prerequisite for GCIs to inject power into the grid when power is available. This means the primary issue of a GCI not being able to generate power even under the situation of best weather conditions for generation while the power grid is cut off for a reason either foreseeable (such as scheduled maintenance and power curtailment when power supply does not meet demand in general) or unforeseeable incidence (such as fire, flood). This is especially the case in some areas of the power system which are relatively vulnerable such as in developing countries in Saharan Africa and South-Asian where there are excellent solar energy sources, but unreliable or unavailable electricity grids.



**Figure 1- 1 Conventional RPC for solar PV power system**

Taken from (Eltawil & Zhao, 2010)

In addition, the increasing application of nonlinear loads, such as induction cookers, large variable frequency drives (VFD), switching-power supplies, induction motors and welding machine, may cause distribution system power quality issues, especially the production of a significant amount of reactive power and harmonics (Renukadevi & Jayanand, 2015). However, conventional distributed generation systems have limited capability to RPC. The use of a complementary external passive parallel RLC (resistor, inductor and capacitor) components or static synchronous compensator (STACOM) at the point common coupling

(PCC) shown in Figure 1-1 can provide compensation (Medina, et al., 2016). This increases the system and operation cost.

Finally, Llaría and Chicco presented that a system based on small-scale cogeneration could be more suitable than a large-scale distributed generation (Llaría, et al., 2011) (Chicco & Mancarella, 2009). Residential roof mounted solar PV system can be considered as a small-scale generation, so each individual small-scale system like that, connected to the same substation or community, can constitute a micro-grid system. But for the residential roof mounted solar PV system or commercial small-scale renewable power system, using Economy 7, a type of electricity tariff based on the time of use, the price of electricity on Economy 7 is very low during night, however night-time is the period of the lowest electricity consumption.


## **1.2 Aims and objectives**

This thesis aims

- 1) To develop a bi-directional GCI with RPC for a micro-grid by using interconnected small-scale GCIs sharing responsibility for community reactive power.
- 2) To develop an interleaved bi-directional boost/buck direction current to direction current (DC/DC) converter interfacing the DC link and the battery bank for charging/discharging batteries.

To mitigate the output voltage fluctuation from GCIs and improve customers' profitability, a battery bank at the inverter DC side, is included, interfaced by a bi-directional DC/DC converter with a DC-Bus as shown in Figure 1-2. In the community micro-grid, each individual inverter only injects excess power into the utility grid, generated from the renewable energy source (RES), with the premise that the battery bank is fully charged and the customers' requirements are completely met. During low tariff periods the inverter can be operated as an AC/DC controllable active rectifier to draw power from the utility grid to provide energy to


charge the battery bank by means of the bi-directional boost/buck DC/DC converter. Therefore, the inverter with those two control rules can minimise the end-user's electricity costs.



**Figure 1- 2 Proposed the diagram of small-scale GCIS**

Figure 1-2 presents the community micro-grid formed with a number of individual small-scale GCI system (GCIS), in which, the GCIS is integrated with a maximum power point tracking (MPPT) regulated DC/DC converter connecting solar PV panels or AC/DC converter connecting wind turbine generator, a bi-directional boost-buck DC/DC converters for charging/discharging batteries, and a bi-directional DC/AC inverter with RPC interfacing the DC bus and AC grid. A single GCI cannot provide RPC for a whole system, if each GCIS in the micro-grid system can quantitatively share responsibility RPC for whole system, then the conventional RPC devices or equipment illustrated in Figure 1-1 can be removed at the PCC node.

Figure 1-3 illustrates a diagram of micro-grid system, which consists of solar PV generations, wind turbines, electrical vehicle (EV), public utilities, GCISs and control centre. The Presented GCIS is used to interface between distributed sources and micro-grid.



**Figure 1- 3 Diagram of smart distributed micro-grid**

There are a number of established algorithms that can be employed to implement MPPT for both wind turbines and solar PV systems. Therefore, the MPPT algorithms are not considered in this thesis. To develop a smart GCIS for the micro-grid, the objectives of the project are:

1. To investigate the design process of a phase-locked loop (PLL) based on second order generalised integrator (SOGIPLL) for synchronising with the grid voltage and constructing orthogonal signals.
2. To model a bi-directional multi-phase interleaved boost/buck DC/DC converter.
3. To model an active rectifier with PFC based on the topologies of GCI for single-phase system.
4. To model a controllable active space vector pulse width modulation (SVPWM) rectifier with PFC based on the topologies of GCI for three-phase system.
5. To model a dispatchable single-phase hysteresis band GCI with RPC.



6. To model a dispatchable three-phase SVPWM GCI with RPC.
7. To model multi-inverter sharing RPC for a micro-grid.
8. To compare the results of modelling with measurements on a laboratory system.

### **1.3 State of the art technologies**

Nowadays, with technological developments, many clean renewable energy resources, such as solar, wind, hydro, tidal and biomass power are being utilised without emissions. Although renewable energy resources are clean and favoured by researchers for generation, the high penetration of renewable energy in distributed generation is associated with many new technical challenges in practical applications, such as grid voltage fluctuation, frequency regulation and RPC. Thereby, large amount of GCIs without proper technical infrastructure could have an impact and place significant harmonic stress on the electricity grid (Obi & Bass, 2016), unless the increasing GCIs have the dispatchable characteristics (Zarina, et al., 2012). Hence, during recent years, the micro-grid concept has been introduced, consisting of several alternative sources which can be considered plug-in or –out, while distributing electricity more efficiently and securely (Aghajani, et al., 2015) (Kamankesh, et al., 2016).

A micro-grid is commonly defined as a small community of interconnected loads and small-scale distributed generators (DGs) which can be dispatched or regulated by a control centre. A micro-grid is typically supplied by a MV/LV substation, and generally comprises DG, a smart meter and information communication (Sbordone, et al., 2016). The DG interfaces the resource and the micro-grid, it plays an important role, with the features of maintaining voltage balance, provide peak-shaving, optimise energy flux, and offer auxiliary services, which can be easily plugged-in or -out.

In the future, the numerous unpredictable loads introduced into the micro-grid, such as the expected increase of a number of EV charging stations, could bring chaos to a distributed grid

that has been fluctuating due to the intermittent nature of renewable energy sources. Sbordone et al propose solving these problems (Sbordone, et al., 2016) by the concept of integrating autonomous energy storage system at a location near the substation for reducing variability of power flow, providing balancing support, peak-shaving and load shifting. Panwar et al. present a strategy of incorporating regenerative fuel cells and EVs to solve the problem discussed above (Panwar, et al., 2015). Though the approach of configuring storage devices near a substation could enhance the stability of an entire distributed grid system, for a distributed micro-grid system, except the stabilising the grid, and minimising the user's costs which is also an important factor to be considered.

The voltage source inverter (VSI) is the most widely employed topology for this role with some common filter circuits,  $L$  (inductor) or  $LCL$  (inductor, capacitor and inductor), to achieve a DC/AC GCI for distributed generation (Sampaio, et al., 2016). Several related papers present various current control algorithms to feed active power into the grid. In order to enhance the stability of the grid system, the requirement of RPC has drawn more interest from researchers in the past few years.


### **1.3.1 Techniques related to RPC**

The most common volt amperes reactive (VAR) control approach for both small-scale and large-scale distributed generation is ensuring the inverter operates at a constant, unity power factor. The approach of utilising large passive capacitive banks or STACOM, at the PCC node, to maintain unity power factor is widely used. However, the major drawback of these approaches is not being able to inject RPC back to the grid. In other words, these approaches do not offer RPC for domestic loads. Variable power factor is a popular method, in which an inverse relationship between  $\frac{\Delta P}{\Delta Q}$  and the ratio of  $\frac{R}{X}$  at the PCC is established by setting the voltage variation difference to 0 (Smith, et al., 2011). This method observes the voltage

changes at the PCC to determine the extent of RPC. This is rather similar to the droop control technique, in which active power changing affects the grid frequency and reactive power influences grid voltage magnitude (Samadi, et al., 2014) (Rouzbehi, et al., 2014).

Sampaio et al. present, according to active and reactive power transfer, a strategy to control the power transfer angle by means of stabilising active power output and to control reactive power by reducing voltage magnitude fluctuation, which is actually quite similar to the droop control (Sampaio, et al., 2016).

Liu et al. proposed a topology of a single-stage for a single-phase GCI with wide range RPC, in which 3 full-bridge inverters are connected in series. One of the inverters injects active power into the main grid, and the other two auxiliary inverters interface dedicated energy storage for the grid, providing RPC, see Figure 1-4 (Liu, et al., 2010).



**Figure 1- 4 Topology of single-stage GCI**

Taken from (Liu, et al., 2010)

### **1.3.2 Techniques for energy storage**

Energy storage systems (ESS) can be traced back to early last century when power generation was often shut down overnight because power electronics control technology was not available (Baker & Collinson, 1999) (Suberu, et al., 2014) (Chen, et al., 2009). Initially, the commonly used ESS approach for peak-shaving in practical applications was hydroelectric pumped storage (HPS). With the technical development of storage, there are variety of storage media, including HPS, compressed air, flywheel, battery, flow battery, capacitor or supercapacitor, superconducting magnet, solar fuels and thermal energy storage (Luo, et al., 2015) (Kousksou, et al., 2014) (Rodrigues, et al., 2014) (Abdin, et al., 2015).

In recent years, integrating ESS into distributed generation systems has attracted many researchers' attention, associated with high penetration of renewable energy generation with unpredictable power fluctuation. These ESS especially include battery systems technology, which is the most widespread energy storage device for power applications. Batteries can be configured in different sizes with wide capacities ranging from watt-hours to gigawatt-hours (Aneke & Wang, 2016). There are many articles proposing a variety of applications aimed at mitigating fluctuation, balancing intermittency of wind or other renewables and RPC, by means of installing a central ESS close to the electrical substation (Suberu, et al., 2014) (Chicco & Mancarella, 2009) (Chen, et al., 2009).

## **1.4 Major contributions**

### **1.4.1 GCI output with RPC**

The thesis describes a novel algorithm, based on D-Q theory, to split the active and reactive currents, to quantitatively control active and reactive power for GCI.

### **1.4.2 Interleaved bi-directional DC/DC converter for charging/discharging battery**

In order to reduce the ripple of converter current and improve thermal dissipation issue, the thesis presents a topology of four-phase interleaved bi-directional DC/DC boost/buck converter (IDBBBC) for charging/discharging battery.

### **1.4.3 MRes dissertation and publications**

1. Fan, Z. & Liu, X., 2015. Smart Inverter with Active Power Control and Reactive Power Compensation. *Journal of Electrical and Electronic Engineering*, pp. 139-145.
2. Fan, Z., 2012. Mathematical Modelling of Grid Connected Fixed-Pitch Variable-Speed Permanent Magnet Synchronous Generators for Wind Turbines, Preston: UCLAN.
3. Fan, Z. & Liu, X., 2012. A novel universal voltage sag detection algorithm. *Power Engineering and Automation Conference (PEAM), IEEE publisher.*
4. Wen, C., Lu, G., Wang, P., Li, Z., Liu, X., Fan, Z., 2011. Vector control strategy for small-scale grid-connected PMSG wind turbine converter *Innovative Smart Grid Technologies (ISGT Europe) conference, IEEE publisher.*
5. Fan, Z. & Liu, X., *Reactive power compensation for single-phase inverter in microgrid* submitted to *International Journal of Advanced Engineering Research and Science* to be reviewed.

## **1.5 Outline of the thesis**

The structure of the thesis is as follows: In order to demonstrate methodologies and algorithms, simulations and experiments have been carried out which require specific software tools and hardware development kits to support them.

Chapter 2 describes the software tools, integrated development environment (IDE), the hardware development kit and mathematical tools.

Chapter 3 describes the step-by-step procedures on how to design a SOGIPLL for an embedded real time system and an algorithm, which is demonstrated through MATLAB/Simulink modelling and hardware implementation. PLL as a fundamental function for GCI plays a key role for an on-grid system.

Chapter 4 describes in detail the design of a three-phase SVPWM rectifier through constructing a pair of orthogonal signals for single-phase current, adopting Clarke's and Park's transformation into a single-phase system to split active and reactive current for a single-phase system. The modelling of both three-phase and single-phase rectifiers, and experimental work based on a three-phase SVPWM rectifier are conducted.

Chapter 5 describes the modelling of a four-phase, bi-directional, interleaved, boost/buck DC/DC converter, which can be an ideal charging/discharging converter for the battery storage in a micro-grid.

Chapter 6 presents a smart dispatchable GCI with RPC and the simulation model of multi-inverters synergistically providing RPC for a micro-grid.


Chapter 7 concludes the project with discussion of the project outcomes and briefs future research directions.

# Chapter 2 Experimental Environment

## 2.1 Introduction

In order to achieve power flow bi-directionally in a micro-grid, some key factors must be taken into account for building an experimental environment for a three-phase system achieve rectifier, based on a GCI topology. Another experimental environment for a single-phase GCI built to demonstrate multi-inverters operating synchronously in a stand-alone system without grid support.

Because the purpose of the rectifier is to achieve bi-directional power flow based on the inverter topology, Figure 2-1 illustrates a bi-directional rectifier/inverter topology in three-phase system consisting of 6 switching devices, if swapping the input and output in the figure, the system can be considered as the conventional three-phase inverter. This requires 6 PWM signal channels, and 3 sampling of phase voltages, and currents and 1 of DC bus voltage, totally requiring 7 channels of analogue to digital (AD) signal conversion. Another issue which has to be considered is to minimise filter inductance size before output by increasing the PWM signal frequency. Moreover, the algorithms for a three-phase SVPWM rectifier system contain complex trigonometrical functions and proportional-integral-derivative (PID) control which require mathematical floating point calculations. Therefore, a high speed TMS320F28335 processor with built-in floating-point unit was utilised to implement the three-phase AC/DC rectifier system.




**Figure 2- 1 Structure of bi-directional three-phase rectifier/inverter topology**

Digital Signal Processor (DSP) TMS320F28335 is a high-performance real-time controller with single-precision Floating-Point Unit (FPU) from Texas Instruments (TI). TMS320F28335 has a good number of peripheral ports, such as 18 PWM outputs and 16 channels 12-Bit ADC.


The C2000 Solar Inverter Development Kit (SDK) shown in Figure 2-2 is designed to achieve the general functions of a GCI. There are some special functions required by the thesis which need extra hardware to support them, such as inverter outputs synchronised with each other when operating in off-grid mode. Therefore, the control board has been re-designed by the author, as shown in Figure 2-4, to replace the original control board SDK shown in Figure 2-



3, using A LPC2132 NXP ARM microcontroller control the main board of the C2000™ SDK and this is utilised to implementing a single-phase inverter controlled by a central controller, implemented on a LPC2132 development board, illustrated in Figure 2-5.



**Figure 2- 2 The main board of C2000™ SDK**



**Figure 2- 3 Control board of C2000™ SDK**




Figure 2- 4 Re-designed control board




Figure 2- 5 Central control board



C/C++ was employed to program the controllers using CCS3.3 IDE and Keil uVision 4.0 for the TI DSP processor and ARM microcontroller respectively. All simulations in this thesis were modelled in MATLAB/ SIMULINK; part of the algorithms have been conducted through experiments, such as SVPWM rectifier in three-phase system. Three GCI operate in stand-alone mode.

## **2.2 Hardware environment**

### **2.2.1 C2000 Solar PV inverter development board**

Figures 2-2 and 2-3 show the *C2000*<sup>TM</sup> SDK is a development platform based on a DSP C2000 Microcontroller from Texas Instruments. The Development Kit is a general and conventional inverter, which is insufficient to provide communications between the inverter and a central controller. Therefore, the circuit of the control part of the Inverter Development Kit was redesigned and the C2000 Microcontroller replaced by a NXP LPC2132 ARM microcontroller to implement the function of a standalone inverter, which was used to demonstrate the feasibility of solving synchronising issues under circumstances of multi-inverter operate in off-grid mode. In the experiment, only three inverters connected together operate in off-grid mode.

### **2.2.2 NXP LPC 2132 ARM**

The LPC2132 microcontroller is based on a 16/32-bit ARM7TDMI-S control processor unit (CPU) with real-time emulation and embedded trace support and a 64kB embedded high-speed flash memory. A 128-bit wide memory interface and unique accelerator architecture enable 32-bit code execution at maximum clock rate. LPC2132 has 6 channels of PWM and 8 channels of 10-Bit A/D converter which are sufficient to implement a single-phase full-bridge inverter.

### **2.2.3 TMS320F28335 DSP**

TMS320F28335 is a high-performance static CMOS (Complementary Metal-Oxide Semiconductor) technology with speed up to 6.67ns cycle time. The total harmonic distortion

(THD) is inversely proportional to the switching frequency of the rectifier/inverter-bridge, which means using a high-speed DSP to implement active rectifier with PFC or GCI, which has the features of high reliability and power quality.

Enhanced control peripherals include 18 PWM outputs and 16 channel AD converters with 12-Bits resolution and 80ns high speed sampling rate. The most prominent feature of the F28335 DSP is that it has an excellent floating point, built-in coprocessor.

#### **2.2.4 Insulated-gate bipolar transistor (IGBT)**

An IGBT FF75R12RT4 shown in Figure 2-6 was utilised to build the three-phase rectifier/inverter-bridge; it is 34mm module with fast Trench/Fieldstop IGBT4 and Emitter Controlled 4 diodes, produced by Infineon. The voltage stresses of FF75R12RT4 between collector and emitter is up to 1200V, continuous DC maximum collector current is 75A and maximum repetitive peak collector current is 150A. The maximum turn-on and turn-off delay times are 0.15 $\mu$ s and 0.40 $\mu$ s respectively for inductive loads (MK, 2013-11-05).




**Figure 2- 6 IGBT FF75R12RT4**

### 2.2.5 Voltage and current transducers

TBC50SYH was chosen to measure three-phase rectifier current due to its 50A nominal current rating. The TBC-SYH series high-precision current sensor is a closed loop device based on Hall Effect, with a galvanic isolation between primary and secondary circuit. It has strong anti-jamming ability and can provide accurate electronic measurement of DC, AC or pulsed currents.

The TLP7820 optically isolated amplifier was used to measure voltage, using a delta-sigma AD converter input circuit and providing an analogue output via a 1 bit D/A and a low pass filter. Figure 2-7 shows sampling of an input voltage.




**Figure 2-7 Sampling circuit of input voltage**

The TLP7820 device, which is shown in Figure 2-8, can detect small current and voltage fluctuations with high-precision. It offers a common-mode transient immunity of 15kV/ $\mu$ s minimum, enabling stable operation in electrically noisy environments.



**Figure 2- 8 TLP7820 device**




**Figure 2- 9 Linear relationship between input and output of TLP7820**

According to the datasheet of the TLP7820, the analogue input voltage is limited between -300 mV +300 mV as shown in Figure 2-9. Assuming a maximum input the AC peak voltage of  $300 \times \sqrt{2}$  V, this must then be attenuated to 300mV. According to Figure 2-7, the gains  $G_s$  of sampling input voltage can be obtained in the following equation:

$$G_s = \frac{R_2}{R_{1a} + R_{1b} + R_{1c} + R_2} = 7.7459 \times 10^{-4} \quad (2 - 1)$$

Because the TLP7820 output signal is limited -300mV and +300mV without an amplifier, an additional stage of amplification with a gain of 10 was added between the output and sampling input, as shown in Figure 2-10.



**Figure 2- 10 Sampling Gain**

## 2.3 Software environment

### 2.3.1 MATLAB/Simulink

Simulink is a user friendly block diagram environment for simulation and Model-Based design, supporting simulation, automatic code generation, and continuous test and verification of embedded systems.

Simulink provides a graphical editor, customizable block libraries, and solvers for modelling and simulating dynamic systems. It is integrated with MATLAB, enabling incorporation of MATLAB algorithms into models and exportation of simulation results to MATLAB for further analysis.

### 2.3.2 Keil uVision

The MDK-ARM is a complete IDE for Cortex-M, Cortex-R4, ARM7 and ARM9 processor based devices. It is specifically designed for microcontroller applications with easy to use and

powerfully adequate for most embedded applications. Therefore, MDK-ARM was chosen to program the central control system using C/C++ language.

### **2.3.3 Code composer studio**

Code composer studio (CCS) is an IDE that supports TI's Microcontroller and Embedded Processors portfolio and comprises a suite of tools used to develop and debug embedded applications. CCS has resources to help developers, which can shorten development cycles and reduce development costs and improve development efficiency. The technology of Real-time Exchange Data (RTXD) was developed by TI, and gives designers continuous, real-time visibility into their applications. The bi-directional capability allows developers to access data from the application for real-time visibility, or to simulate data input to the DSP, perhaps before real-time sensor hardware is available.


In Simulink, the accuracy of results of simulation depends on the time step interval (The Math Works 2011). In general, the smaller the time step, the more accurate the simulated results. In the case of variable-step solvers, the solver can automatically determine the time step; in the case of fixed-step solvers, the time step can be specified. Therefore, the results of simulation based on MATLAB/Simulink have some tolerances compared with ideal mathematical models.

## **2.4 Mathematical methods**

### **2.4.1 Clarke's transformation**

Clarke's Transformation as shown in Figure 2-11. Considering a vector  $X$  ( $x_a$ ,  $x_b$  and  $x_c$ ),  $a$ -,  $b$ - and  $c$ - are the component vectors in directions  $a$ ,  $b$  and  $c$ , respectively, in the static three-phase system.  $x_\alpha$  and  $x_\beta$  are  $\alpha$ - and  $\beta$ -component vectors of  $X$  in the stationary two-phase frame  $\alpha\beta$  respectively. As Figure shows, the vector  $X$  in three-phase system can be expressed in stationary two-phase frame.





**Figure 2 - 11 Clarke's Transformation**

The voltages of a three-phase balanced system can be written as the following mathematical model:

$$\begin{cases} v_a = v_{max} \cos \omega t \\ v_b = v_{max} \cos \left( \omega t - \frac{2\pi}{3} \right) \\ v_c = v_{max} \cos \left( \omega t - \frac{4\pi}{3} \right) \end{cases} \quad (2-2)$$

Let

$$v_\alpha = v_{max} \cos \omega t$$

And the orthogonal variable of  $v_\alpha$  be  $v_\beta$ , so that:

$$v_\beta = v_{max} \sin \omega t$$

Adopting  $v_\alpha$  and  $v_\beta$  to simplify Equation (2-2) as follows:

$$v_a = v_\alpha \quad (2 - 2.1)$$

$$v_b = v_{max} \left( \cos \omega t \cos \frac{2\pi}{3} + \sin \omega t \sin \frac{2\pi}{3} \right)$$

$$= -\frac{1}{2}v_\alpha + \frac{\sqrt{3}}{2}v_\beta \quad (2-2.2)$$

$$\begin{aligned} v_c &= v_{max}(\cos \omega t \cos \frac{2\pi}{3} - \sin \omega t \sin \frac{2\pi}{3}) \\ &= -\frac{1}{2}v_\alpha - \frac{\sqrt{3}}{2}v_\beta \end{aligned} \quad (2-2.3)$$

Therefore, rearranging  $v_a$ ,  $v_b$  and  $v_c$

$$\begin{bmatrix} v_a \\ v_b \\ v_c \end{bmatrix} = A \begin{bmatrix} v_\alpha \\ v_\beta \end{bmatrix} \quad (2-3)$$

where  $A = \begin{bmatrix} 1 & 0 \\ -1/2 & \sqrt{3}/2 \\ -1/2 & -\sqrt{3}/2 \end{bmatrix}$

#### 2.4.2 Inverter Clarke's transformation

Finding the inverse matrix for the matrix A, then multiplying both sides of Equation (2-3) by the inverse of A results in Equation (2-4) giving  $v_\alpha$  and  $v_\beta$ .


$$\begin{bmatrix} v_\alpha \\ v_\beta \end{bmatrix} = \frac{2}{3} \begin{bmatrix} 1 & -1/2 & -1/2 \\ 0 & \sqrt{3}/2 & -\sqrt{3}/2 \end{bmatrix} \begin{bmatrix} v_a \\ v_b \\ v_c \end{bmatrix} \quad (2-4)$$

where,

$v_\alpha$ ,  $v_\beta$  are the stationary orthogonal reference frame quantities.

#### 2.4.3 Park's transformation

The two-axis stationary orthogonal reference frame quantities are transformed into a  $d$ - $q$  rotating reference frame using the Park's transformation as illustrated in Figure 2-12.



**Figure 2- 12 Park's transformation**

The rotating reference frame  $d$ - $q$  quantities can be obtained as follows.

$$\begin{cases} v_d = v_\alpha \cos \phi + v_\beta \sin \phi \\ v_q = v_\beta \cos \phi - v_\alpha \sin \phi \end{cases} \quad (2 - 5)$$

where,

$v_d, v_q$  are the rotating reference frame quantities.

$v_\alpha, v_\beta$  are the stationary orthogonal reference frame quantities.

$\phi$  is the rotational angle.

#### 2.4.4 Inverse Park's transformation

Then the Inverse Park's transformation can be expressed as the following equation:

$$\begin{cases} v_\alpha = v_d \cos \phi - v_q \sin \phi \\ v_\beta = v_q \cos \phi + v_d \sin \phi \end{cases} \quad (2 - 6)$$

where,

$v_d, v_q$  are the rotating reference frame quantities.

$v_\alpha, v_\beta$  are the stationary orthogonal reference frame quantities.

$\phi$  is the rotational angle.

### 2.4.5 P-Q theory

The voltages of a three-phase balanced system can be written as the following mathematical model:

$$\begin{cases} v_{sa} = A_m \cos \omega t \\ v_{sb} = A_m \cos \left( \omega t - \frac{2\pi}{3} \right) \\ v_{sc} = A_m \cos \left( \omega t - \frac{4\pi}{3} \right) \end{cases} \quad (2-7)$$

Through the  $d$ - $q$  coordinate transformation, the voltage of a three-phase system in the  $d$ - $q$  rotating frame system can be expressed as:

$$\begin{cases} v_d = A_m \\ v_q = 0 \end{cases} \quad (2-8)$$

According to the instantaneous power of P-Q theory, the three-phase active power  $P$  and reactive power  $Q$  can be written in the stationary frame system  $\alpha\beta$  as

$$\begin{bmatrix} P \\ Q \end{bmatrix} = \begin{bmatrix} v_\alpha & v_\beta \\ v_\beta & -v_\alpha \end{bmatrix} \begin{bmatrix} i_\alpha \\ i_\beta \end{bmatrix} \quad (2-9)$$

where  $v_\alpha, v_\beta$  and  $i_\alpha, i_\beta$  are mutually orthogonal pair of voltages and currents respectively.

Through Park's transformation, Equation (2-9) can be expressed as follows:

$$\begin{cases} P = v_d i_d + v_d i_q \cos \omega t (\sin \omega t - \cos \omega t) \\ Q = -v_d i_q \end{cases} \quad (2-10)$$

In Equation (2-10), as  $i_q$  approaches 0 then the reactive power component approaches 0 and only the active power remains, i.e. the term  $v_d i_d$ . Through analysing the above equation, the reactive power  $Q$  of the power grid can be controlled by adjusting the instantaneous quadrature component of current  $i_q$  in the  $d$ - $q$  rotating frame.

## **2.5 Summary**

In this chapter, the experimental environment, including hardware, software and programming IDE, are briefly introduced. Mathematical tools, particularly Park's, Clarke's transformation and P-Q theory, are addressed as well. These tools are widely employed in power electronic control algorithm development.

## Chapter 3 Phase-Locked Loop

### 3.1 Introduction

PLLs are common signal processing methods. They are widely used in applications such as measurement, coherent demodulation, time synchronisation, frequency synthesis, and other signal processing fields. There are a number of types of PLL depending on the implementation technology, including analogue PLL (APLL), digital PLL (DPLL), synchronous frame PLL (SFPLL) and soft PLL (SPLL). In the development of virtual radio technology, SPLL has been used widely (Liu, et al., 2007). The basic principle of SPLL is similar to that of conventional PLL, but differs significantly in the mathematical model, parameter design and implementation modalities (Bhardwaj, 2013) (Guo, et al., 2011).


The frequency, phase angle and amplitude of the AC voltage on the electricity grid are critical parameters for a GCI, employed to inject AC power to the grid, to ensure the inverter system operates properly and does not cause grid transients. In order to generate the reference control signals for the PWM control of the inverter switches, accurate detection of the phase angle of the electrical quantities on the grid is essential.

A few topologies of PLL for GCIs have been implemented in industrial applications. The sine and cosine of the phase angle are key parameters for a GCI; conventional methods yield those parameters by firstly obtaining phase angle from the power grid voltage, then through a series of trigonometric computations. Actually, because the grid voltage is a sine signal, obtaining the grid voltage phase angle is unnecessary if a pair of orthogonal signals from a sampling of the sine signal can be obtained. The SOGI can generate a pair of orthogonal signals, therefore a SOGIPLL, with a strong anti-interference PLL algorithm, has been introduced to achieve phase synchronisation with the grid. This technique has been analysed in detail in the analogue

continuous-time domain (Rodriguez, et al., 2009) and the implementation in the digital discrete-time domain is described in this chapter. Finally the results of simulation are presented.


## 3.2 Generic PLL

Figure 3-1 shows the functional block diagram of a generic PLL, where  $\phi_i$  and  $\phi_o$  are the relative phase angles of the input and output voltage signals  $v_i$  and  $v_o$ . The Phase Detector multiplies the input and output signals and produces a voltage  $v_d$  proportional to the phase difference between the input frequency with feedback frequency output, which contains a second harmonic term that need to be removed by the Loop Filter, which is a low-pass filter. The Loop Filter outputs voltage  $v_{vco}$  which is proportional to the phase difference  $\phi_i - \phi_o$  and employed to control the Voltage Controlled Oscillator (VCO).



**Figure 3- 1 Diagram of generic PLL**


A conventional linearised SFPLL block diagram is illustrated in Figure 3-2, which is widely employed in three-phase GCI applications. The instantaneous phase angle  $\phi$  is detected by synchronising the d-q rotating reference frame with the three-phase electricity grid. When the phase angle is locked to the phase angle of grid voltage vector, the output quadrature component should be 0 and the direct component indicates the grid voltage amplitude.




**Figure 3- 2 Linearised conventional SFPLL block diagram**

### 3.3 SOGISPLL mathematical model

Figures 3-3 and 3-4 illustrate block diagrams of both open-loop and close-loop implementations of a SOGI, respectively (Fan & Liu, 2015).



**Figure 3- 3 Open-loop system of SOGI**



**Figure 3- 4 Close-loop system of SOGI**

According to the Figures above, let  $X$  represent the input signal  $v_i \sin \omega t$ , let  $Y_1$  represent the output signal  $v_o \sin \omega t$  and  $Y_2$  represent the output signal  $-v_o \cos \omega t$ , then the mathematical model of the close-loop system in the Laplace domain can be expressed as:



$$\begin{cases} Y_1 = \frac{(K(X - Y_1) - Y_2)\omega}{s} \\ Y_2 = \frac{Y_1\omega}{s} \end{cases} \quad (3-1)$$

where,

$K$  is the gain which affects the speed of response and the bandwidth of the close-loop system,

$\omega$  is the signal frequency in radians, and

$\frac{1}{s}$  is the integrator in Laplace domain.

Substituting  $\frac{Y_1\omega}{s}$  for  $Y_2$  and rearranging Equation (3-1) yields:

$$\begin{cases} Y_1 = \frac{K\omega s X}{s^2 + K\omega s + \omega^2} \\ Y_2 = \frac{K\omega s X}{s^2 + K\omega s + \omega^2} \cdot \frac{\omega}{s} \end{cases} \quad (3-2)$$

So the transfer function of the close-loop system can be obtained as:


$$\begin{cases} H_{s1} = \frac{Y_1}{X} = \frac{K\omega s}{s^2 + K\omega s + \omega^2} \\ H_{s2} = \frac{Y_2}{X} = \frac{K\omega^2}{s^2 + K\omega s + \omega^2} \end{cases} \quad (3-3)$$

Converting the denominators to the standard second order form:

$$s^2 + 2\zeta\omega s + \omega^2 \quad (3-4)$$

where,  $\zeta$  is the damping factor (typically  $\zeta=1/\sqrt{2}=0.707$ ), so in the term of denominator of Equation (3-3),  $K = 2\zeta = 1.414$  and the frequency of the electricity grid is 50 Hz, which means  $\omega = 2\pi 50$  rad/s.

Figure 3-5 illustrates the step responses of the system with the gain of  $K=0.5, 1.2, 1.414, 2$  and  $3$  respectively. These responses show that the system reaches steady state conditions, and the shortest time is  $0.0247s$  when the gain  $K = 2\zeta = \sqrt{2}$  (i.e.  $\zeta = \frac{1}{\sqrt{2}}$ ), as the response in red on the graph below.



**Figure 3- 5 Step responses of a closed-loop SOGIPLL in continuous-time**

Equation (3-3) is the transfer function of the close-loop system in continuous-time in the Laplace domain. The equivalent discrete-time transfer function is required to implement the second order integrator in a digital signal system. There are a number of methods that can be employed to obtain the discrete-time approximation of a continuous-time transfer function, such as Forward Difference, Backward Difference, Tustin's Approximation and Bilinear Transformation. (Ogata, 1995).

Tustin's approximation, also known as Euler's method or Trapezoidal Approximation, (Ciobotaru, et al., 2006) is a common method and is demonstrated below using the substitution

$\frac{2}{T} \frac{z-1}{z+1}$  to replace the Laplace operator  $s$ .

$$H_{s1} = \frac{Y_1}{X} = \frac{K\omega s}{s^2 + K\omega s + \omega^2} = \frac{444.2208s}{s^2 + 444.2208s + 98696.044}$$

Substituting  $\frac{2}{T} \frac{z-1}{z+1}$  for the Laplace operator for  $s$  and sampling time  $2e-5s$  for  $T$ , results in

$$H_{z1} = \frac{444.2208 \frac{2}{2 \times 10^{-5}} \frac{z-1}{z+1}}{\left( \frac{2}{2 \times 10^{-5}} \frac{z-1}{z+1} \right)^2 + 444.2208 \frac{2}{2 \times 10^{-5}} \frac{z-1}{z+1} + 98696.044}$$

This result simplifies to

$$H_{z1} = \frac{0.004423z^2 - 0.004423}{z^2 + 1.991z + 0.9912} \quad (3 - 5)$$

$$H_{s2} = \frac{Y_2}{X} = \frac{K\omega^2}{s^2 + K\omega s + \omega^2} = \frac{139556.21}{s^2 + 444.2208s + 98696.044}$$

Substituting the Laplace operator  $s$  with  $\frac{2}{T} \frac{z-1}{z+1}$  and sampling time  $T$  with  $2e-5s$

$$H_{z2} = \frac{139556.21}{\left( \frac{2}{2 \times 10^{-5}} \frac{z-1}{z+1} \right)^2 + 444.2208 \frac{2}{2 \times 10^{-5}} \frac{z-1}{z+1} + 98696.044}$$

On rearrangement this becomes

$$H_{z2} = \frac{1.389 \times 10^{-5} z^2 + 2.779 \times 10^{-5} z + 1.389 \times 10^{-5}}{z^2 + 1.991z + 0.9912} \quad (3 - 6)$$

MATLAB's `c2d` command can also be utilised to convert continuous to discrete transfer function as in the following example.

```

>> W=2*pi*50;
>> K=1.414;
>> H1=tf([K*W 0],[1 K*W W*W])

H1 =

          444.2 s
-----
s^2 + 444.2 s + 9.87e04

Continuous-time transfer function.

>> HD1=c2d(H1,2e-5,'tustin')

HD1 =

    0.004423 z^2 - 0.004423
-----
    z^2 - 1.991 z + 0.9912

Sample time: 2e-05 seconds
Discrete-time transfer function.


>> W=2*pi*50;
>> K=1.414;
>> H2=tf(K*W*W,[1 K*W W*W])

H2 =

          1.396e05
-----
s^2 + 444.2 s + 9.87e04

Continuous-time transfer function.

>> HD2=c2d(H2,2e-5,'tustin')

HD2 =

    1.389e-05 z^2 + 2.779e-05 z + 1.389e-05
-----
           z^2 - 1.991 z + 0.9912

Sample time: 2e-05 seconds
Discrete-time transfer function.

```

The MATLAB results and the results produces by Tustin's Approximation are the same.

### 3.4 Discrete Implementation of SOGIPLL


Equations (3-5) and (3-6) show that the SOGIPLL system response functions are second-order digital filters with feedback. Hence, they can be achieved using an infinite impulse response (IIR) digital filter. The standard form of a digital second order IIR filter is shown below:

$$H_d(Z) = \frac{b_0 + b_1 z^{-1} + b_2 z^{-2}}{a_0 + a_1 z^{-1} + a_2 z^{-2}}$$

where  $b_0, b_1$  and  $b_2$  are feed-forward coefficients

$a_0, a_1$  and  $a_2$  are feed-back coefficients

Figure 3-6 shows a general block diagram of the digital second order IIR filter in Direct Form II structure.



**Figure 3- 6 Direct Form II structure for IIR filter**

where the  $Z^{-1}$  blocks represent a single sample delay and the nodes  $E(n)$ ,  $E(n-1)$  and  $E(n-2)$  represent memory for temporary storage during the calculations.

The Equations of the discrete transfer function, (3-5) and (3-6), can be written as the relationship between instantaneous input and output as follows:

$$H_{z1} = \frac{v_o(n)}{v_i(n)} = \frac{Y_{1(n)}}{X_{(n)}} = \frac{0.004423z^2 - 0.004423}{z^2 + 1.991z + 0.9912} \quad (3-7)$$

$$H_{z2} = \frac{v_o(n)}{v_i(n)} = \frac{Y_{2(n)}}{X_{(n)}} = \frac{1.389z + 2.779 \times 10^{-5}z + 1.389 \times 10^{-5}}{Z^2 + 1.991z + 0.9912} \quad (3-8)$$

where  $v_{i(n)}$  is the system discrete input and  $v_{o(n)}$  is the system discrete output.

Multiplying the numerator and denominator by  $z^{-2}$  and solving for instantaneous output  $Y_{1(n)}$ .

For Equation (3-7) this gives.

$$(1+1.991z^{-1}+0.9912z^{-2})Y_{1(n)} = (0.004423-0.4423z^{-2})X_{(n)}$$

Which yields

$$Y_{1(n)} = 0.004423X_{(n)}-0.4423z^{-2}X_{(n)}-1.991z^{-1}Y_{1(n)}-0.9912z^{-2}Y_{1(n)}$$

According to  $X_{(n)}z^{-k} = X_{(n-k)}$  and  $Y_{1(n)}z^{-k} = Y_{1(n-k)}$ , rearranging the equation above gives

$$Y_{1(n)} = 0.004423X_{(n)}-0.4423X_{(n-2)}-1.991Y_{1(n-1)}-0.9912Y_{1(n-2)} \quad (3-9)$$

Now for Equation (3-9), multiplying the numerator and denominator by  $z^{-2}$  and solving for instantaneous output  $Y_{2(n)}$  gives.

$$(1+1.991z^{-1}+0.9912z^{-2})Y_{2(n)} = (1.389 \times 10^{-5} + 2.779 \times 10^{-5}z^{-1} + 1.389 \times 10^{-5}z^{-2})X_{(n)}$$


Substituting  $X_{(n)}z^{-k} = X_{(n-k)}$  and  $Y_{2(n)}z^{-k} = Y_{2(n-k)}$ , and rearranging gives

$$Y_{2(n)} = 1.389 \times 10^{-5}X_{(n)} + 2.779 \times 10^{-5}X_{(n-1)} + 1.389 \times 10^{-5}X_{(n-2)} - 1.991Y_{2(n-1)} - 0.9912Y_{2(n-2)} \quad (3-10)$$


### 3.5 Simulation

The Simulink model created by utilising MATLAB/Simulink according to Equations (3-9) and (3-10) is illustrated in Figure 3-7. A random white noise generator is added at the input terminal to test the stability and anti-interference capability of the system. In a practical system, the


sampling accuracy of the analogue to digital signal converter is affected by noise and/or system drift.



**Figure 3- 7 Simulink model of SOGIPLL**



**Figure 3- 8 Comparison between input with white noises and PLL output**



**Figure 3- 9 Comparison of original input and PLL output**

Figure 3-8 shows that the output of the SOGIPLL has anti-interference performance when random white noise is added to an input signal with 50 Hz frequency. Additionally, Figure 3-9 shows the sine (blue line) and cosine (green line) generated by the SOGIPLL follows the original input signal (red line) after one periods, the difference between the output (blue line) and the input (red line) wave has decreased to negligible levels.

### 3.6 Summary

The simulation results demonstrate that SOGI orthogonal output signals with anti-interference performance can be employed to implement PLL in a GCIS. In addition, SOGI only requires one input signal, which means the model can be applied in both single-phase and three-phase GCIs.



# Chapter 4 AC to DC Rectifier

## 4.1 Introduction

A Three-phase SVPWM rectifier has attractive characteristics including controllable DC output voltage, low THD, high power factor for the grid current (Zheng, et al., 2010), and bi-directional power flow, which are the major features considered in this thesis.

Rapid growth of renewable power generation in the past decade has certainly been facilitated advanced inverter technology development, which plays a key role in interfacing renewable power generators with the power grid. The most popular three-phase inverter circuit consists of six IGBT switches in a full-bridge configuration, because IGBT has relative higher voltage and current rating. The single-phase inverter circuit is formed by four IGBT switches in a full-bridge.

The full-bridge topology composed of IGBTs or MOSFETs not only utilities to inverter DC voltage into power grid, it also can implement an active controllable rectifier.

Because each switching devices in full-bridge circuit is equipped with an anti-parallel, flywheel diode to protect the device if the load is inductive, as all the switching devices without PWM control signals the full-bridge circuit could be operated in the uncontrollable rectifier mode, because of each switching device has flywheel diode connected in shunt.

As using PWM signals to control switching devices, then the full-bridge topology could be operated in active controllable rectifier or inverter mode, which depends on different control algorithms.





During off-peak or low-tariff hours for peak-hour or high-tariff hours use, integrating energy storage on the DC bus link to store power from grid has great potential advantage.

Conventional renewable energy GCI interfaces to the power grid with as much renewable generator power output as it can deliver but does not offer RPC, which is normally provided by dedicated local reactive power or is matched by the reactive capability of synchronous generators in large power stations.

For a load centre, it is a general practice to compensate reactive power demand from the load centre at the PCC so as to maintain a statutory voltage at the PCC and the distribution network and minimise the line loss. Large synchronous generators are required to produce reactive power, because transmission lines demand reactive power in addition to that needed at distribution load centres. For a more distributed power generation system, it would be ideal that all generation units share the responsibility of providing reactive power.


There are a number of topologies presented to implement active rectifiers with PFC, such as the buck rectifier, boost rectifier, buck-boost rectifier, H-bridge converters (Rodriguez, et al., 2016), and Vienna rectifier (Kedjar, et al., 2014; Shaon & Salam, 2014). Figure 4-1 shows the basic rectifier topologies with PFC.

Although all the topologies of single-phase active rectifiers shown in Figure 4-1 can achieve high performance PFC, only Figure 4-1(d) can provide bi-directional power flow for a single-phase system.



**Figure 4- 1 Basic rectifier topologies with PFC**

Because the voltage stress of each switching device is only half of the total output voltage, the topology of the Vienna rectifier shown in Figure 4-2 is the most attractive (Shaon & Salam, 2014) in the application of large power rectifiers.




**Figure 4- 2 Topology of Vienna rectifier**

In terms of control measures, there are many control techniques presented in literature; examples include PWM, sinusoidal PWM (SPWM), Hysteresis PWM (HPWM), SVPWM, and Fuzzy PWM (FPWM). Although the switching losses of the SPWM can be reduced by means of modifying the carrier signal, it results in greater harmonic distortion, which causes poor power factor (Ting, et al., 2015). The control algorithm of HPWM is simple and has greater dynamic response than the PWM and SVPWM because the PWM ratio is adjusted at each PWM period; on the other hand, it has a higher ripple current (Ting, et al., 2015). The SVPWM has low switching losses and provides superior overall performance and power conversion efficiency (Ahmed & Ali, 2013), and is broadly used to implement active controllable rectifiers with PFC in three-phase systems.

The PWM algorithm is widely used in single-phase, buck, boost, and buck-boost rectifiers, according to the linear relationship between the instantaneous input and output to regulate the ratio of PWM duty.

This chapter presents a SVPWM rectifier algorithm based on three-phase GCI topology to achieve an active rectifier with PFC and presents a novel rectifier algorithm for a single-phase rectifier with PFC, so that an inverter cannot only deliver quantitative active power with quantitative RPC to the grid when it operates as an inverter, but can also implement an active rectifier with PFC.

In the topology of a three-phase inverter shown in Figure 4-3, each of the IGBTs shunts a freewheeling diode in the full-bridge inverter circuit so as to provide a complete circuit loop to protect the IGBTs from being damaged by the reverse current of an inductive load when the IGBTs are switched off. This means the circuit actually can be operated as a conventional uncontrolled rectifier while the voltage source is considered as an electrical load.




**Figure 4- 3 Topology of three-phase full-bridge inverter**

The disadvantages of a conventional power rectifier utilising passive diodes and capacitors contain AC current distortion and harmonic injection to the power grid. Harmonics are a major factor in determining power quality due to increasing non-linear loads; its impedance changes with the applied voltage in power systems. Harmonics cause problems in power systems and in consumer products, such as voltage distortion at the PCC (Bakar, 2008), capacitors in

equipment overheating, motor vibration, excessive neutral currents and lower power factor (Kale & Ozdemir, 2005), contribute low power conversion efficiency to the system. So improving the power factor, stabilising the rectifier DC output and reducing harmonic distortion has attracted the interest of many researchers (Moungkhum & Subsingha, 2013). Figure 4-3 is similar to Figure 2-1, they can attain bi-directional current flowing high power quality active rectifier or GCI in a three-phase system. Therefore, the following research about three-phase active rectifier is based on this concept.

## 4.2 Mathematical model of three-phase active rectifier

Figure 4-4 illustrates a topology from a MATLAB/Simulink of a three-phase full-bridge active rectifier. The full-bridge topology also can be operated in GCI mode if PWM control signals are changed and the load  $R_L$  in Figure 4-4 is replaced with a DC voltage source, for example DC bus link.



**Figure 4- 4 Topology of three-phase full-bridge active rectifier**

Hence, the topology illustrated above is able to implement power flowing bi-directionally. The relationships in a dynamic three-phase system of current and voltage can be described in a switched functional mathematical model as follows:

$$\begin{cases} L \frac{di_a}{dt} = e_a - Ri_a - v_{dc} \left( \frac{2S_u - S_v - S_w}{3} \right) \\ L \frac{di_b}{dt} = e_b - Ri_b - v_{dc} \left( \frac{2S_v - S_u - S_w}{3} \right) \\ L \frac{di_c}{dt} = e_c - Ri_c - v_{dc} \left( \frac{2S_w - S_u - S_v}{3} \right) \end{cases} \quad (4-1)$$

where

$i_a$ ,  $i_b$  and  $i_c$  are the instantaneous AC currents of phases A, B and C respectively.

$e_a$ ,  $e_b$  and  $e_c$  are the instantaneous voltages of the power grid.

$v_{dc}$  is the voltage of the DC bus.

$R$  is the equivalent resistance of the input filter inductors shown in Figure 4-4.

$L$  is the inductance of the input filter inductors shown in Figure 4-4.

$S_u$ ,  $S_v$  and  $S_w$  are the switching status of the upper switching devices of each pair switching devices such as  $S_1$  and  $S_2$ ,  $S_3$  and  $S_4$ ,  $S_5$  and  $S_6$  in Figure 4-4 respectively, in which, logic 1 represents that the upper devices are switched on and logic 0 means switched off.

The mathematical model of the three-phase static system is clearly described by Equation (4-1). However, according to Equation (4-1) the design of the control system is a difficult challenge due to the fact that the equation shows the system is a time-variant AC system and the variables to be controlled couple each other making the system complex. Therefore, applying Clarke's and Park's transformation simplifies the process.

Through Clarke's and Park's transformation, Equation (4-1) mathematical model yields the  $d$ - $q$  rotating reference frame as follows:

$$\begin{cases} L \frac{di_d}{dt} = e_d - Ri_d - v_{dc}S_d + \omega Li_q \\ L \frac{di_q}{dt} = e_q - Ri_q - v_{dc}S_q - \omega Li_d \end{cases} \quad (4-2)$$

where

$e_d$  and  $e_q$  are  $d$  and  $q$  components of the grid three-phase voltage vector ( $e_{dq}$ ) respectively.

$v_{dc}S_d$  and  $v_{dc}S_q$  are  $d$  and  $q$  components of the voltage vector of the rectifier at the three-phase grid side respectively.

$i_d$  and  $i_q$  are  $d$  and  $q$  components of the current vector of the rectifier at the three-phase grid side respectively.

In the  $d$ - $q$  rotating reference frame, assuming the  $e_d$  component of the grid three-phase voltage vector falls in the  $d$ -direction, the  $e_q$  component is equal to 0. The  $d$  and  $q$  components in Equation (4-2) still couple each other, so using the feed forward decoupling control method (Milosevic, 2003) with PI control for the current in the  $d$ - $q$  frame, then the  $d$  and  $q$  components of the voltage vector of the rectifier, at the three-phase grid side can be obtained as follows:

$$\begin{cases} v_d = -\left(K_{dp} + \frac{K_{di}}{s}\right)(i_{dr} - i_d) + e_d + \omega Li_q \\ v_q = -\left(K_{qp} + \frac{K_{qi}}{s}\right)(i_{qr} - i_q) + e_q - \omega Li_d \end{cases} \quad (4-3)$$

where

$K_{dp}$  and  $K_{qp}$  are the proportional gain of the PI compensator.

$K_{di}$  and  $K_{qi}$  are the integrator gain of the PI compensator.

$i_{dr}$  and  $i_{qr}$  are reference current for  $d$  and  $q$  components of the current vector.



Because at the grid side,  $d$ - and  $q$ - components of three-phase VSR,  $v_d = v_{dc}S_d$  and  $v_q = v_{dc}S_q$ , so substituting Equation (4-3) into Equation (4-2) to eliminate terms of  $e_d - v_{dc}S_d + \omega Li_q$  and  $e_q - v_{dc}S_q - \omega Li_d$  respectively gives:


$$\begin{cases} L \frac{di_d}{dt} = -Ri_d + \left( K_{dp} + \frac{K_{di}}{s} \right) (i_{dr} - i_d) \\ L \frac{di_q}{dt} = -Ri_q + \left( K_{qp} + \frac{K_{qi}}{s} \right) (i_{qr} - i_q) \end{cases} \quad (4-4)$$

### 4.3 Current loop design

The feed forward control as described in Equations (4-3) and (4-4) reveals that the current loop of a three-phase voltage source rectifier has been successfully achieved.

This analysis only focuses on the  $d$ -axis quantities of current due to the symmetry between the  $d$  and  $q$  current quantities, as Equation (4-4) suggests.

In practical applications, considering some delays from sampling to computation results, in order to enhance system performance and controlled accuracy, it is necessary to add certain delays and gain parameters into a system. The  $d$ -component of the current loop control diagram with the perturbation of  $d$ -component of the power grid is illustrated in Figure 4-5.




**Figure 4- 5 d-component of current-loop control diagram**

In Figure 4-5,  $T_s$  is the system sampling time,  $K_{PWM}$  is the system equivalent gain of the PWM,  $R$  is the equivalent resistance of the input filter inductor and  $L$  is the inductance,  $e_d$  is the perturbation of the voltage d-component at the grid side. In order to facilitate analysis and design of the system, writing the PI control equation in a pole-zero style (assuming the small

fluctuation of  $d$ -axis quantities of the grid voltage is ignored and combining the two delays in the transfer function,  $T_s$  and  $0.5 T_s$ ), then the current-loop control diagram can be simplified as in Figure 4-5.

$$K_p + \frac{K_i}{s} = K_p \frac{s + A}{s} = K_p \frac{\frac{1}{A}s + 1}{\frac{1}{A}s}$$

where  $A = \frac{K_i}{K_p}$ .




**Figure 4- 6 Simplified current-loop control**

According to the classical control theory, classical type I control system has faster response than type II and III. In Figure 4-6, the system could be simplified to a type I control system if PI's zero can eliminate transfer function's pole. So assuming  $A = R/L$ , the open-loop transfer function of the simplified current-loop control shown in Figure 4-6 can be expressed as the following mathematical model.

$$H_{id} = \frac{K_p K_{PWM}}{sL(1.5T_s s + 1)} \quad (4 - 5)$$

According to Equation (4-5), the block diagram in Figure 4-6 can be equivalently further simplified as in the following figure.



**Figure 4- 7 Final d-component of current-loop control**

Let  $K = \frac{K_p K_{PWM}}{L}$ , then the open-loop transfer function of the current  $i_d$  shown in Figure 4-6 can be expressed as:

$$H_{id} = \frac{K}{s(1.5T_s s + 1)} \quad (4-6)$$

And the close-loop transfer function of the current  $i_d$  shown in Figure 4-7 can be obtained as:

$$\begin{aligned} E_s &= \frac{\frac{K}{s(1.5T_s s + 1)}}{1 + \frac{K}{s(1.5T_s s + 1)}} = \frac{K}{s(1.5T_s s + 1) + K} \\ &= \frac{\frac{K}{1.5T_s}}{s^2 + \frac{1}{1.5T_s}s + \frac{K}{1.5T_s}} \end{aligned} \quad (4-7)$$

Now convert the denominator of  $E_s$  to the standard form below

$$s^2 + 2\zeta\omega s + \omega^2 \quad (4-8)$$

Comparing Equation (4-7) with the standard form Equation (4-8) yields the following two quantities.

$$\omega = \sqrt{\frac{K}{1.5T_s}}$$

$$\zeta = \frac{1}{2\sqrt{1.5KT_s}}$$

Typically the damping factor  $\zeta = \frac{1}{\sqrt{2}} \approx 0.707$  is used with  $K = \frac{K_p K_{PWM}}{L}$ , then the proportional parameter  $K_P$  of the current loop can be obtained as

$$K_P = \frac{L}{3T_s K_{PWM}} \quad (4-9)$$

Because  $\frac{K_i}{K_p} = \frac{R}{L}$ , the integral parameter can be found

$$K_i = \frac{K_p R}{L} = \frac{R}{3T_S K_{PWM}} \quad (4-10)$$

Thus, Equations (4-9) and (4-10) represent the proportional and integral parameters of the PI controller for the current loop  $K_{dp}$  and  $K_{di}$  in Equation (4-4).

## 4.4 Voltage loop design

In the  $d$ - $q$  rotating reference frame, the system Equation (4-8) can be expressed as

$$\begin{cases} Lp i_d = e_d - R i_d - v_d + \omega L i_q \\ Lp i_q = e_q - R i_q - v_q - \omega L i_d \end{cases} \quad (4-11)$$

$$v_{dc} i_{dc} = \frac{3}{2} (v_d i_d + v_q i_q) \quad (4-12)$$

$$p v_{dc} = \frac{1}{C_o} (i_{dc} - i_L) \quad (4-13)$$

where

$p$  is the differential operator  $d/dt$ ,

$e_d$  and  $e_q$  are the  $d$ -axis and  $q$ -axis voltage components of the power grid respectively,

$R$  is the equivalent resistance of input filter inductor,

$v_d$  and  $v_q$  are the  $d$ -axis and  $q$ -axis voltage components of the rectifier at the AC side, respectively,

$L$  is the inductance of input filter inductor,

$\omega$  is the angular frequency of the voltage of the power grid in  $rad/s$ ,

$i_d$  and  $i_q$  are the  $d$ -axis and  $q$ -axis current components of the rectifier at the AC side, respectively,

$C_o$  is the capacitance of the output filter of the rectifier,

$i_L$  is the DC load current,

$v_{dc}$  is the DC output voltage, and

$i_{dc}$  is the rectifier output current.

Assuming the system is operating on rectifier mode with unity power factor and the  $d$ -axis component of the rectifier at the AC side overlaps with the  $d$ -axis component of the power grid (which means  $e_q = 0$ ,  $v_q = 0$  and  $i_q = 0$ ), then Equations (4-11), (4-12) and (4-13) can be simplified as

$$pi_d = \frac{e_d - v_d - Ri_d}{L} \quad (4 - 14)$$

$$vi_{dc} = v_d i_d \quad (4 - 15)$$

$$pv = \frac{i_{dc} - i_L}{C} \quad (4 - 16)$$

where,

$$v = \frac{2}{3}v_{dc} \text{ and } C = \frac{3}{2}C_o.$$

According to Equation (4-16), the second order differential equation of the output DC voltage  $v$  can be written as

$$v = p \left( \frac{i_{dc} - i_L}{C} \right) = \frac{1}{C}pi_{dc} - \frac{1}{C}pi_L \quad (4 - 17)$$

And rearranging Equation (4-15) yields the rectifier output current  $i_{dc}$  as

$$i_{dc} = \frac{v_d}{v} i_d \quad (4 - 18)$$

Differentiating both sides of the above equation gives

$$p i_{dc} = p \left( \frac{v_d}{v} i_d \right) = i_d p \frac{v_d}{v} + \frac{v_d}{v} p i_d \quad (4 - 19)$$

Combining Equations (4-16) and (4-18) yields the  $d$ -component of the current of the rectifier at the AC side,  $i_d$ .

$$i_d = \frac{v}{v_d} i_{dc} = \frac{v}{v_d} (C p v + i_L) \quad (4 - 20)$$

Substituting Equation (4-20) into Equation (4-14) with  $i_d$  yields

$$p i_d = \frac{e_d - v_d}{L} - \frac{R}{L} \cdot \frac{v}{v_d} (C p v + i_L) \quad (4 - 21)$$

Substituting Equations (4-20) and (4-21) into Equation (4-19) with  $i_d$  and  $p i_d$ , then substituting the new Equation (4-19) into Equation (4-17) with  $p i_{dc}$  yields the second order differential equation of the DC output voltage  $v$  as

$$\begin{aligned} v &= p \left( \frac{i_{dc} - i_L}{C} \right) \\ &= \left[ \frac{v}{v_d} p \left( \frac{v_d}{v} \right) - \frac{R}{L} \right] + \frac{v_d (e_d - v_d)}{v L C} - \frac{i_L}{C} \left[ p + \frac{R}{L} - \frac{v}{v_d} p \left( \frac{v_d}{v} \right) \right] \end{aligned} \quad (4 - 22)$$

Rearranging Equations (4-22) and (4-16) as a state equation gives

$$p[X] = AX + BU \quad (4 - 23)$$

where

$$X = \left[ \frac{V}{\frac{i_{dc} - i_L}{C}} \right]$$

$$A = \begin{bmatrix} 0 & 1 \\ 0 & \frac{v}{v_d} p \left( \frac{v_d}{v} \right) - \frac{R}{L} \end{bmatrix}$$

$$B = \begin{bmatrix} 0 \\ \frac{v_d(e_d - v_d)}{vLC} - \frac{i_L}{C} \left[ p + \frac{R}{L} - \frac{v}{v_d} p \left( \frac{v_d}{v} \right) \right] \end{bmatrix}$$

Equation (4-23) is a nonlinear system due to the term  $\frac{v}{v_d} p \left( \frac{v_d}{v} \right)$ , which results in an extremely complicated control system. In order to simplify the system, assume there is a linear relationship between the DC output voltage and the  $d$ -component of the rectifier input voltage at the AC side as  $v_d = kv$ , hence Equation (4-23) can be written as a linear system thus:

$$p[X] = A'X + B'U \quad (4-24)$$

where

$$A' = \begin{bmatrix} 0 & 1 \\ -\frac{k^2}{LC} & -\frac{R}{L} \end{bmatrix}$$

$$B' = \begin{bmatrix} 0 \\ \frac{ke_d}{LC} - \frac{i_L}{C} \left( p + \frac{R}{L} \right) \end{bmatrix}$$

The transfer function of the close-loop control system can be found by comparing the characteristic equation of a control system with Equation (4-24), which is the state-space in controllable canonical form.

Because

$$sI - A' = \begin{bmatrix} s & 0 \\ 0 & s \end{bmatrix} - \begin{bmatrix} 0 & 1 \\ -\frac{k^2}{LC} & -\frac{R}{L} \end{bmatrix}$$

$$= \begin{bmatrix} s & -1 \\ \frac{k^2}{LC} & s + \frac{R}{L} \end{bmatrix}$$

Hence, the characteristic equation can be expressed as

$$\det(sI - A') = s\left(s + \frac{R}{L}\right) + \frac{k^2}{LC} = 0$$

or

$$s^2 + \frac{R}{L}s + \frac{k^2}{LC} = 0 \quad (4 - 25)$$

Then the un-damped natural frequency and damping factor can be obtained as

$$\omega = \frac{k}{\sqrt{LC}} \quad (4 - 26)$$

$$\zeta = \frac{R}{2k} \sqrt{\frac{C}{L}} \quad (4 - 27)$$

A desirable value of the damping factor is between 0.6 to 0.8 with the ideal value being  $\frac{1}{\sqrt{2}}$ .

Because, if the damping factor is too small, this will result in system oscillation; and if the damping factor is too large, the system response will be slow.

The proportional gain parameter,  $k$ , of the system can be selected by the appropriate choice of the input filter inductor and output filter capacitor values.

## 4.5 Simulation of a three-phase SVPWM active rectifier

The mathematical model of the current and voltage control loops of a three-phase power system have been designed in the previous analysis. However, accurately determining the position in a rotation frame system by sampling the voltage of the three-phase power grid is a crucial point for the field orientated SVPWM control algorithm. The SVPWM algorithm is generally composed of the following subsystems: PLL for synchronisation, Identify Sector, Firing time of the six switch devices, Park's, Clarke's, Inverse Park's and Inverse Clarke's transformations.




Detailed design of a PLL for synchronisation has been introduced in Chapter 3, and will not be described again here.

#### 4.5.1 Identify sector

Figure 4-8 shows the relationship of the normalised sinusoidal waves of a three-phase system. The period of the sinusoidal waves of a three-phase system can be divided into 6 sectors, delimited by the zero crossing points of the 3 sine waves, i.e.  $0, \pi/3, 2\pi/3, \pi, 4\pi/3, 5\pi/3$  and  $2\pi$  radians.

In Figure 4-8, the blue, green and red lines indicate the phase voltages of the A Phase, B Phase and C Phase respectively, in a three-phase balance system. Figure 4-8 shows the voltage of Phase A is greater than or equal to zero from  $0$  to  $\pi$  radians and is less than or equal to zero from  $\pi$  to  $2\pi$  radians. Similarly Phase B is positive or zero from  $0$  to  $\pi/3$  and from  $4\pi/3$  to  $2\pi$  radians, and negative or zero from  $\pi/3$  to  $4\pi/3$  radians. Also, Phase C is positive or zero from  $2\pi/3$  to  $5\pi/3$  radians, negative or zero from  $0$  to  $2\pi/3$  and from  $5\pi/3$  to  $2\pi$  radians.




**Figure 4- 8 Normalised sinusoidal waves of three-phase voltage**

The sectors in Figure 4-8 can be represented logically, assuming logic 1 represents the corresponding phase voltage is greater than 0 and logic 0 represents it when less than 0, then according to the above analysis the logic relationship between the three phases in the six sectors is shown in the following table.

<b>Sectors in Figure 4-8</b>	<b>Areas</b>	<b>Phase A</b>	<b>Phase B</b>	<b>Phase C</b>
1	$0 - \pi/3$	1	1	0
2	$\pi/3 - 2\pi/3$	1	0	0
3	$2\pi/3 - \pi$	1	0	1
4	$\pi - 4\pi/3$	0	0	1
5	$4\pi/3 - 5\pi/3$	0	1	1
6	$5\pi/3 - 2\pi$	0	1	0

**Table 4- 1 Logical relationship between voltage and each phase**

#### 4.5.2 Determine firing time for switching devices



**Figure 4- 9 Vector synthesis schematic in sector 1**

Figure 4-9 illustrates the vector synthesis schematic in Sector 1 between 0 and  $\pi/3$  radian in Figure 4-8. Assuming  $T_z$  is the normalised time unit, analysis of the figure shows that the firing times  $T_1$  and  $T_2$  can be obtained by the following equations:

$$\frac{|\vec{V}_{ref}|}{\sin\left(\frac{2\pi}{3}\right)} = \frac{|\vec{V}_1|T_1}{\sin\left(\frac{\pi}{3} - \alpha\right)} \quad (4 - 28)$$

$$\frac{|\vec{V}_{ref}|}{\sin\left(\frac{2\pi}{3}\right)} = \frac{|\vec{V}_2|T_2}{\sin(\alpha)} \quad (4 - 29)$$

Because

$$|\vec{V}_1| = |\vec{V}_2| = |U_{dc}|$$

Therefore

$$T_1 = \frac{|\vec{V}_{ref}|}{|\vec{V}_1|} \frac{\sin(\frac{\pi}{3} - \alpha)}{\sin(\frac{2\pi}{3})} = M \sin\left(\frac{\pi}{3} - \alpha\right) \quad (4 - 30)$$

$$T_2 = \frac{|\vec{V}_{ref}|}{|\vec{V}_1|} \frac{\sin \alpha}{\sin(\frac{2\pi}{3})} = M \sin \alpha \quad (4 - 31)$$


$$T_0 = T_Z - T_1 - T_2 \quad (4 - 32)$$

$T_0$  is the time when both the upper and lower arms in the inverter-bridge are switched off, and


where  $M$  is the ratio of modulation,

$$M = \frac{2}{\sqrt{3}} \frac{|\vec{V}_{ref}|}{|U_{dc}|} \quad (4 - 33)$$


Figure 4-10 shows that one period of the output voltage is divided into 6 patterns. The patterns show the switched on/off state of the upper arms in the inverter-bridge, which is generally composed with IGBTs or MOSFETs. Because the states of lower arms are opposite to the upper arms, the state of on/off states for the lower arms are easy to obtain, therefore only the upper arm control signals are shown in Figure 4-10.




(a) Sector 1 switching state




(b) Sector 2 switching state




(c) Sector 3 switching state



(d) Sector 4 switching state



(e) Sector 5 switching state



(f) Sector 6 switching state

Figure 4- 10 The patterns of voltage vectors

Taken from (Cai, 2006)

The firing times of each switch in the upper arms of the bridge in the different Sectors can be obtained from Figure 4-10 as follows (Fan, 2012).

Sector 1:

$$\begin{cases} F_{S_1} = T_1 + T_2 + \frac{T_0}{2} \\ F_{S_3} = T_2 + \frac{T_0}{2} \\ F_{S_5} = \frac{T_0}{2} \end{cases} \quad (4-34)$$

Sector 2:

$$\begin{cases} F_{S_1} = T_1 + \frac{T_0}{2} \\ F_{S_3} = T_1 + T_2 + \frac{T_0}{2} \\ F_{S_5} = \frac{T_0}{2} \end{cases} \quad (4-35)$$

Sector 3:

$$\begin{cases} F_{S_1} = \frac{T_0}{2} \\ F_{S_3} = T_1 + T_2 + \frac{T_0}{2} \\ F_{S_5} = T_2 + \frac{T_0}{2} \end{cases} \quad (4-36)$$

Sector 4:

$$\begin{cases} F_{S_1} = \frac{T_0}{2} \\ F_{S_3} = T_1 + \frac{T_0}{2} \\ F_{S_5} = T_1 + T_2 + \frac{T_0}{2} \end{cases} \quad (4-37)$$

Sector 5:

$$\begin{cases} F_{S_1} = T_2 + \frac{T_0}{2} \\ F_{S_3} = \frac{T_0}{2} \\ F_{S_5} = T_1 + T_2 + \frac{T_0}{2} \end{cases} \quad (4-38)$$

Sector 6:

$$\begin{cases} F_{S_1} = T_1 + T_2 + \frac{T_0}{2} \\ F_{S_3} = \frac{T_0}{2} \\ F_{S_5} = T_1 + \frac{T_0}{2} \end{cases} \quad (4 - 39)$$

#### 4.5.3 Over modulation

Generally, calculating the firing time of each of the switching devices in the inverter-bridge does not cause any problems in theory. In practical applications, however, over modulation errors can be introduced in the calculation of the vector due to following reasons:

- Mathematical operations in the algorithm (particularly multiply, divide and trigonometrical operators) may introduce rounding/truncation errors; and
- Calculation across Sector boundaries may result in errors in the synthesis of the vectors.

Therefore, in order to solve the problem of over modulation, linear modulation and non-linear modulation are employed to control over modulation (Fan, 2012).

If the module is working during the dead time, i.e. when  $T_0$  is greater than or equal to 0, Equations (4-30), (4-31) and (4-32) will be executed. Otherwise Equations (4-40), (4-41) and (4-42) below will be executed.

$$T_1' = \frac{T_1}{T_1 + T_2} T_z \quad (4 - 40)$$


$$T_2' = \frac{T_2}{T_1 + T_2} T_z \quad (4 - 41)$$

$$T_0 = 0$$

(4 – 42)

#### 4.5.4 Generating controlled PWM for SVPWM

Figure 4-11 illustrates the principle of PWM generation. A triangular waveform carrier wave is compared with a sine wave reference signal, the state of output is positive when the value of the reference signal is greater than the carrier waveform, otherwise it is negative.



**Figure 4- 11 The principle of PWM generation**

The output logical relationships of PWM can be described in mathematical form as follows:



$$V_{PWM} = \begin{cases} 1 & \text{if } V_{ref} \geq V_{tri} \\ -1 & \text{otherwise} \end{cases} \quad (4 - 43)$$


where

$V_{PWM}$  is the logical value of PWM output, 1 represents upper arm is switched on,  
-1 represents lower arm is switched on

$V_{ref}$  is the reference modulation sine wave

$V_{tri}$  is the triangular carried wave

In Figure 4-11, the modulation waveform is a reference sine wave, but for SVPWM algorithm, the ideal modulation waveforms is a saddle-like shapes, as in Figure 4-12. To compare with traditional sine modulation waveform, the utilization of the DC-bus voltage was improved (Infineon Technologies AG, 2006).



**Figure 4- 12 Ideal modulation waveform of SVPWM**


## 4.6 Modelling three-phase SVPWM rectifier

All the models of Clarke, Inverse Clarke, Park, Inverse Park, Identify Area and Firing time have been modelled as MATLAB Function Blocks as this is the most convenient way to

achieve the complex mathematical calculations required and to implement the design in a real time embedded system in the future. The input filter inductor coils have an inductance of 3mH and equivalent resistance of  $0.5\Omega$ . The sample time of system is 100ms. The frequency of the power grid is 50Hz.

#### 4.6.1 Modelling identify area and firing time

Figure 4-13 illustrates the modelling of current controlled-loop according to Equation (4-3) stated previously, and the parameters of the PI controller are listed in the figure.



**Figure 4- 13 Modelling of current controlled-loop**


Figure 4-14 depicts a model of the three-phase SVPWM rectifier, which can be operated as a normal SVPWM rectifier without PFC, or a SVPWM rectifier with PFC which requires a change of the PWM control signals for the Rectifier Bridge, i.e. the block of SVPWM, which generates PWM signals for normal rectifier without PFC to be changed as the block of PFC SVPWM, which generates PWM signals for rectifier with PFC. The blocks of V\_CLARKER and I\_CLARKER transform three-phase reference frame into stationary orthogonal reference frame for voltage and current of the grid respectively. The blocks of V\_PARK and I\_PARK




As the figure shows, the topology of the rectifier bridge is composed of six IGBT devices, which is exactly the same as the inverter-bridge of a three-phase GCI.

For GCIS, if the Load in the figure is considered as a DC voltage source or DC bus then the system can be operated as GCI injecting power into the power grid.


Figure 4-15 shows the simulated results of the generated normalised control saddled waves of the SVPWM which are compared with counters to generate the PWM control signals. The experimental results of control saddled waves are shown in Figure 4-16, 4-17 and 4-18 which are used to compare with the up-down timer register in the DSP chip to generate PWM signals to control switched devices  $S_1 - S_6$ . The saddled waves in Figure 4-16, 4-17 and 4-18 were captured through CCS 3.3 IDE for TI DSP.




**Figure 4- 15 Generated saddled modulation waveform**



**Figure 4- 16 Experiment result of Phase A saddled carried waveform**




**Figure 4- 17 Experiment result of Phase B saddled carried waveform**




**Figure 4- 18 Experiment result of Phase C saddled carried waveform**


As Figure 4-19 shows, although the rectifier employs SVPWM algorithm to generate PWM control signals, there is no current control-loop for PFC. Therefore, the input current appears as a smooth sine wave, but lags the voltage due to the filter inductor coils. Figure 4-20 illustrates the results of SVPWM rectifier with PFC, in which the current is in phase with the voltage. After PFC, analysis and comparison of the current waveforms in Figure 4-21, shows the THD of the input current is 1.72%, less than the general threshold 3%, which means the quality of input current is satisfied.



**Figure 4- 19 Phase A current and voltage without PFC**




**Figure 4- 20 Phase A current and voltage after PFC**




**Figure 4- 21 Analysis of harmonic distortion**


Figure 4-22 (a) illustrates the experimental comparison of Phase A current and voltage waves of an uncontrolled rectifier, in the figure, the yellow trace is voltage signal and the magenta trace is current signal. Intuitively there is gross distortion on the current wave. Figure 4-22 (b) shows experimental results of SVPWM rectifier without PFC; it can be seen that the distortion content of the input Phase A current is eliminated using the SVPWM algorithm. However, although the power quality has been dramatically improved, the power efficiency and voltage utilisation still need to be improved. Figure 4-22 (c) demonstrates the results of SVPWM rectifier with PFC, as the figure shows that the current is in phase with the voltage on Phase A when the SVPWM algorithm, including voltage and current control-loops are used.



(a) Uncontrolled rectifier voltage and current



(b) SVPWM rectifier voltage and current without PFC




(c) SVPWM rectifier voltage and current with PFC

Figure 4- 22 Experimental results



## 4.7 Modelling single-phase rectifier

P-Q theory is a powerful tool to apply for three-phase system (Afonso, et al., 2003). Three-phase active rectifier has been described previously and successfully modelled in section 4.6. The theory of this three-phase active rectifier is based on control of reactive current which is obtained through Clarke and Park transformations. Using the same approach, a novel method of single-phase rectification is presented in this section. The strategy of single-phase rectifier with PFC is illustrated in Figure 4-23.




**Figure 4- 23 Strategy of single--phase rectifier with PFC**

For a single-phase system Clarke's and Park's three-phase transformations are not appropriate (Microsemi, 2013). Therefore, the novel approach for a single-phase rectifier presented here, constructing a new pair of orthogonal signals against with the sample of the instantaneous input current signal by the SOGI is introduced in Chapter 3. Then the Park transformation can be employed to decompose active and reactive currents, the reactive current being controlled to


be as close to zero as possible. Then using the Inverse Park's transformation to generate a reference current, which is used to compare with the actual input current to generate PWM control signals for the rectifier bridge.

**Figure 4- 24 Model of single-phase rectifier with PFC**

Figure 4-24 shows the complete simulation model of the single-phase rectifier with PFC in MATLAB/Simulink environment. The sampling time of the simulation model is  $10\mu\text{s}$ , the peak value of input voltage sine wave is 110V, the inductance of both input filter inductors  $L_1$  and  $L_2$  are 2.5mH, the load comprises a 1mH inductor in serial with a  $30\Omega$  resistor and the capacity of the output filter capacitor is  $4700\mu\text{F}$ .



**Figure 4- 25 Results of single-phase rectifier**



**Figure 4- 26 Harmonic analysis of input current**

## 4.8 Summary

In order to implement a DC/AC power inverter so that electrical power can be converted bi-directionally either from the AC grid side to the DC bus side or from the DC bus side to the

AC grid side, an ideal rectifier and inverter based on the same topology for both single-phase and three-phase power system have been considered in this chapter.

Using the concept of three-phase PFC rectifier and the P-Q theory of instantaneous reactive power, through a detailed mathematical analysis and design process for a three-phase SVPWM rectifier, a novel method of constructing a pair of orthogonal signals for current sampling and using Clarke's and Park's transformation to split active and reactive components of the input current for single-phase rectifier for a bi-directional H-bridge converter, was presented in this chapter.

Simulation models of both three-phase and single-phase systems were developed in MATLAB/Simulink environment. By analysing the simulation results, it is apparent that the input power quality is considerably improved.

# **Chapter 5 Bi-directional interleaved boost/buck**

## **DC/DC converter**

### **5.1 Introduction**

For a renewable power system, directly injecting power into the power grid impacts the grid power quality, due to renewable source intermittency and random characteristics. In order to stabilise inverter output and enhance end-user's benefits from integrated renewable power system, a battery bank is typically included at the user terminal to buffer fluctuations and meet end-user's expectations.

Battery bank capacity is proportional to cost, so the main problem in providing the best cost-effective configuration of the battery bank is that the battery bank terminal voltage might not match the DC Bus voltage. In this case, it is necessary to have a bi-directional DC/DC converter to interface between a higher DC bus potential and lower battery voltage.

This chapter presents a novel four-phase interleaved boost/buck topology to implement power flow bi-directionally between the higher and lower potentials, which means the boost and buck can be achieved on a same topology by swapping the input and output terminals.

With the rapid development of power electronics, to improve power supply quality, reliability and efficiency, there are a number of topologies for DC/DC converters that have been put forward in the past two decades. According to the method of electrical connection, the DC/DC converter is categorised into two classes: isolated and non-isolated. Normally, an isolated DC/DC converter uses a transformer between the input source and output circuit, providing electrical isolation via the magnetic coupling in the transformer. The advantage of an isolated

converter is a high safety level; however the drawback is loss of power in the transformer and associated isolation circuitry and high cost.


In this project, it was decided to simulate a non-isolated DC/DC converter because the fundamental principle of isolated and non-isolated converters are the same.

There are four basic converter topologies employed practically in renewable power systems: the step-down (Buck) circuit, the step-up (Boost) circuit, the boost-buck converter and the Ćuk converter (Maniktala, 2006).

Whatever the converter topology, it can be subdivided into continuous conduction mode (CCM) or discontinuous conduction mode (DCM). In a CCM converter, the current through the inductor  $L$  is always positive and never equal to zero in any switching period of the switching device  $M$ ; in a DCM converter, the current is not always positive.

## 5.2 Buck converter

A step-down circuit, also known as a buck circuit, is shown in Figure 5-1. The circuit consists of a voltage source  $v_s$ , a switching device  $S_1$  connected in series with  $v_s$ , a reverse biased diode  $D_1$  shunts the voltage source and switch combination, across which an LC filter provides the output to a resistive load  $R_L$ .



**Figure 5- 1 Topology of buck converter**

For the buck converter, from Figure 5-1, in the steady state, the relationship between the input voltage  $v_s$ , output voltage  $v_o$ , and the duty ratio of switching time  $D$  can be obtained as (Czarkowski, 2007):

$$(v_s - v_o)DT = v_o(1 - D)T \quad (5-1)$$

Dividing both sides by the switching time period,  $T$ , and rearranging the relationship between output and input voltage, we have:

$$A \equiv \frac{v_o}{v_s} = D \quad (5-2)$$

where  $A$  is the buck circuit gain.

For the buck circuit, based on Equation 1, it can be summarised that the input voltage is always greater than the output voltage. Therefore, this topology is appropriate for applications where the load voltage is relatively low, such as a battery charging circuit. This type of circuit is commonly used in laptop power supply.

If the switching frequency is fixed, the inductor inductance  $L_l$  in the buck circuit determines whether the circuit operates in CCM or DCM mode. The critical inductance between CCM and DCM is given by (Czarkowski, 2007):

$$L_1 = \frac{(1-D^2)R_l}{2f} \quad (5-3)$$

$L_l$  is the critical inductance of the inductor,

$D$  is the ratio duty of the switching period for switching devices  $S_l$ ,


$R_l$  is the load resistance in Figure 5-1, and

$f$  is the switching frequency.

If the inductance of inductor is greater than the critical inductance  $L_I$  then the circuit operates in CCM, otherwise in DCM.

### 5.3 Boost converter

Figure 5-2 shows the circuit of a simple boost converter. It consists of a voltage source  $v_s$ , in series with an inductor  $L_I$  used for energy storage, a switching device  $S_I$ , a diode  $D_I$ , a filter capacitor  $C_I$  and a load  $R_I$ .



**Figure 5- 2 Circuit of boost converter**

When the switching device  $S_I$  is conducting, energy is stored in the inductor  $L_I$ . Assuming all devices are ideal and the voltage across the capacitor  $C_I$  is greater than the source voltage  $v_s$ , then the diode  $D_I$  is reversely biased and the capacitor provides the energy needs of the load  $R_I$ . During this time, i.e. the switching device  $S_I$  is conducting, the current through the inductor rises linearly. When the switching device  $S_I$  is opened, the diode  $D_I$  conducts the current through the inductor  $L_I$ , providing current for the load  $R_I$  and (re)charging the capacitor  $C_I$ .

In the steady state, using Faraday's law, the relationship between the switching duty ratio of the switching devices  $D_I$ , the output voltage  $v_o$  and the input voltage  $v_s$  can be obtained as (Czarkowski, 2007):



$$v_s DT = (v_o - v_s)(1 - D)T \quad (5-4)$$

Dividing both sides by the switching period,  $T$ , and rearranging the relationship between output and input voltage, we have:

$$A \equiv \frac{v_o}{v_s} = \frac{1}{1-D} \quad (5-5)$$

where  $A$  is the boost circuit gain.

Equation 5-5 shows that the boost circuit gain is always greater than 1, which means that the output voltage is higher than the input voltage. Hence, the boost circuit is widely employed in the field of RES to increase the voltage of DC bus link in order to ensure that power can be adequately injected into the power grid.

For the boost circuit, once the switching frequency is confirmed, the inductance of  $L_l$  determines the operating mode of circuit, as given by (Czarkowski, 2007):

$$L_1 = \frac{(1-D)^2 DR}{2f} \quad (5-6)$$

where

$L_l$  is the critical inductance of inductor in Figure 5-2,

$D$  is the ratio duty of the switching period,

$R_l$  is the load resistance in Figure 5-2, and

$f$  is the switching frequency.


If the inductance of inductor in Figure 5-2 is greater than  $L_l$ , the circuit is operated in CCM, otherwise in DCM.

Most MPPT units, which are used in the application of solar PV system, are based on DC to DC converters of either a Boost or Buck topology, and the article (Glasner & Appelbaum, 1996) demonstrates that a Boost converter has higher power conversion efficiency than a Buck converter.

All switch-mode power supplies are made up of a buck or boost topology or combination of buck and boost with or without transformers (Billings, 2003). In a buck converter the input current is discontinuous and the output current is continuous. Conversely, in a boost converter the input current is continuous and output current is discontinuous (Billings, 2003; Maniktala, 2006).

## 5.4 Interleaved boost circuit

Interleaved topology was introduced to overcome the problems of ripple current, thermal dissipation and large filter capacitor bank requirements at the input or output terminal of switch-mode power supplies, widely employed in the application of computer power supply.



**Figure 5- 3 Basic interleaved boost topology**

Figure 5-3 shows a basic interleaved boost topology which consists of two boost circuits,  $S_1$  and  $S_2$  connected in parallel. The two PWM signals,  $PWM_1$  and  $PWM_2$  driving the switches

are mutually 180 degree out of phase. The total current supplied for the load is split between the two paths, reducing the required size of the inductors and capacitor and significantly reducing the  $I^2R$  losses (thermal dissipation) compared to the conventional boost topology. Also, because the total current is divided into two paths to deliver to the output terminal, the two path currents are eventually combined at the capacitor  $C_l$  in Figure 5-3, so the ripple frequency at the load is doubled but at smaller amplitude therefore can be more easily filtered.

The interleaved topology has the following four advantages:

- improvement in the power quality;
- increased efficiency from reduced thermal dissipation in the circuit;
- reduced size of the filter inductor; and
- reduced output ripple voltage.

Typically, a renewable power system operates at a high voltage potential, and there is a potential difference between the DC bus and the battery bank. For this project, a four-phase interleaved bi-directional boost-buck converter (IBDBBC) is proposed and modelled in MATLAB/Simulink.

## 5.5 Modelling four-phase IBDBBC under boost mode

A four-phase IBDBBC is derived from a conventional boost and buck converter. For comparison purposes, it is essential to create both simulation models for the four-phase IBDBBC and the conventional boost converter with the same parameters for the components in both circuits. Figure 5-4 is a simulation model of a conventional boost converter which is created in MATLAB/Simulink. In the figure, the input DC voltage source  $v_s$  is 200V and the expected output voltage at the filter capacitor  $C_l$  terminal is 450V. In the circuit, the inductance of energy stored inductor  $L_l$  is 200 $\mu$ H, the inductance of output filter inductor  $L_2$  is 50 $\mu$ H, the capacitance of output filter capacitor  $C_l$  is 2200 $\mu$ F, and the resistance of load  $R_l$  is 10 $\Omega$ . The

frequency of PWM signal is 5kHz. All those parameters in the simulation model were initially given based on the author's experience; after several simulations, they were eventually confirmed.




Figure 5- 4 Conventional boost circuit model




Figure 5- 5 Simulation of four-phase IBDBBC circuit


Figure 5-5 shows a four-phase IBDBBC operating under boost mode. In the simulation model, all the parameters of the components in the circuit are the same as in Figure 5-4. The frequency of the controlled PWM signals is 5kHz,  $v_s$  is considered as an input battery bank with a nominal

voltage 200Vdc, the  $R_l$  10 $\Omega$  is the load of the circuit, which can be considered as a higher potential DC bus, so the expected output voltage of the boost converter is 450V. The inductances of the input and output filter inductors  $L_6$  and  $L_5$  are 50 $\mu$ H each, filter capacitors  $C_2$  and  $C_1$  are 2200 $\mu$ F each, and the inductance of energy stored inductors  $L_1$ - $L_4$  are 200 $\mu$ H each. The blocks of PWM Boost and PWM Buck generate four-phase PWM signals for boost mode and buck mode respectively.


In Figure 5-5, the circuit operates under boost mode which means power can be delivered from the low potential side to the high potential side when  $PWM_1$ - $PWM_4$  are activated and  $PWM_5$ - $PWM_8$  are disabled. Conversely, swapping the input and output side, enable  $PWM_5$ - $PWM_8$  and disable  $PWM_1$ - $PWM_4$ , the circuit operates under buck mode.

Figure 5-6 illustrates the four-phase PWM signals generated by the block of PWM Boost for boost mode operation, in which, the PWM signals are out of phase 90° to each other.


The simulation result of the current flowing through the energy stored inductor in the conventional boost topology is shown in Figure 5-7. As the simulation result in Figure 5-7 shows, the maximum peak current carried by the inductor reached roughly 75A. Comparing this with the results of four-phase IBDBBC circuit shown in Figure 5-8, the current flowing through each inductor is significantly reduced and the average current of each inductor is approximately reduced by about 50%. This means the thermal dissipation ( $I^2R$  losses) problems of the electronic components are considerably reduced.



**Figure 5- 6 Generated PWM signals**



**Figure 5- 7 Inductor current of conventional CCM boost circuit**




**Figure 5- 8 Inductor currents of IBDBBC circuit**


Figure 5-9 and 5-10 show the simulation results of the output DC voltage of the conventional boost and the four-phase IBDBBC circuit, respectively.

As Figure 5-9 illustrates the voltage output of the conventional boost circuit has a ripple voltage of about 2.25V. By contrast, the output from the IBDBBC circuit only has a ripple voltage of about 0.2V, as shown in Figure 5-10. This means the output power quality of four-phase IBDBBC is much better than conventional boost.

Additionally, in the simulation results of the four-phase IBDBBC circuit, the frequency of ripple voltage is 4 times that of a conventional boost circuit. That means the output ripple voltage can be filtered easily with a relatively small size capacitor.



**Figure 5- 9 DC output voltage of conventional boost circuit**




**Figure 5- 10 DC output voltage of four-phase IBDBBC circuit**




## 5.6 Modelling four-phase IBDBBC under buck mode

Figure 5-11 illustrates a simulation model of the IBDBBC operating under buck mode, the switching signals PWM5-PWM8 are enabled and PWM1-PWM4 are disabled, which means the input terminals and output terminals are conversely changed comparing with Figure 5-5. All the parameters of the components and the simulation conditions are exactly the same as under boost mode which was described in the previous section and shown in Figure 5-5. In order to observe the response of converter output voltage, at the point of 0.2s, input voltage steps up from 350Vdc to 450Vdc. In order to compare with interleaved boost circuit in Figure 5-5, most devices in the figure remains unchanged but the PWM control signals, and the input and output terminals are swapped.



**Figure 5- 11 Simulation of four-phase IBDBBC under buck mode**


The simulation results for the input and output currents of the interleaved buck converter are shown in Figure 5-12. It can be seen that the output current is continuous and input current is discontinuous.




**Figure 5- 12 Input and output current**

The voltage of a battery bank is generally more stable than the DC bus voltage due to the intermittent character of the renewable energy source which causes the generator output with fluctuation. Figure 5-13 illustrates that the charging voltage at the battery terminal remains almost constant at approximately 200Vdc when the DC bus voltage steps up from 350Vdc to 450Vdc.

Figure 5-14 demonstrates that the output ripple voltage of the four-phase IBDBBC operating under buck mode remains relatively small when the input steps up from 350V to 450V. The ripple increases from approximately 0.06V to around 0.15V.



**Figure 5- 13 Input and output voltage**



**Figure 5- 14 Output voltage ripple**

## **5.7 Summary**

A novel four-phase IBDBBC to deal with the bi-directional power flow between a DC bus and a battery bank has been proposed, designed, modelled and simulated. Comparing this design with the conventional boost-buck converter, the four-phase IBDBBC can significantly reduce the ripple of output voltage, the thermal dissipation and the current stress on the switching devices.

## Chapter 6 GCI with RPC

### 6.1 Introduction

This chapter presents a novel control strategy for a single-phase inverter to achieve RPC and output active power when the inverter is connected to a single-phase electricity grid. Because the SOGI introduced in Chapter 3 can produce a pair of orthogonal signals, it is used to construct an orthogonal current signal for splitting active and reactive current based on the instantaneous load current sampled from the single-phase grid. The active and reactive current of the grid can be rapidly decomposed through trigonometric calculation. The reference current of the inverter output can be produced through the actual active and reactive currents which are obtained in the previous stage. Then the re-synthesised reference current is compared with the inverter output current, and the difference is used to generate the PWM signals for controlling the IGBT devices.

The GCI is one of the most important parts of a distributed generator using renewable energy sources. The power output from solar PV panels is DC, so the inverter plays a key role to convert DC to AC power. Although most wind turbines generate AC power, however, the AC power generated by wind turbines cannot be fed directly into the power grid. For example, wind turbines with synchronous generators output AC power with variable frequency due to constantly changing wind speed, and the variable frequency AC power must be converted to a fixed frequency AC power through AC/DC and DC/AC conversions for grid connection.

The conventional GCI interfacing a renewable power generator and the electricity grid is generally equipped with an MPPT algorithm which is expected to draw maximum power from the renewable source. However, the conventional GCI has some critical issues. Firstly, the inverter injects maximum power into the grid with the fluctuation of renewable energy sources

without providing RPC. Secondly, the inverter feeds the power to the grid as much as it can without considering the grid condition (such as voltage, frequency and power factor) and power demand on the grid.

Based on their applications, the inverters for renewable power generators can be categorised into standalone inverters and GCIs. Generally the characteristic of a standalone system is equipped with an energy storage which can be used to maximally extract energy from the renewable sources and consistently provide power for loads while smoothing or even eliminating renewable source fluctuation. Most GCIs without energy storage devices consider the utility grid as a battery of unlimited capacity. The conventional GCI is generally composed of an MPPT block, PLL block and DC/AC inverter block. The MPPT is realised to ensure maximum power from the renewable source at any time, PLL block is used to synchronise the inverter power output with power grid voltage, and DC/AC inverter is tasked to feed the power generated by the renewable power generator into the grid.

Initially, the technology of standalone inverters and GCIs gradually evolved from the application of VFD, where AC power supply with variable frequency is required to improve performance, such as for an induction motor. Hence, the control algorithms of an RES inverter is similar to that for a VFD.

The GCI can be considered as an interface device between the RES and the grid. There are a number of topologies and control methodologies which have been implemented in the last two decades. With the historic development of GCIs in the area of solar PV power systems, they can be divided into three types: centralised inverter, string inverter and multi-string inverter (Kjaer, et al., 2005). Additionally, based on whether the inverter has a transformer or not, the GCI can also be categorised as a transformer inverter or transformerless inverter.


The centralised inverter operates between the grid and large number of solar PV panels connected in series strings to produce adequate voltage. The series strings are connected in parallel through anti-reverse current diodes. The major drawback of this type of system is that the plant with central inverter shuts down if any problem occurs in the inverter. A further drawback is that the effect of shading using centralised inverter is worse than when using string inverters. For example, when clouds gather over a solar power farm, the performance and effectiveness of the system using string inverters is better than for a centralised inverter system. Although the string-inverter technology can reduce the power losses on the DC bus, however, it treats group's panel as a single large panel, any problems of single panel could impact whole system performance. The technology of multi-string systems is an advanced development of string-inverter systems, in which each string has its own DC to DC converter with MPPT supplying power to the DC bus link and from there then injects AC power into the utility grid via a common inverter. All the inverter systems discussed above inject the maximum possible power into the electricity grid, even in the situation of that the capability of utility grid provided matched customer's electricity requirement. Also, it is rare that a GCI can quantitatively provide RPC.

## **6.2 Topologies of a GCI**

For a DC/AC inverter, according to its AC output waveforms, it can be considered as a VSI, where the independently controlled AC output is the voltage waveform. Alternatively, it can be considered as a CSI, where the independently controlled AC output is the current waveform (Espinoza, 2001). There are a number of methods and techniques which are widely utilised to implement VSIs and CSIs. According to the PWM carrier wave, the methods are classified into many types, such as Square-wave Operation, Carrier-based PWM, Switch Frequency Optimal (SFO)-PWM, Regular and Non-regular Sampled PWM, Selective Harmonic Elimination PWM (SHEM), SVPWM (Amatoul, et al., 2012) (Espinoza, 2001) and Hysteresis Current Control


(HCC) (Bode & Holmes, 2000). HCC has the advantage of an inverter output with small output current ripples, and it is a real time control methodology with very good stability, close tracking of current requirements and rapid transient response (Kojabadi, et al., 2006). Hence, HCC is widely used for single-phase GCIs.

According to practical applications, GCIs can be categorised as single-phase VSI, three-phase VSI, single-phase CSI and three-phase CSI. The inverter can be divided into half-bridge and full-bridge on the basis of the number of inverter legs. The topologies of a half-bridge VSI and a full-bridge VSI, based in a single-phase system are shown in Figures 6-1 and 6-2 respectively. In Figure 6-1 the two large capacitors provide a central neutral point for the load. That implies the voltage across each capacitor should be equal to half voltage supply  $v_s/2$ .



**Figure 6- 1 Topology of half-bridge single-phase VSI**






**Figure 6- 2 The topology of full-bridge single-phase VSI**

In the full-bridge single-phase VSI, illustrated in Figure 6-2, an additional leg of switches (controlled in anti-phase) is utilised to replace the neutral point. In both the half-bridge VSI and the full-bridge VSI, the top switch and bottom switch in the same leg are not allowed to be switched “on” simultaneously. If switching devices  $S_1$  and  $S_2$  (or  $S_3$  and  $S_4$ ) are switched “on” at the same time, this would create a short circuit across the DC power supply,  $v_s$ .

### 6.3 GCI based on HCC

Figure 6-3 shows the block diagram of generally grid-connected single-phase inverter based on close-loop HCC. The PLL block produces normalised sinusoidal signal which is synchronous with power grid. The inverter output targeted current  $I_{Ref}$  multiply PLL output to generate instantaneous reference current,  $i_{Ref}$ . The generated instantaneous reference current  $i_{Ref}$ , is compared with the output current of the inverter  $i_o$  to yield an offset error signal,  $\Delta i$ , which is the input of the hysteresis controller. According to the extent of the offset error, the controller determines which pair of the switching devices  $S_1$  and  $S_4$  or  $S_2$  and  $S_3$  should be switched “on” or “off”. If  $i_{Ref}$  is positive, the output current of the inverter will be increased as the switching devices  $S_1$  and  $S_4$  are switched “on” (with  $S_2$  and  $S_3$  switched “off”). Conversely, the current will be decreased as  $S_2$  and  $S_3$  are switched “on” (with  $S_1$  and  $S_4$  switched “off”). If

$i_{Ref}$  is negative, switching “on”  $S_1$  and  $S_4$  (with  $S_2$  and  $S_3$  switched “off”) will cause the absolute value of  $i_o$  to be decreased, otherwise it will be increased. To summarise the above analysis, the output current of the inverter will be increased when  $S_1$  and  $S_4$  are switched “on” (with  $S_2$  and  $S_3$  switched “off”); switching “on”  $S_2$  and  $S_3$  (with  $S_1$  and  $S_4$  switched “off”) will cause the output current of the inverter to be decreased. Therefore, if the hysteresis band is set as  $2\Delta i$ , then the output current is between  $i_{Ref} + \Delta i$  and  $i_{Ref} - \Delta i$ .



**Figure 6- 3 Structure of DC/AC inverter based on HCC**

## 6.4 Simulation of conventional single-phase GCI

The output voltage of the inverter has to be synchronised with the grid voltage, which means it is essential to embed the function of PLL in the inverter for tracking the phase angle of the grid voltage.

Assume the grid voltage is

$$v = A \sin \omega t \quad (6 - 1)$$


where  $A$  is the amplitude of the grid voltage,  $\omega$  is the angular frequency of the grid voltage.

Taking derivative with respect to time from Equation (6-1) yields:

$$\frac{dv}{dt} = A\omega \cos \omega t \quad (6-2)$$


The tangent of instantaneous phase angle of the grid voltage can be obtained as:

$$\tan \theta = \frac{v\omega}{dv/dt} = \frac{A\omega \sin \omega t}{A\omega \cos \omega t} = \tan \omega t \quad (6-3)$$



**Figure 6- 4 Simulation model of conventional PLL for GCI**


Figure 6-4 is the simulation block diagram which is utilised to implement the PLL function for GCI according to Equations (6-1) to (6-3).




**Figure 6- 5 Simulation model of full-bridge single-phase GCI**

Figure 6-5 is the complete simulation model of a full-bridge single-phase GCI with hysteresis control (bang-bang). In the figure, the inverter-bridge is formed by 4 IGBTs,  $IGBT_1$ ,  $IGBT_2$ ,  $IGBT_3$  and  $IGBT_4$ . The block of PLL takes instantaneous voltage of the grid as input signal to attain normalised sine and cosine values of the grid voltage phase angle. The block of PWM Generator produces 4 channels of control PWM signals for the inverter-bridge in accordance with input voltage, the phase angle of grid voltage and the output current of the inverter. The block of Source generates a dynamically varying DC power supply to simply simulate PV panel output with fluctuation.

In order to observe changes of the inverter output as the voltage on the DC bus varies, an input voltage source is provided, as shown in Figure 6-6 (a). Figure 6-6 (b) shows the output current of the inverter. The amplitude of output current of the inverter varies as a result of the changes of the input voltage.



**Figure 6- 6 Simulation results of full-bridge single-phase GCI**



**Figure 6- 7 Output current of conventional GCI**

Figure 6-7 illustrates the relationship between the grid voltage and the output current of the inverter. The output current is in phase with the grid voltage, i.e. there is no reactive power injection to the grid from the inverter.


Through analysing the simulation results as shown in Figure 6-6 and 6-7, it can be said that inverter output current follows the changes of the voltage on the DC-bus, and output current is in phase with the grid voltage.

## 6.5 RPC

This section presents a novel algorithm to deliver quantitative RPC for a micro-grid.

The conventional STATCOM is generally connected to the grid in parallel with a load. The output reactive power and current of the STATCOM can be controlled by means of adjusting either the voltage at the PCC, or the amplitude and phase angle of the current outputted from STATCOM.


Supposing a smart micro-grid system is installed in a community, which comprises a number of small scale distributed generators (SSDG) with RPC, a central controller, current and voltage transducers, and a communication system. A stable and secure generation system should guarantee that residents in the community are not affected by unpredictable power cut off from the main grid. Therefore, the whole system without grid support should deliver both active power and reactive power to meet the power demands of the community. A single small scale SSDG, in a smart micro-grid, is not capable of completely compensating the whole micro-grid system's reactive power. However, the whole system's reactive power may be compensated collectively by all the SSDGs, because each SSDG can deliver a certain amount of reactive power.



**Figure 6- 8 Schematic diagram of GCI**

Figure 6-8 shows an equivalent schematic of a single-phase GCI which is connected into the power grid through an output filter inductor with inductance  $\omega L$ .

Generally, the impedance of an electricity grid is inductance, which means the grid as a load consumes reactive power, and the load's current lags the voltage with a certain phase angle. Therefore, if the inverter output current leads the grid voltage with a certain same phase angle, then the grid reactive power can be compensated.




**Figure 6- 9 Vector relationships of GCI**

Figure 6-9 illustrates the vector relationships between the output current  $I_o$  of the inverter, the load current  $I_L$  and the grid voltage  $v_g$ . In Figure 6-9, the load current  $I_L$  is lagging by a phase angle  $\theta$  with respect to the grid voltage  $v_g$ . The load current can be decomposed into active and reactive currents  $I_{Ld}$  and  $I_{Lq}$  respectively. Figure 6-9 illustrates that if the inverter output current  $I_o$  is composed by an active current component  $I_{od}$  and a reactive current component  $I_{oq}$ , which is equal in magnitude to the load reactive current component  $I_{Lq}$  but opposite in phase to  $I_{Lq}$ ,

the whole system's reactive power can be completely compensated by the inverter, thereby achieving the objective to inject active power to the grid with RPC.

### 6.5.1 Control strategies

The theory of instantaneous active and reactive power is the well-known p-q theory which is most widely used in time-domain reference current generation techniques (Golestan, et al., 2013; Wang, et al., 2007). The SOGI is widely exploited to achieve PLL (Golestan, et al., 2013) (Rodriguez, et al., 2009) (Fedele, 2012) and to eliminate, or reduce, the instantaneous noise level in many fields, such as control theory, relaying protection, signal processing, radio frequency, power systems. (Fedele, 2012). In the present study, SOGI is utilised to construct a pair of orthogonal trigonometric functions for the load current in a single phase system, which is sampled at the PCC of the micro-grid, as shown in Figure 6-10.




**Figure 6- 10 PCC of single-phases system**

As previously discussed in chapter 4, instantaneous active and reactive power can be represented as Equation (4-4). In the equation, as  $i_q$ , the q-axis component of the grid current, approaches 0, the reactive power component  $Q$  approaches 0 and only the d-axis component,



$v_d i_d$ , the active power term remains. Through analysis of the above equation, the reactive power  $Q$  of the power grid can be controlled by adjusting  $i_q$ , the instantaneous quadrature component of current, in the d-q rotating frame.

Through the above analysis, the reactive and active power can be regulated by adjusting components of  $i_d$  and  $i_q$  individually. The  $d$ - and  $q$ - axis components can be obtained by means of transformation from the stationary frame, and those two signals are an orthogonal pair of the load currents. Therefore, for a single-phase system, it is necessary to construct a pair of orthogonal signals from the load current as Figure 6-11 illustrates.



**Figure 6- 11 Structure of control algorithm**

The single-phase instantaneous voltage of the power grid and the load current are given by:

$$v_g = v_{max} \cos \omega t \quad (6-4)$$

$$I_\alpha = I_{max} \cos(\omega t - \theta) \quad (6-5)$$

where

$v_{max}$  is the peak value of the grid voltage.

$I_{max}$  is the peak value of the load current.

$I_\alpha$  is the instantaneous load current.

$\theta$  is the phase angle of the load current respect to the grid voltage.

The orthogonal component of the instantaneous load current in Equation (6-5) can be obtained as:

$$I_\beta = I_{max} \sin(\omega t - \theta) \quad (6-6)$$

Conducting trigonometric calculation for Equations (6-5) and (6-6) yields:

$$I_\alpha = I_{max} \cos \omega t \cos \theta + I_{max} \sin \omega t \sin \theta \quad (6-7)$$

$$I_\beta = I_{max} \cos \omega t \sin \theta - I_{max} \sin \omega t \cos \theta \quad (6-8)$$

$$\begin{bmatrix} I_\alpha \\ I_\beta \end{bmatrix} = \begin{bmatrix} \cos \omega t & \sin \omega t \\ -\sin \omega t & \cos \omega t \end{bmatrix} \begin{bmatrix} I_{max} \cos \theta \\ I_{max} \sin \theta \end{bmatrix} \quad (6-9)$$


To obtain the active and reactive load current by multiplying both sides of Equation (6-9) by the matrix  $\begin{bmatrix} \cos \omega t & -\sin \omega t \\ \sin \omega t & \cos \omega t \end{bmatrix}$  gives

$$\begin{bmatrix} I_{max} \cos \theta \\ I_{max} \sin \theta \end{bmatrix} = \begin{bmatrix} \cos \omega t & -\sin \omega t \\ \sin \omega t & \cos \omega t \end{bmatrix} \begin{bmatrix} I_\alpha \\ I_\beta \end{bmatrix} \quad (6-10)$$

From Equation (6-10), the active current  $i_d$  and reactive current  $i_q$  are decomposed from the load current given in Equation (6-5), which are  $I_{max} \cos \theta$ ,  $I_{max} \sin \theta$  respectively.


Figure 6-12 illustrates a block diagram of RPC for a single-phase system, which is based on the above equations. The control system takes instantaneous samples of grid voltage  $v_g$  and the load current of grid  $i_g$ , calculates the reactive power current component  $i_q$  which is used to

combine with the demanding active power current  $i_{d\_re}$  to generate a reference current  $i_{ref}$  for the inverter output.



**Figure 6- 12 Diagram of RPC**


The sine and cosine functions in Equation (6-10), can be provided by a PLL module, as illustrated in Figure 6-13, which is a module designed to obtain instantaneous active and reactive power from the grid. The block of the Orthogonal Generator in Figure 6-13 is an SOGI module introduced in Chapter 3, which is employed to generate a pair of orthogonal signals according with sampling current signal  $i_g$ .



**Figure 6- 13 Split instantaneous active and reactive current**

The system samples the grid voltage to ensure the voltage output of the inverter is completely synchronous with the grid in the terms of frequency, phase angle and the root mean square (RMS) value.

Figure 6-14 implements Equation (6-9), which illustrates that the module produces the output reference current of the inverter according to the demanding reactive current  $i_g$  obtained from the grid current, the inverter providing active current  $i_{d\_ref}$  in accordance with instructions from the control centre, and the PLL signals.




**Figure 6- 14 Generated reference current**


## 6.6 Simulation of single-phase GCI with RPC

Figure 6-15 illustrates a MATLAB/Simulink model of a single-phase GCI with RPC, which is based on the diagram shown in Figure 6-12. In the simulation model, the PLL block assures the GCI output voltage is synchronous with the grid voltage. The block labelled D\_Q decomposes the grid current to obtain the reactive and active components of the grid current. The I\_REF block combines the reactive current component and demands the active current component to generate a reference current for the GCI output. The inverter output current is fed back to and compared with the generated reference current to produce the PWM control signals for the inverter-bridge.

In the simulation model,  $R_l$  represents the equivalent sampling impedance of output current and the resistance of  $R_l$  is  $1\Omega$ ;  $L_3$  is the filter inductor at the inverter output and the inductance of  $L_3$  is  $10\text{mH}$ ;  $Z_l$  is formed by a  $200\Omega$  resistor connected in series with a  $10\text{mH}$  inductor, which represents the domestic load of a residential home; and  $Z_2$  is formed by a  $5\Omega$  resistor connected in serial with a  $10\text{mH}$  inductor, which represents the public loads in a community. The grid voltage is a sinusoidal voltage of frequency  $50\text{ Hz}$ .




**Figure 6- 15 Modelling of single-phase inverter**




**Figure 6- 16 Generated orthogonal signals**

Figure 6-16 illustrates the simulation results of the orthogonal system output a pair of 50Hz negative sine (black trace) and negative cosine wave (blue trace) with respect to a 50Hz input negative cosine wave (red trace) signal. This figure shows that the two output sine (black trace) and cosine (blue trace) signals accurately formed a quadrature pair. Although there is some transient error when the system is started, the system rapidly reaches steady-state conditions (within one cycle) and the produced sinusoidal signal coincides with the input signal.

Constructing a pair of orthogonal signals is a foundation of splitting active and reactive current for single-phase system, so the simulation results mean that a pair of orthogonal signals have been successfully constructed for splitting active and reactive current in single-phase system which will be described in the subsequent section.




**Figure 6- 17 Grid voltage and current without RPC**



**Figure 6- 18 Grid voltage and current with RPC**

The load current lags the grid voltage by a certain phase angle, as shown in Figure 6-17. There is considerable contrast with Figure 6-18, in which, the phase angle of load current perfectly matches that of the grid voltage after RPC is applied to the grid by the inverter that utilizes the presented method of RPC.

Comparison of active and reactive power provided by the power grid before and after RPC is applied, and is illustrated in Figure 6-19 and 6-20 respectively. The results of simulation distinctly demonstrate that the reactive power supported by the grid has been dramatically reduced.




**Figure 6- 19 Comparison of active and reactive power without RPC**



**Figure 6- 20 Comparison of active and reactive power with RPC**







**Figure 6- 21 Another comparison of active and reactive**

Comparing Figure 6-20 and 6-21, the active power supported by the grid is reduced to approximately 5.8 kW in Figure 6-21 from previous 7.1 kW shown in Figure 6-20, whilst the reactive power provided by the grid in two Figures has not changed. This means that the simulation model of the GCI can quantitatively output active power and provide RPC. Therefore, it can also be said that the output of GCI can separately control the active power and reactive power according to the demands from the loads.

Figure 6-22 shows the simulation results of the GCI output without RPC. The red line shows that the inverter injects 0 power into the grid, from 0 to  $4\pi$ . After  $4\pi$ , the inverter starts to inject 8A into the grid. Figure 6-24 also demonstrates that the inverter will still provide power for the residential load when the inverter delivers 0 power into the grid (the green trace).



**Figure 6- 22 Inverter injects zero power into the grid**




**Figure 6- 23 Inverter injects zero active power with RPC**

Figure 6-23 illustrates the simulation results of an inverter operating with RPC, but injecting 0 active power into the grid. The figure shows that the grid current (cyan trace) and the residential load current (green trace) are in phase with the grid voltage (blue trace). From 0 to  $4\pi$ , the GCI only provides RPC for the load without injecting active power into the grid. After  $4\pi$ , the inverter recovers to inject 8A active current into the grid. Therefore, after the inverter

has reached steady state conditions, the grid current reduces by approximately 8A comparing the peak values.

## **6.7 Simulation of three-phase GCI with RPC**


In the previous section, the simulation of a single-phase GCI has demonstrated the feasibility of inverter output active power with RPC. In a whole community, one GCI being responsible for the reactive power requirement of the whole community is impossible. Figure 6-24 illustrates two three-phase GCIs connected with the power grid in parallel to jointly provide for the reactive power requirements of common facilities. The common facilities are formed by three resistor-inductor (RL) loads in star connection, each RL load consists of a  $10\Omega$  resistor connected in series with a 5mH inductor. The output filter of both inverters is formed by a  $0.5\Omega$  resistor connected in series with a 2mH inductor. For the simulation system, the input DC bus voltage is 600V, the peak value of the grid voltage is 310V and frequency of the grid is 50Hz.




**Figure 6- 24 Three-phase GCI with RPC**

Simulation results of the current and voltage of Phase A of the three-phase GCI are shown in Figure 6-25. It is apparent that the grid current is in phase with the voltage, which means the reactive power requirement of common facilities has been compensated by the two inverters.

Figure 6-26 shows the Phase A currents of the two inverter outputs, the Phase A grid current and the Phase A voltage waveforms. Although the two inverter output currents are not in phase with each other and not the same amplitude, the grid current is in phase with the voltage.



**Figure 6- 25 Current and voltage of the grid**




**Figure 6- 26 Current and voltage waveforms**

## 6.8 Modelling of multi-inverter with RPC

Figure 6-27 shows the MATLAB/Simulink model of three GCIs forming a small scale distributed generation system, which supplies power to a community. In the simulation model, the three inverters can be considered as 3-5kW individual GCIs, for individual resident homes

delivering power to the micro-grid, and controlled by a central controller.  $R_3$  represents public facilities (such as small-scale wind turbine, any equipment contained motor, transformer.), which is formed by a  $5\Omega$  resistor connected in series with a 10mH inductor.  $R_2$ ,  $R_6$  and  $R_7$  represent domestic loads which are  $200\Omega$ .  $R_1$ ,  $R_4$  and  $R_5$  represent the equivalent impedance of filter inductors and distribution lines, which are 10mH.




**Figure 6- 27 Multi-inverters with RPC in a micro-grid**


In Figure 6-27, the D\_P block separates active and reactive current of the grid, the blocks of  $GRC_1$ ,  $GRC_2$  and  $GRC_3$  generate reference currents for each inverter with respect to the demanding active and reactive current. In the simulation model,  $INVERTER_1$  provides 4A of active power current with 1/3 of the reactive power current of the public facilities for the micro-grid,  $INVERTER_2$  delivers 8A of active power current with 1/6 of the reactive power current of

the public facilities for the micro-grid and *INVERTER<sub>3</sub>* generates 10A of active power current with ½ of the reactive power current of the public facilities for the micro-grid.

Figure 6-28 illustrates the simulation results of the grid current and voltage; the grid current is in phase with the voltage with the three inverters sharing reactive power. Figure 6-31 demonstrates that the simulated power factor of the grid at the PCC is extremely close to unity, which means the required reactive power of public facility in the micro-grid has been compensated collectively by the three distributed GCIs.




**Figure 6- 28 Current and voltage of the gird**




**Figure 6- 29 Power factor**

Figure 6-30 shows the output currents of the inverters, the grid current and the grid voltage. It is clear that inverter output currents are neither in phase with each other nor the grid voltage, and the amplitudes of the inverter output currents are not equal. However, the grid current is completely in phase with grid voltage. This demonstrates that each GCI can supply different amounts of active and reactive power according to its own circumstances.



**Figure 6- 30 Currents and voltage after PFC**





**Figure 6- 31 Conventional inverter output current and grid voltage**

Figure 6-31 illustrates the output current of three inverters when they only inject active power into the grid, in which, the output current of the inverters are in phase with the grid, but the grid current increases approximately to 12A comparing with Figure 6-30.

## 6.9 Experimental verification of off-grid inverters

Ensuring that the output voltage of a GCI is synchronised with the grid voltage is a fundamental prerequisite, which allows the inverter to be connected to the grid. As the result of a collapse of the grid, which happens occasionally (due to for example load shading, feed transformer failure), all the inverters installed in a community will be turned off due to the loss of the synchronising signal. Therefore, it is necessary to provide a synchronising signal for all the inverters in the micro-grid system to ensure them working on off-grid mode properly without support from external frequency and phase signals from the grid, such as through a diesel generator. It is very complicated to enable an inverter to perform the function of a synchronous generator (Zhong & Hornik, 2013). In a practical smart micro-grid, an uninterruptible power supply (UPS) is usually installed at the circuit breaker, which is adapted to interface with the

grid to provide a synchronising signal for all the inverters in the micro-grid community. Zero-crossing method is the simplest way to yield the grid frequency and phase angle information (Gardner, 2005). This section proposes a novel method to generate a small zero-crossing signal by the central controller in a practical application to enable the inverters in a micro-grid to operate properly on off-grid mode.

### 6.9.1 Generating synchronous signal

An ARM7 core LPC2132 from NXP is utilised to generate the synchronising signal. In the experimental set-up, a case study of an inverter output voltage of frequency 50Hz is considered. Therefore, the central controller only needs to generate a square wave of 50Hz with 50% duty ratio for all the inverters.

Assuming a 50Hz sinusoidal wave has 256 sampling points, i.e. the time interval between each sampling point is  $1/50/256 = 78.125\mu s$ . The external crystal of ARM LPC2132 is 11.0592 MHz, the internal core clock frequency is configured as 5 times the external crystal frequency and the clock frequency of ARM peripheral bus is half of internal core clock frequency.

Figure 6-32 shows that the Timer 0 block in the LPC2132 connects with ARM peripheral bus, the number of clocks cycles between each sampling point can be obtained as follows:

$$N_c = \frac{F_{pclk}}{2F_g N_s} \quad (6 - 11)$$

where


$N_c$  is the number of clock cycles between each sampling point

$F_{pclk}$  is the frequency of ARM peripheral bus

$F_g$  is the frequency of electrical power

$N_s$  is the number of sampling point in each period.

Therefore, if the value of Prescale Register 0  $T_0PR$  in LPC2132 is configured to be  $N_s$ , and the Match Register 0  $T_0MR_0$  is configured as 1, when the Timer 0 Counter  $T_0TC$  is equal to  $T_0MR_0$ , Timer 0 interrupt can be triggered automatically to produce a toggle of one of the input and output (IO) pins as an output in the Timer 0 interrupts routine to broadcast a synchronising signal for each inverter.




**Figure 6- 32 LPC213x block diagram**

Taken from (NXP Semiconductors, 2012)

### 6.9.2 Frequency synchronisation

Figure 6-33 illustrates a square wave with 50% duty ratio; the conventional approach starts counting clocks at the rising at point A, storing the number of clock cycles at the falling edge at point B and stopping the count and storing the number of clock cycles at point C, then calculates the total number of clock cycles captured over one cycle, which can be used to determine the frequency of the square wave.




**Figure 6- 33 Square wave**

Signal attenuation in a practical long-distance transmission system is a concern. This can result in inaccurate determination of the frequency. The key parameters of the inverters' output frequency and number of samples can be broadcasted to all inverters through communication by the central controller. Then, each inverter starts from 0, counts to the sampling number and each rising edge resets the sampling sequence to 0.


### 6.9.3 Experiment and results

Figure 6-34 shows a lab simulation model of smart micro-grid comprising three 1kW C2000 solar DC/AC Single-Phase Inverters working at off-grid mode; an ARM LPC 2132 development toolkit board which is employed to represent the central controller to generate the synchronising signal for three inverters. 110 MHz digital storage oscilloscope with two input channel was used to measure inverter and control centre output signals. Programming IDE is based on ARM MDK, using the joint test action group (JTAG) simulated tool to debug and download program.




**Figure 6- 34 Experimental setup of three off-grid inverters connected together**

Figure 6-35 (a) illustrates the output results of inverter<sub>1</sub> (Yellow trace) and inverter<sub>2</sub> (Cyan trace), 6-35 (b) shows the output results of inverter<sub>2</sub> (Cyan trace) and inverter<sub>3</sub> (Yellow trace). The results in Figure 6-35 clearly demonstrates that the output voltages of the three inverters are completely in phase with each other.



**(a) Output of inverter1 and inverter2**




**(b) Output of inverter2 and inverter3**

**Figure 6- 35 Output voltages of two off-grid inverters**

Figure 6-36 reveals the frequency of the inverter<sub>2</sub> (Cyan trace) output voltage, which synchronises with the input square wave which is shown in Figure 6-36 (yellow trace).

Considering Figures 6-35 and 6-36, it can be stated that the outputs of the three off-grid inverters are completely synchronised.



**Figure 6- 36 Comparison of inverter output (Cyan trace) and input (Yellow trace) synchronous signal**

## 6.10 Summary

Through modelling a GCI with RPC and analysing the simulation results, it has been demonstrated that the presented method of separating active and reactive current components of the grid to quantitatively control reactive power has been successfully achieved. That means the inverter can inject controlled active power into the grid and provide certain amounts of RPC. It has also been demonstrated that the inverter can inject zero active power into the grid and operate as STACOM providing RPC for the grid. In Section 6.9, the comparison of experimental results from the three off-grid single-phase inverters has shown that they can be synchronised whilst working on off-grid mode in a community micro-grid.

# Chapter 7 Conclusions and Future Work

## 7.1 Conclusions and Discussion

This project implemented a simulation model of a smart micro-grid in which RPC was achieved through each GCI in the smart micro-grid by quantitatively producing a certain amount of reactive current so as to collectively share the reactive power demand from the smart micro-grid. A bi-directional DC/AC inverter and an interleaved DC/DC converter was simulated in MATLAB/Simulink, which was employed to charging and discharging battery storage. In experimental work, implemented three-phase SVPWM rectifier based on a full-bridge inverter circuit. Another experimental work connecting three 1kW inverters to simulate a small-scale micro-grid demonstrated that anyone of inverter output voltage and phase is consistent with each other's without support from external grid voltage, frequency and phase signals, typically from a diesel generator. The significance of solving the issue of synchronisation of the inverters in a micro-grid is that domestic users are not seriously affected in the event of grid collapse or cut off, or the micro-grid working in standalone mode.

In order to provide the micro-grid with a stable and continue power supply, the smart micro-grid not only operates under on-grid mode but also runs on off-grid mode.

There are a number of issues to be considered as the micro-grid works on off-grid mode, such as inverter synchronisation with the grid, RPC, remote control, optimisation and end-user's benefit. Except synchronous issue between the each inverter, all the issues addressed above have to be faced in GCI system as well. Therefore, detecting zero-crossing method implemented to allows three GCIs to be synchronised and work properly to solve inverter no power output in the situation of power cut-off while the generated sources are abundant.

An inverter and rectifier, based on the same IGBT full-bridge topology (let's call it as converter), has been successfully modelled in MATLAB/Simulink. The operating mode of the converter can be switched between inverting and rectifying modes in accordance with end-user's demands or by remote control. During low grid electricity tariff periods the converter may work as a rectifier taking electricity from the AC grid and storing DC power in a battery bank configured to enhance users' profit. When the converter operates in inverting mode the priority is to meet the residential demand on electricity, and only the excess power from the renewable power generator is injected into the power grid, which improves users' benefits and reduces reverse power flow to the power grid.

A single-phase GCI with RPC and rectifier input PFC has been developed, adopting the same algorithm employed in three-phase GCI to separate the active and reactive power for the inverter output. This reduces code and data size, increases code execution speed and saves memory space in practical application real-time system.

Chapter 4 presented detailed step-by-step design procedures and simulation of a SOGIPLL for a real-time system. Simulation results demonstrate that the SOGIPLL algorithm has strong anti-interference performance.

Chapter 5 introduced a topology of a four-phase IBDBBC to implement a bi-directional DC power transfer between a low voltage battery storage system and a high voltage DC bus. Simulation results reveal that the ripple voltage of the converter output was significantly reduced, which allows the size of the filter elements to be reduced, and the power switching device's voltage and current stresses have been significantly improved. However, the cost of the four-phase IBDBBC was higher than the cost of a simple circuit topology.

Chapter 6 presented a lab simulation model of a micro-grid comprising three shunt GCIs. In the lab simulation model, the three inverters inject different amounts of active power into the



grid and provide different amounts of reactive power for common loads to successfully implement RPC for the micro-grid.


## **7.2 Future work**

Although the three-phase GCI and the four-phase IBDBBC have been designed and modelled in MATLAB/Simulink, it was not implemented in a practical application due to limited lab resources.


Theoretical analysis reveals that a change of reactive power demand will be reflected in a change in voltage at the side of inverter output . However, in a practical application, due to the intrinsic voltage fluctuations and harmonics on the power grid, measuring the voltage change to derive the RPC is very difficult. Further work is needed to overcome these problems and thereby improve the RPC in real systems.

This project and thesis have focused only on the core technology of implementing the functionality of a micro-grid system. It was impossible to consider the battery storage system in terms of capacity, configuration and lifecycle. Those factors need to be investigated in the future to determine the optimum battery storage system solutions suitable for end-users with different generation potential and residential loads, whilst also considering storage system costs, power sourcing and grid electricity tariff.


# Phase Inverter




# Appendix B Schematic Of Sensors



# Appendix C Schematic Of Main Control For Rectifier



# Appendix D Schematic Of Signal Pre-Processing



# Appendix E MATLAB Function Program

## E.1 Clarke's transformation

```
function [Alpha,Belta]= fcn(Va,Vb,Vc)
%#codegen
Alpha = 2*(Va-(Vb+Vc)/2)/3;
Belta = 1.732*(Vb-Vc)/3;
```

## E.2 Park's transformation

```
function [Vd,Vq]= fcn(Alpha,Belta,Sin,Cos)
%#codegen
Vd = Alpha*cos + Belta*sin;
Vq = Belta*cos - Alpha*sin;
```

## E.3 Inverse Park's transformation

```
function [Alpha,Belta]= fcn(Vd,Vq,Sin,Cos)
%#codegen
Alpha = Vd*cos - Vq*sin;
Belta = Vq*cos + Vd*sin;
```

## E.4 Identify area

```
function [Area,T1,T2]= fcn(Alpha,Belta,Udc)
%#codegen
a=0;
b=0;
c=0;
x=0;
y=0;
z=0;
A=0;
B=0;

Output=0;
a=Belta;
b=0.5*(sqrt(3)*Alpha-Belta);
c=-0.5*(sqrt(3)*Alpha+Belta);

A=Alpha;
B=Belta;

x=1.732*B/Udc;
y=(1.5*A+0.866*B)/Udc;
z=(0.866*B-1.5*A)/Udc;

if a>0
    a=1;
else
```

```

        a=0;
    end
    if b>0
        b=1;
    else
        b=0;
    end
    if c>0
        c=1;
    else
        c=0;
    end
    N=int16(a+2*b+4*c);
    if(N==0)
        N=int16(1);
    end
    switch (N)
        case 1                %%%Area 2
            Output=2;
            T1=y;
            T2=z;
        case 2                %%%Area 6
            Output=6;
            T1=-x;
            T2=y;
        case 3                %%%Area 1
            Output=1;
            T1=-z;
            T2=x;
        case 4                %%%Area 4
            Output=4;
            T1=z;
            T2=-x;
        case 5                %%%Area 3
            Output=3;
            T1=x;
            T2=-y;
        case 6                %%%Area 5
            Output=5;
            T1=-y;
            T2=-z;
        otherwise
            Output=1;
            T1=z;
            T2=y;
    end
    Area=N;
    if ((T1+T2)>1)            %%% Over-modulation
        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    end
end

```

## E.5 Firing time calculation

```

function [Ta,Tb,Tc]= fcn(Sector,Time)
TA=0;

```

```

TB=0;
TC=0;
TD=0;
Ts=1e-4;
TA=Time(3)/4;
TB=Time(1)/2+TA;
TC=Time(2)/2+TA;
TD=Time(1)/2+Time(2)/2+TA;

switch (int16(Sector))
    case 1
        Ta=TB;
        Tb=TD;
        Tc=TA;
    case 2
        Ta=TD;
        Tb=TA;
        Tc=TB;
    case 3
        Ta=TD;
        Tb=TC;
        Tc=TA;
    case 4
        Ta=TA;
        Tb=TB;
        Tc=TD;
    case 5
        Ta=TA;
        Tb=TD;
        Tc=TC;
    case 6
        Ta=TC;
        Tb=TA;
        Tc=TD;
    otherwise
        Ta=Time(3)/4;
        Tb=Time(3)/4;
        Tc=Time(3)/4;
end
Ta=Ta*2;
Tb=Tb*2;
Tc=Tc*2;

```



# Appendix F Central Control Program

## F.1 Main function codes

```
/*=====*/
#include <LPC213X.H>
#include "initPLL.h"
#include "pwm.h"
#include "Timer.h"
#include "adc.h"
#include "definition.h"
/*=====*/
extern void ExtInit(void);
/*=====*/
int main(void)
{
    InitPLL();
    IO0DIR|=OPRLY;
    SETIO0(OPRLY,0); //Switched off inverter output
    InitDAC();          //Initialised DAC function
    InitADC();          //Initialised ADC function
    ExtInit();
    InitTimer0();
    while(1);
    return 0;
}
/*=====*/
```

## F.2 Configure PLL

```
/*=====*/
#define FOOSC 11059200
//#define FOOSC      10000000
```

```

#define FCCLK      FOSC*5
#define PCLK FCCLK/2
/*=====*/
void InitPLL(void)
{
    //The processor clock is configured 50MHz as the osciilator is 10MHz
    PLLCFG=(((FCCLK/FOSC)-1)|(2<<6));
    PLLCON=0x01;    //Enable pll and connect it
    PLLFEED=0xAA;    //Feeding pll
    PLLFEED=0x55;    //Fedding pll
    while(!(PLLSTAT&(1<<10)));
    PLLCON=0x03;
    PLLFEED=0xAA;    //Feeding pll
    PLLFEED=0x55;    //Fedding pll
    VPBDIV=0x02;    //The APB bus clock is half of the processor clock
}
/*=====*/

```

### F.3 Timer 0 codes

```

/*=====*/
#define SAMPLE_POINT    256
#define FREQ_GRID 50
/*=====*/
void __irq Timer0_isr(void)
{
    static int Count=0;
    T0IR|=0x01;
    Count++;
    if(Count>=256)
    {
        Count=0;
    }
}

```

```

    if(Count==0)
    {
        SETIO0(OPRLY,0);
    }
    else if(Count==128)
    {
        SETIO0(OPRLY,1);
    }
    VICVectAddr=0;
}

/*=====*/

void InitTimer0(void)
{
    int mSecond5=0;
    VICIntSelect&=~(1<<4); // Assigning timer0 to irq interrupt
    VICVectCntl0=0x20|4; // Slot 0 appoint to timer0 interrupt
    VICVectAddr0=(unsigned int)&Timer0_isr;
    VICIntEnable|=(1<<4); // Enable the interrupt of timer0
    T0TCR=0; // Disable timer0 for configuration
    T0CTCR=0; // Timer model
    //The sampling frequency is configured as 50x256
    mSecond5=PCLK/FREQ_GRID/SAMPLE_POINT/10 - 1;
    T0PR=mSecond5;
    T0MCR=0x0003; // TC will be reset if MR0 matches it
    T0TCR=0x01; //Timer0 start to run
    T0MR0=9;
    VICVectAddr=0; //clear interrupt vector address
}

/*=====*/

```

# Appendix G Inverter Program

## G.1 Main function codes

```
/*=====*/
#include <LPC213X.H>
#include "initPLL.h"
#include "pwm.h"
#include "Timer.h"
#include "adc.h"
#include "serial.h"
/*=====*/

#define S_OFF_GRID 0
#define S_WAITING_ON_GRID_OUTPUT 1
#define S_ON_GRID_OUTPUT 2
#define S_WAITING_STOP_ON_GRID 3
#define S_WAITING_OFF_GRID_OUTPUT 4
#define S_OFF_GRID_OUTPUT 5
#define S_WAITING_STOP_OFF_GRID 6
#define OPRLY (1<<25)
#define SETIO0(o,s) { \
    if(s==0) \
        IO0CLR|=o; \
    else \
        IO0SET|=o; \
}
#define SETIO1(o,s) { \
    if(s==0) \
        IO1CLR|=o; \
    else \
        IO1SET|=o; \
}
```

```

/*=====*/
typedef struct{
    int16 State;
    int16 (*GetState)(void);
    void (*ChangeState)(int16);
}tagSystem;
typedef struct{
    uint32 Direction;
    uint32 (*GetDirection)(void);
    void (*ChangeDirection)(uint32);
}tagBridge;

extern unsigned int const Sinewave[SAMPLE_POINT];
extern void TestFunction(void);
extern void ExtInit(void);
int16 ReadSystemState(void );
void WriteSystemState(int16 Value);
uint32 KeyScan(void);
tagSystem System={S_OFF_GRID,ReadSystemState,WriteSystemState};
/*=====*/
int16 ReadSystemState(void)
{
    return(System.State);
}
/*=====*/
void WriteSystemState(int16 Value)
{
    System.State=Value;
}
/*=====*/
void InitIO(void)
{

```

```

        IO1DIR=(1<<25);
        SETIO1(OPRLY,0);
#ifdef DEBUG
        IO1DIR=(1<<16);
        SETIO1(LINEZERO,1);
#endif
    }
    /*=====*/
    int main(void)
    {
        int16 SystemState;
        InitPLL();
        PWMInitial();
        InitDAC();
        InitADC();
        InitUart1();
        ExtInit();
        InitIO();
        InitTimer0();
        while(1)
        {
            if(!KeyScan())
            {
                SystemState=System.GetState();
#ifdef DEBUG
                //The system is operating on grid
                if(SystemState==S_OFF_GRID)
                {
                    //The system is Waiting to output to the grid
                    System.ChangeState(S_WAITING_ON_GRID_OUTPUT);
                }
                else if(SystemState==S_ON_GRID_OUTPUT)
                //The system is outputing to the grid

```

```

        {
            //The system is waiting to off the grid
            System.ChangeState(S_WAITING_STOP_ON_GRID);
        }

#else

        if(SystemState==S_OFF_GRID)
        {
            System.ChangeState(S_WAITING_OFF_GRID_OUTPUT);
        }
        else if(SystemState==S_OFF_GRID_OUTPUT)
        {
            System.ChangeState(S_WAITING_STOP_OFF_GRID);
        }

#endif

    }

}

return 0;

}

/*=====*/

#define SW_ON    (1<<10)

void DelaymS(uint16 mSecond)
{
    uint16 i;
    while(--mSecond)
    {
        i=10000;
        while(--i);
    }
}

/*=====*/

uint32 KeyScan(void)
{

```

```

uint32 KeyValue=0;
KeyValue=IO0PIN;
KeyValue&=SW_ON;
if(KeyValue==0)
{
    DelaymS(1);
    do{
        KeyValue=IO0PIN;
        KeyValue&=SW_ON;
    }while (KeyValue==0);
    KeyValue=0;
}
return KeyValue;
}
/*=====*/

```

## G.2 Extern interrupts codes

```

/*=====*/
#include <LPC213X.H>
#include "pwm.h"
#include "main.h"
#include "definition.h"
//Timer0      VICVectCntl0
//Ext3         VICVectCntl3
//Ext2         VICVectCntl4
//Uart1        VICVectCntl5
extern tagBridge Bridge;
extern tagSystem System;
extern unsigned int PeroidReset;
extern unsigned int Count;
void __irq ExtINT3_isr(void);
void __irq ExtINT2_isr(void);

```



```

/*=====*/
void ExtInit(void)
{
    PINSEL0&=0x3FFFFFFF;
    PINSEL0|=0x80000000;           // P0.15 is assigned to EINT2
    PINSEL1&=0xCFFFFFFF;
    PINSEL1|=0x20000000;           // P0.30 is assigned to EINT3
    EXTMODE|=((1<<2)|(1<<3));     // Ext2 and Ext3 is edge sensitive
    EXTPOLAR|=((1<<2)|(1<<3));     // Ext2 and Ext3 is rising-edge sensitive
    VICIntSelect&=~(1<<16);        // Assigning Ext2 to irq interrupt
    VICIntSelect&=~(1<<17);        // Assigning Ext3 to irq interrupt
    VICVectCntl4=0x20|16;          // Slot 4 appoint to Ext3 interrupt
    VICVectCntl3=0x20|17;          // Slot 3 appoint to Ext3 interrupt
    VICVectAddr3=(unsigned int)&ExtINT3_isr;
    VICVectAddr4=(unsigned int)&ExtINT2_isr;
    VICIntEnable|=(1<<16);         // Enable the interrupt of ExtINT2
    VICIntEnable|=(1<<17);         // Enable the interrupt of ExtINT3
    EXTINT|=((1<<2)|(1<<3));       // Clear external interrupt 2 and3
}

/*=====*/
void __irq ExtINT3_isr(void)
{
    uint32 Direction=POSITIVE;
    uint32 SystemState;
    EXTINT|=(1<<3);                // Clear external interrupt 3
    SystemState=System.GetState();
    if(SystemState==S_WAITING_ON_GRID_OUTPUT)
    {
        SystemState=S_ON_GRID_OUTPUT;
        System.ChangeState(SystemState);
        SETIO1(OPRLY,1);
    }
}

```

```

else if(SystemState==S_WAITING_STOP_ON_GRID)
{
    SystemState=S_OFF_GRID;
    System.ChangeState(SystemState);
    SETIO1(OPRLY,0);
}
if(SystemState==S_ON_GRID_OUTPUT)
{
    Direction=Bridge.GetDirection();
    Direction^=0x01;
    Bridge.ChangeDirection(Direction);
}
VICVectAddr=0;
}
/*=====*/
void __irq ExtINT2_isr(void)
{
    EXTINT|=(1<<2);                // Clear interrupt flag
    PeroidReset=1;
    VICVectAddr=0;                // return interrupt routine
}
/*=====*/

```

## G.3 Timer 0 codes

```
/*=====*/
#include <LPC213X.H>
#include "initPLL.h"
#include "Timer.h"
#include "PWM.h"
#include "adc.h"
#include "definition.h"
/*=====*/

unsigned int SinePointer=0;
unsigned int SampleOrder=INC_DIR;
unsigned int Count=0;
unsigned int PeroidReset=0;
//unsigned int Direction=POSITIVE;
extern tagFIR FIR;
extern tagSystem System;
extern tagBridge Bridge;
/*=====*/

unsigned int const Sinewave[HALF_SAMPLE_POINT]=
{
    0,25,49,74,98,122,147,171,195,219,243,267,290,314,337,360,
    383,405,428,450,471,493,514,535,556,576,596,615,634,653,672,690,
    707,724,741,757,773,788,803,818,831,845,858,870,882,893,904,914,
    924,933,942,950,957,964,970,976,981,985,989,992,995,997,999,1001,
    1001,1001,999,997,995,992,989,985,981,976,970,964,957,950,942,933,
    924,914,904,893,882,870,858,845,831,818,803,788,773,757,741,724,
    707,690,672,653,634,615,596,576,556,535,514,493,471,450,428,405,
    383,360,337,314,290,267,243,219,195,171,147,122,98,74,49,25
};

/*=====*/

void __irq Timer0_isr(void)
```

```

{
    static int i=0;
    static int HistoryDir=POSITIVE;
    uint32 Direction;
    unsigned int Value;
    int16 SystemState;
    T0IR|=0x01;
    if(PeroidReset)
    {
        PeroidReset=0;
        Count=0;
    }
    Value=Sinewave[i];
    Value*=9;                                     //The output 90% of full
    Value/=10;
    i++;
    SystemState=System.GetState();
    Direction=Bridge.GetDirection();
    if(i>=HALF_SAMPLE_POINT)
    {
        i=0;
        //The system is going to output in off-grid mode
        if(SystemState==S_WAITING_OFF_GRID_OUTPUT)
        {
            System.ChangeState(S_OFF_GRID_OUTPUT);
            SystemState=S_OFF_GRID_OUTPUT;
            SETIO1(OPRLY,1);
        }else if(SystemState==S_WAITING_STOP_OFF_GRID)
        //The system is going to stop output in off-grid mode
        {
            System.ChangeState(S_OFF_GRID);
            SystemState=S_OFF_GRID;
            SETIO1(OPRLY,0);
        }
    }
}

```

```

    }
}
if(SystemState==S_OFF_GRID_OUTPUT) //Off-grid output
{
    if(i==0)
    {
        Direction^=1;
        Bridge.ChangeDirection(Direction);
        ZeroCrossing(Direction);
    }
    if(Direction==POSITIVE)
    {
        PWMMR1=Value;
        PWMMR5=Value;
        PWMLER=((1<<1)|(1<<5));
    }
    else
    {
        PWMMR3=Value;
        PWMMR2=Value;
        PWMLER=((1<<2)|(1<<3));
    }
}
else if (SystemState==S_ON_GRID_OUTPUT)    //On-grid output
{
    Direction=Bridge.GetDirection();
    PWM_UpgradeValue(Value,Direction);
    if(Direction!=HistoryDir)
    {
        HistoryDir=Direction;
        ZeroCrossing(Direction);
    }
}

```

```

    }
    else
    {
        PWM2_IO_LOW();
        PWM5_IO_LOW();
        PWM1_IO_LOW();
        PWM3_IO_LOW();
        SETIO1(OPRLY,0);
    }
    VICVectAddr=0;
}

/*=====*/
void InitTimer0(void)
{
    int mSecond5=0;
    VICIntSelect&=~(1<<4);           // Assigning timer0 to irq interrupt
    VICVectCntl0=0x20|4;              // Slot 0 appoint to timer0 interrupt
    VICVectAddr0=(unsigned int)&Timer0_isr;
    VICIntEnable|=(1<<4);             // Enable the interrupt of timer0
    T0TCR=0;                          // Disable timer0 for configuration
    T0CTCR=0;                         // Timer model
    mSecond5=PCLK/FREQ_GRID/SAMPLE_POINT/10 - 1;
    T0PR=mSecond5;
    T0MCR=0x0003;                    // TC will be reset if MR0 matches it
    T0TCR=0x01;
    T0MR0=9;
    VICVectAddr=0;
}

/*=====*/

```

## G.4 PWM generator codes

```
/*=====*/
#include <LPC213X.H>
//#include <LPC21xx.H>
#include "main.h"
#include "pwm.h"
#define PWM1_BITS 0
#define PWM2_BITS 14
#define PWM3_BITS 2
#define PWM5_BITS 10
typedef struct{
    uint32 Direction;
    uint32 (*GetDirection)(void);
    void (*ChangeDirection)(uint32);
}tagBridge;
tagBridge Bridge={ POSITIVE,ReadDirection,WriteDirection };
void __irq isr_PWM(void);
/*=====*/
void ZeroCrossing(unsigned int Direction)
{
    if (Direction==POSITIVE)
    {
        //First step is Disable PWM3 output
        PWM3_IO_LOW();
        PWM2_IO_LOW();
        PWM1Connect();
        PWM5Connect();
    }
    else
    {
        PWM1_IO_LOW();
    }
}
```

```

        PWM5_IO_LOW();
        PWM3Connect();
        PWM2Connect();
    }
}

/*=====*/
void PWMInitial(void)
{
    IO0DIR|=(0x00000003|(1<<PWM2_IO)|(1<<PWM5_IO));
    PINSEL0|=(2<<PWM1_BITS|2<<PWM2_BITS)|(2<<PWM3_BITS);
    PINSEL1|=(1<<PWM5_BITS);
    PWM1_IO_LOW();
    PWM3_IO_LOW();
    PWM2_IO_LOW();
    PWM5_IO_LOW();
    PWMPCR=((1<<PWM1ENA)|(1<<PWM3ENA)
            |(1<<PWM2ENA)|(1<<PWM5ENA));
    PWMTCR=0x02;                //reset pwm timer counter
    PWMPR=0;                    // no prescale
    PWMMCR=0x02;
    PWMMR0=1000;
    PWMLER=0x0B;
    PWMTCR=0x09;
}

/*=====*/
uint32 ReadDirection(void)
{
    return Bridge.Direction;
}

/*=====*/
void WriteDirection(uint32 Direction)
{

```



```

        Bridge.Direction=Direction;
    }
    /*=====*/
void PWM_UpgradeValue(uint32 Value, uint32 Direction)
{
    if(Direction==POSITIVE)
    {
        PWMMR1=Value;
        PWMMR5=Value;
        PWMLER=((1<<1)|(1<<5));
    }
    else
    {
        PWMMR3=Value;
        PWMMR2=Value;
        PWMLER=((1<<2)|(1<<3));
    }
}
/*=====*/

```

# Appendix H Three-phase SVPWM Rectifier

## Program

### H.1 Three-phase rectifier with PFC codes

```
/*=====*/
#include "DSP28x_Project.h"
#include "definition.h"
#include <math.h>
/*=====*/

#define RATE_MODULATION      1
#define OFFSET      500
#define MAX_VALUE_COMP      1000//1875
#define MAX_SAMPLE_VAL      4095
#define MAX_INPUT_VOL 3
#define GRID_FRE   50
#define LIN_VAL    2.5E-3
#define TS      1000

#define MAX_AC_CURRENT      50
#define MAX_DC_BUS          750
#define SAMPLE_GAIN      MAX_SAMPLE_VAL/MAX_INPUT_VOL

#define VOL_CROSS_ZERO      1706 //4095*1.25/3
#define CUR_CROSS_ZERO      2048
#define VOL_GAIN  300
#define CUR_GAIN  25
#define MODULATION_RATE      1

#define DC_BUS      600
//Sampling Frequency
```

```

//      12.8K
#define A1    -1.961
#define A2    0.96159
#define B0    0.01921
#define B1    -0.01921
#define B2    0.0002362
#define B3    2*B2
#define B4    B2

/*=====*/
SOGIType PhaseAValue={0,0};
SOGIType PhaseBValue={0,0};
SOGIType PhaseCValue={0,0};
PLL PLLPhaseA={0,1};
extern void PWM_ModifyRate(TagModuleTime PWMTimer);
/*=====*/

int GetAmplitude(ThreePhase *pInput)
{
    float Amplitude,Alpha,Beta;
    Alpha=2.0/3*pInput->PhaseA-
        2.0/3*0.5*(pInput->PhaseB+pInput->PhaseC);
    Beta=1.732/3*(pInput->PhaseB-pInput->PhaseC);
    Amplitude=Alpha*Alpha+Beta*Beta;
    Amplitude=sqrt(Amplitude);
    return((int)Amplitude);
}

/*=====*/

float SOGIFilterA(float Value)
{
    float Temp1,Temp2,ReturnValue;
    Temp1=-1.961*PhaseAValue.Zeta1;
    Temp2=0.96159*PhaseAValue.Zeta2;
    Temp1=Temp1+Temp2;

```

```

    Temp1=Value-Temp1;
    Temp2=-0.01921*PhaseAValue.Zeta2;
    PhaseAValue.Zeta2=PhaseAValue.Zeta1;
    PhaseAValue.Zeta1=Temp1;
    Temp1=0.01921*Temp1;
    ReturnValue=Temp1+Temp2;
    return ReturnValue;
}

/*=====*/

float SOGIFilterB(float Value)
{
    float Temp1,Temp2,ReturnValue;
    Temp1=-1.961*PhaseBValue.Zeta1;
    Temp2=0.96159*PhaseBValue.Zeta2;
    Temp1=Temp1+Temp2;
    Temp1=Value-Temp1;
    Temp2=-0.01921*PhaseBValue.Zeta2;
    PhaseBValue.Zeta2=PhaseBValue.Zeta1;
    PhaseBValue.Zeta1=Temp1;
    Temp1=0.01921*Temp1;
    ReturnValue=Temp1+Temp2;
    return ReturnValue;
}

/*=====*/

float SOGIFilterC(float Value)
{
    float Temp1,Temp2,ReturnValue;
    Temp1=-1.961*PhaseCValue.Zeta1;
    Temp2=0.96159*PhaseCValue.Zeta2;
    Temp1=Temp1+Temp2;
    Temp1=Value-Temp1;
    Temp2=-0.01921*PhaseCValue.Zeta2;

```

```

    PhaseCValue.Zeta2=PhaseCValue.Zeta1;
    PhaseCValue.Zeta1=Temp1;
    Temp1=0.01921*Temp1;
    ReturnValue=Temp1+Temp2;
    return ReturnValue;
}

/*=====*/
float SOGIFilter(SOGIType *pNode,float Value)
{
    float Temp1,Temp2,ReturnValue;
    Temp1=pNode->Zeta1*A1;
    Temp2=pNode->Zeta2*A2;
    Temp1=Temp1+Temp2;
    Temp1=Value-Temp1;
    Temp2=pNode->Zeta2*B1;
    pNode->Zeta2=pNode->Zeta1;
    pNode->Zeta1=Temp1;
    Temp1=Temp1*B0;
    ReturnValue=Temp1+Temp2;
    return ReturnValue;
}

/*=====*/
void PLLFilter(SOGIType *pNode,PLL *pPLL, float Value)
{
    float Node0,Node1,Node2,Temp1,Temp2,Temp3;
    Node1=pNode->Zeta1;
    Node2=pNode->Zeta2;
    Temp1=pNode->Zeta1*A1;
    Temp2=pNode->Zeta2*A2;
    Temp1=Temp1+Temp2;
    Node0=Value-Temp1;
    Temp2=pNode->Zeta2*B1;

```

```

Temp1=Node0*B0;
pPLL->Sin=Temp1+Temp2;

Temp1=Node0*B2;
Temp2=Node1*B3;
Temp3=Node2*B4;
pPLL->Cos=-(Temp1+Temp2+Temp3);
pNode->Zeta2=Node1;
pNode->Zeta1=Node0;
}
/*=====*/
void PreProcessSamples(VISamples *pSample)
{
    static int Count=0;
    (*pSample).Voltage.PhaseA-=VOL_CROSS_ZERO;
    (*pSample).Voltage.PhaseA*=VOL_GAIN;
    (*pSample).Voltage.PhaseB-=VOL_CROSS_ZERO;
    (*pSample).Voltage.PhaseB*=VOL_GAIN;
    (*pSample).Voltage.PhaseC-=VOL_CROSS_ZERO;
    (*pSample).Voltage.PhaseC*=VOL_GAIN;

    (*pSample).Current.PhaseA-=CUR_CROSS_ZERO;
    (*pSample).Current.PhaseA*=CUR_GAIN;
    (*pSample).Current.PhaseB-=CUR_CROSS_ZERO;
    (*pSample).Current.PhaseB*=CUR_GAIN;
    (*pSample).Current.PhaseC-=CUR_CROSS_ZERO;
    (*pSample).Current.PhaseC*=CUR_GAIN;

    (*pSample).Voltage.PhaseA/=SAMPLE_GAIN;
    (*pSample).Voltage.PhaseB/=SAMPLE_GAIN;
    (*pSample).Voltage.PhaseC/=SAMPLE_GAIN;
    (*pSample).Current.PhaseA/=SAMPLE_GAIN;

```

```

(*pSample).Current.PhaseB/=SAMPLE_GAIN;
(*pSample).Current.PhaseC/=SAMPLE_GAIN;

(*pSample).dcbus*=MAX_DC_BUS;
(*pSample).dcbus/=MAX_SAMPLE_VAL;

CurrentA=SOGIFilter(&PhaseAValue,(*pSample).Current.PhaseA);
CurrentB=SOGIFilter(&PhaseBValue,(*pSample).Current.PhaseB);
CurrentC=SOGIFilter(&PhaseCValue,(*pSample).Current.PhaseC);
(*pSample).Current.PhaseA=CurrentA;
(*pSample).Current.PhaseB=CurrentB;
(*pSample).Current.PhaseC=CurrentC;
Temp=SOGIFilterA((*pSample).Voltage.PhaseA);
(*pSample).Voltage.PhaseA=Temp;

Temp=SOGIFilterB((*pSample).Voltage.PhaseB);
(*pSample).Voltage.PhaseB=Temp;

Temp=SOGIFilterC((*pSample).Voltage.PhaseC);
(*pSample).Voltage.PhaseC=Temp;
}
/*=====*/
void ClarkeTransf(ThreePhase *pInput, ClarkeType *pOutput)
{
    pOutput->Alpha=2.0/3*pInput->PhaseA-
                2.0/3*0.5*(pInput->PhaseB+pInput->PhaseC);
    pOutput->Beta=1.732/3*(pInput->PhaseB-pInput->PhaseC);
}
/*=====*/
void InvParkTransf(InvParkType *Input, ClarkeType *Output)
{
    Output->Alpha=Input->Cos*Input->ParkOut.Direct-

```

```

        Input->Sin*Input->ParkOut.Quadrature;
    Output->Beta=Input->Cos*Input->ParkOut.Quadrature+
        Input->Sin*Input->ParkOut.Direct;
}

/*=====*/
void ParkTransf(ParkInputType *Input, ParkType *Output)
{
    Output->Direct=Input->Stationary.Alpha*Input->Cos+
        Input->Stationary.Beta*Input->Sin;
    Output->Quadrature=Input->Stationary.Beta*Input->Cos-
        Input->Stationary.Alpha*Input->Sin;
}

/*=====*/
void PhaseLockedLoop(ParkInputType *pVoltage,PLL *pll)
{
    float Amplitude=0;
    Amplitude=pVoltage->Stationary.Alpha*pVoltage->Stationary.Alpha+
        pVoltage->Stationary.Beta*pVoltage->Stationary.Beta;
    Amplitude=sqrt(Amplitude);
    if(Amplitude>180)
    {
        pll->Cos=pVoltage->Stationary.Alpha/Amplitude;
        pll->Sin=pVoltage->Stationary.Beta/Amplitude;
    }
}

/*=====*/
void GetInvParkVal(InvParkType *pInvPark)
{
    float Vd,Vq,IDref,IQref;
    PIDController(pInvPark->DCVol,DC_BUS,&DCVoltage);
    IDref=DC_BUS-pInvPark->DCVol;
    IDref=-pInvPark->Current.Direct;
}

```



```

PIDController(pInvPark->Current.Direct,DCVoltage.OuputValue,
               &DirectCurrent);
IQref=0-pInvPark->Current.Quadrature;
PIDController(pInvPark->Current.Quadrature,0,&QuadratureCurrent);
Vd=pInvPark->Current.Quadrature*(6.283185*GRID_FRE*LIN_VAL);
Vd+=pInvPark->Voltage.Direct;
Vd-=DirectCurrent.OuputValue;
Vd-=IDref;

Vq=pInvPark->Voltage.Quadrature;
Vq-=QuadratureCurrent.OuputValue;
Vq-=IQref;
Vq-=pInvPark->Current.Direct*(6.283185*GRID_FRE*LIN_VAL);
pInvPark->ParkOut.Direct=Vd;
pInvPark->ParkOut.Quadrature=Vq;
}
/*=====*/
void GetModuleTime(ClarkeType *pPointer, TagModuleTime *pCOMP)
{
    float a,b,c;
    unsigned int Area=0;
    float T1,T2,T0,X,Y,Z,TA,TB,TC,TD,TimerA,TimerB,TimerC;
    /*The variable a,b,c are used to determine sectors*/
    a=pPointer->Beta;
    b=0.866*pPointer->Alpha-0.5*pPointer->Beta;
    c=-0.866*pPointer->Alpha-0.5*pPointer->Beta;
    /*X,Y,Z are utilised to obtain module time*/
    X=(1.732*pPointer->Beta)*RATE_MODULATION/DC_BUS;
    Y=(1.5*pPointer->Alpha+0.866*pPointer->Beta)*
        RATE_MODULATION/DC_BUS;
    Z=(0.866*pPointer->Beta-1.5*pPointer->Alpha)*
        RATE_MODULATION/DC_BUS;

```

```

if(a>0)
    Area=1;
if(b>0)
    Area+=2;
if(c>0)
    Area+=4;
switch(Area)
{
    case 1:
        T1=Y;
        T2=Z;
        if((T1+T2)>1)
        {
            T1=T1/(T1+T2);
            T2=T2/(T1+T2);
        }
        T0=TS*(1-T1-T2);
        T1=TS*T1;
        T2=TS*T2;
        TA=T0/4;
        TB=T1/2+TA;
        TC=T2/2+TA;
        TD=T1/2+T2/2+TA;
        TimerA=TB;
        TimerB=TD;
        TimerC=TA;
        break;
    case 2:
        T1=-X;
        T2=Y;
        if((T1+T2)>1)
        {

```

```

        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    }
    T0=TS*(1-T1-T2);
    T1=TS*T1;
    T2=TS*T2;
    TA=T0/4;
    TB=T1/2+TA;
    TC=T2/2+TA;
    TD=T1/2+T2/2+TA;
    TimerA=TD;
    TimerB=TA;
    TimerC=TB;
    break;
case 3:
    T1=-Z;
    T2=X;
    if((T1+T2)>1)
    {
        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    }
    T0=TS*(1-T1-T2);
    T1=TS*T1;
    T2=TS*T2;
    TA=T0/4;
    TB=T1/2+TA;
    TC=T2/2+TA;
    TD=T1/2+T2/2+TA;
    TimerA=TD;
    TimerB=TC;
    TimerC=TA;

```

```

        break;
case 4:
    T1=Z;
    T2=-X;
    if((T1+T2)>1)
    {
        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    }
    T0=TS*(1-T1-T2);
    T1=TS*T1;
    T2=TS*T2;
    TA=T0/4;
    TB=T1/2+TA;
    TC=T2/2+TA;
    TD=T1/2+T2/2+TA;
    TimerA=TA;
    TimerB=TB;
    TimerC=TD;
    break;
case 5:
    T1=X;
    T2=-Y;
    if((T1+T2)>1)
    {
        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    }
    T0=TS*(1-T1-T2);
    T1=TS*T1;
    T2=TS*T2;
    TA=T0/4;

```

```

        TB=T1/2+TA;
        TC=T2/2+TA;
        TD=T1/2+T2/2+TA;
        TimerA=TA;
        TimerB=TD;
        TimerC=TC;
        break;
case 6:
    T1=-Y;
    T2=-Z;
    if((T1+T2)>1)
    {
        T1=T1/(T1+T2);
        T2=T2/(T1+T2);
    }
    T0=TS*(1-T1-T2);
    T1=TS*T1;
    T2=TS*T2;
    TA=T0/4;
    TB=T1/2+TA;
    TC=T2/2+TA;
    TD=T1/2+T2/2+TA;
    TimerA=TC; //Notice variable TC, TA and TD are float types
    TimerB=TA;
    TimerC=TD;
    break;
}
pCOMP->CompareA=(unsigned int)(TimerA+0.5);
pCOMP->CompareB=(unsigned int)(TimerB+0.5);
pCOMP->CompareC=(unsigned int)(TimerC+0.5);
}
/*=====*/

```

```

void GeneratePWM(VISamples *pSample)
{
    float MaxValue,MinValue,PhaseA,PhaseB,PhaseC,Temp;
    static int i=0;
    static int ACAmplitude=0;
    static int PhaseLocked=0;
    static float PastSinValue=0.0001;
    ParkInputType Voltages;
    ParkInputType Currents;
    ParkType VParkOut;
    ParkType IParkOut;
    InvParkType InvParkInput;
    ClarkeType InvClarke;
    TagModuleTime Comp;

    TagModuleTime PWMTimer;
    PhaseA=0;
    PhaseB=0;
    PhaseC=0;
    PreProcessSamples(pSample);
    ACAmplitude=GetAmplitude(&((*pSample).Voltage));
    if(ACAmplitude>10)
    {
        if(i<1000)
            i++;
    }
    else
    {
        i=0;
        PWMTimer.CompareA=0;
        PWMTimer.CompareB=0;
        PWMTimer.CompareC=0;
    }
}

```

```

        PWM_ModifyRate(PWMTimer);
    }
    if(i>=1000)
    {
        PhaseA=(*pSample).Voltage.PhaseA;
        PhaseB=(*pSample).Voltage.PhaseB;
        PhaseC=(*pSample).Voltage.PhaseC;
        PhaseA/=ACAmplitude;
        PhaseB/=ACAmplitude;
        PhaseC/=ACAmplitude;

        ClarkeTransf(&(pSample->Current),&(Currents.Stationary));
        ClarkeTransf(&(pSample->Voltage),&(Voltages.Stationary));

        PhaseLockedLoop(&Voltages,&PLLPhaseA);
        if(PhaseLocked==1)
        {
            Voltages.Cos=PLLPhaseA.Cos;
            Voltages.Sin=PLLPhaseA.Sin;
            Currents.Cos=PLLPhaseA.Cos;
            Currents.Sin=PLLPhaseA.Sin;
            InvParkInput.Cos=PLLPhaseA.Cos;
            InvParkInput.Sin=PLLPhaseA.Sin;
            ParkTransf(&Voltages,&VParkOut);
            ParkTransf(&Currents,&IParkOut);
            InvParkInput.Voltage.Direct=VParkOut.Direct;
            InvParkInput.Voltage.Quadrature=VParkOut.Quadrature;
            InvParkInput.Current.Direct=IParkOut.Direct;
            InvParkInput.Current.Quadrature=IParkOut.Quadrature;
            InvParkInput.DCVol=pSample->dcbus;
            GetInvParkVal(&InvParkInput);
            InvParkTransf(&InvParkInput,&InvClarke);

```

```

        GetModuleTime(&InvClarke,&Comp);
    }
    else
    {
        if((PLLPhaseA.Sin>0)&&(PastSinValue<0))
        {
            PhaseLocked=1;
        }
        else
            PastSinValue=PLLPhaseA.Sin;
    }
}

}

/*=====*/

```



## H.2 SVPWM generation

```
/*=====*/
#include "DSP28x_Project.h" // Device Headerfile and Examples Include File
#include "definition.h"

#define MAX_LEN 50
#define MAX_LEN 33
#define GOING_UP 1
#define GOING_DOWN 0
#define SYSCLK 150000000
#define EPWM_DIV 4
#define FR_SWITCH10K 1000//SYSCLK/2/EPWM_DIV/10000
/*=====*/

void InitPWM(void)
{
    EALLOW;

    GpioCtrlRegs.GPAMUX1.bit.GPIO0=1;
    GpioCtrlRegs.GPAMUX1.bit.GPIO1=1;
    GpioCtrlRegs.GPAMUX1.bit.GPIO2=1;
    GpioCtrlRegs.GPAMUX1.bit.GPIO3=1;
    GpioCtrlRegs.GPAMUX1.bit.GPIO4=1;
    GpioCtrlRegs.GPAMUX1.bit.GPIO5=1;
    GpioCtrlRegs.GPADIR.bit.GPIO0=1;
    GpioCtrlRegs.GPADIR.bit.GPIO1=1;
    GpioCtrlRegs.GPADIR.bit.GPIO2=1;
    GpioCtrlRegs.GPADIR.bit.GPIO3=1;
    GpioCtrlRegs.GPADIR.bit.GPIO4=1;
    GpioCtrlRegs.GPADIR.bit.GPIO5=1;

    EPwm1Regs.TBPRD=FR_SWITCH10K;
    EPwm1Regs.TBPHS.half.TBPHS=0;
    EPwm1Regs.TBCTL.bit.CTRMODE=TB_COUNT_UPDOWN;
```

```

EPwm1Regs.TBCTL.bit.PHSEN=TB_DISABLE;
EPwm1Regs.TBCTL.bit.PRDL=TB_SHADOW;
EPwm1Regs.TBCTL.bit.SYNCOSEL=TB_CTR_ZERO;
EPwm1Regs.TBCTL.bit.HSPCLKDIV=TB_DIV4;
EPwm1Regs.CMPCTL.bit.SHDWAMODE=CC_SHADOW;
EPwm1Regs.CMPCTL.bit.SHDWBMODE=CC_SHADOW;
EPwm1Regs.CMPCTL.bit.LOADAMODE=CC_CTR_ZERO;
EPwm1Regs.CMPCTL.bit.LOADBMODE=CC_CTR_ZERO;

```

```

EPwm1Regs.AQCTLA.bit.CAU=AQ_CLEAR;
EPwm1Regs.AQCTLA.bit.CAD=AQ_SET;

```

```

EPwm1Regs.DBCTL.bit.OUT_MODE=DB_FULL_ENABLE;
EPwm1Regs.DBCTL.bit.POLSEL=DB_ACTV_HIC;
EPwm1Regs.DBFED=50;
EPwm1Regs.DBRED=50;

```

```

EPwm2Regs.TBPRD=FR_SWITCH10K;
EPwm2Regs.TBPHS.half.TBPHS=0;
EPwm2Regs.TBCTL.bit.CTRMODE=TB_COUNT_UPDOWN;
EPwm2Regs.TBCTL.bit.PHSEN=TB_ENABLE;
EPwm2Regs.TBCTL.bit.PRDL=TB_SHADOW;
EPwm2Regs.TBCTL.bit.SYNCOSEL=TB_SYNC_IN;
EPwm2Regs.TBCTL.bit.HSPCLKDIV=TB_DIV4;
EPwm2Regs.CMPCTL.bit.SHDWAMODE=CC_SHADOW;
EPwm2Regs.CMPCTL.bit.SHDWBMODE=CC_SHADOW;
EPwm2Regs.CMPCTL.bit.LOADAMODE=CC_CTR_ZERO;
EPwm2Regs.CMPCTL.bit.LOADBMODE=CC_CTR_ZERO;

```

```

EPwm2Regs.AQCTLA.bit.CAU=AQ_CLEAR;
EPwm2Regs.AQCTLA.bit.CAD=AQ_SET;

```

```

EPwm2Regs.DBCTL.bit.OUT_MODE=DB_FULL_ENABLE;
EPwm2Regs.DBCTL.bit.POLSEL=DB_ACTV_HIC;
EPwm2Regs.DBFED=50;
EPwm2Regs.DBRED=50;

```

```

EPwm3Regs.TBPRD=FR_SWITCH10K;
EPwm3Regs.TBPHS.half.TBPHS=0;
EPwm3Regs.TBCTL.bit.PHSEN=TB_ENABLE;
EPwm3Regs.TBCTL.bit.CTRMODE=TB_COUNT_UPDOWN;
EPwm3Regs.TBCTL.bit.PRDLT=TB_SHADOW;
EPwm3Regs.TBCTL.bit.SYNCSEL=TB_SYNC_IN;
EPwm3Regs.TBCTL.bit.HSPCLKDIV=TB_DIV4;
EPwm3Regs.CMPCTL.bit.SHDWAMODE=CC_SHADOW;
EPwm3Regs.CMPCTL.bit.SHDWBMODE=CC_SHADOW;
EPwm3Regs.CMPCTL.bit.LOADAMODE=CC_CTR_ZERO;
EPwm3Regs.CMPCTL.bit.LOADBMODE=CC_CTR_ZERO;
EPwm3Regs.AQCTLA.bit.CAU=AQ_CLEAR;
EPwm3Regs.AQCTLA.bit.CAD=AQ_SET;

```

```

EPwm3Regs.DBCTL.bit.OUT_MODE=DB_FULL_ENABLE;
EPwm3Regs.DBCTL.bit.POLSEL=DB_ACTV_HIC;
EPwm3Regs.DBFED=50;
EPwm3Regs.DBRED=50;
EPwm1Regs.TBCTR=0;
EPwm2Regs.TBCTR=0;
EPwm3Regs.TBCTR=0;
EDIS;

```

```

}

```

```

/*=====*/

```

```

void PWM_ModifyRate(TagModuleTime PWMTimer)

```

```

{

```

```

    EPwm1Regs.CMPA.half.CMPA=PWMTimer.CompareA;

```

```
    EPwm2Regs.CMPA.half.CMPA=PWMTimer.CompareB;  
    EPwm3Regs.CMPA.half.CMPA=PWMTimer.CompareC;  
}  
/*=====*/
```

## H.3 ADC sampling codes

```
/*=====*/
#include "DSP28x_Project.h"
#include "definition.h"
#include <math.h>
/*=====*/

#if(CPU_FRQ_150MHZ)
    #define ADC_MODCLK    0x03    // High speed peripheral clock
    // HSPCLK=SYSCLKOUT/(2*ADC_MODCLK)
#endif                                //HSPCLK=150M/(2*3)=25M

#if(CPU_FRQ_100MHZ)
    #define ADC_MODCLK    0x02
#endif

#define ADC_CKPS    0x3            //12.5MHz
#define ADC_SHCLK    0xf
#define SYSCLK    150000000
#define TS_1M    SYSCLK/2/1000000
#define TS_100K    SYSCLK/2/100000
#define TS_50K    SYSCLK/2/50000
#define TS_20K    SYSCLK/2/20000
#define TS_12_8K    SYSCLK/2/12800
#define TS_10K    SYSCLK/2/10000
#define TS_3K2    SYSCLK/2/3200
/*=====*/

// #define ADC_Cal (void (*)(void))0x380080
extern void GeneratePWM(VISamples *);
Uint32 ConversionCount=0;
Uint16 Voltage1;
Uint16 Voltage2;
```

```

Uint16 Voltage3;
Uint16 Voltage4;
Uint16 Voltage5;
Uint16 Voltage6;
Uint16 Voltage7;
Uint16 Voltage8;
VISamples ADCSample;
TagModuleTime PWMTimer;

/*=====*/
void ConfigureAdc(void)
{
    // Configure ADC
    EALLOW;
    AdcRegs.ADCTRL1.bit.SEQ_CASC=1;
    AdcRegs.ADCTRL3.bit.SMODE_SEL=0;
    AdcRegs.ADCTRL3.bit.ADCCLKPS=ADC_CKPS;
    AdcRegs.ADCTRL1.bit.ACQ_PS=ADC_SHCLK;
    AdcRegs.ADCMAXCONV.all = 0x0007;    // Setup 2 conv's on SEQ1
    // Setup ADCINA3 as 1st SEQ1 conv.
    AdcRegs.ADCCHSELSEQ1.bit.CONV00 = 0x0;
    // Setup ADCINA2 as 2nd SEQ1 conv.
    AdcRegs.ADCCHSELSEQ1.bit.CONV01 = 0x1;
    AdcRegs.ADCCHSELSEQ1.bit.CONV02 = 0x2;
    AdcRegs.ADCCHSELSEQ1.bit.CONV03 = 0x3;
    AdcRegs.ADCCHSELSEQ2.bit.CONV04 = 0x4;
    AdcRegs.ADCCHSELSEQ2.bit.CONV05 = 0x5;
    AdcRegs.ADCCHSELSEQ2.bit.CONV06 = 0x6;
    AdcRegs.ADCCHSELSEQ2.bit.CONV07 = 0x7;
    AdcRegs.ADCOFFTRIM.all=0x01FA;    //Offset value is -6
    // Enable SOCA from ePWM to start SEQ1
    AdcRegs.ADCTRL2.bit.EPWM_SOCA_SEQ1 = 1;
    // Enable SEQ1 interrupt (every EOS)

```

```

    AdcRegs.ADCTRL2.bit.INT_ENA_SEQ1=1;
    AdcRegs.ADCTRL1.bit.CONT_RUN=1;
    EPwm4Regs.ETSEL.bit.SOCAEN = 1;    // Enable SOC on A group
    // Select SOC from from CPMA on upcount
    EPwm4Regs.ETSEL.bit.SOCASEL=4;
    EPwm4Regs.ETPS.bit.SOCAPRD = 1;    // Generate pulse on 1st event
    EPwm4Regs.CMPA.half.CMPA = 0x0080; // Set compare A value
    EPwm4Regs.TBPRD = TS_12_8K;        // Set period for ePWM1
    EPwm4Regs.TBCTL.bit.CTRMODE = 0;    // count up and start
    EDIS;
}
/*=====*/
interrupt void adc_isr(void)
{
    Voltage1 = (AdcRegs.ADCRESULT0 >>4); //AN0
    Voltage2 = (AdcRegs.ADCRESULT1 >>4);
    Voltage3 = (AdcRegs.ADCRESULT2 >>4);
    Voltage4 = (AdcRegs.ADCRESULT3 >>4);
    Voltage5 = (AdcRegs.ADCRESULT4 >>4);
    Voltage6 = (AdcRegs.ADCRESULT5 >>4);
    Voltage7 = (AdcRegs.ADCRESULT6 >>4);
    Voltage8 = (AdcRegs.ADCRESULT7 >>4);
    ADCSample.Voltage.PhaseA=Voltage5;
    ADCSample.Current.PhaseA=Voltage6;
    ADCSample.Voltage.PhaseB=Voltage3;
    ADCSample.Current.PhaseB=Voltage4;
    ADCSample.Voltage.PhaseC=Voltage1;
    ADCSample.Current.PhaseC=Voltage2;
    ADCSample.dcbus=Voltage7;
    GeneratePWM(&ADCSample);
    Voltage1=0;
    Voltage2=0;

```

```

Voltage3=0;
Voltage4=0;
Voltage5=0;
Voltage6=0;
Voltage7=0;
Voltage8=0;
AdcRegs.ADCTRL2.bit.RST_SEQ1 = 1;    // Reset SEQ1
AdcRegs.ADCST.bit.INT_SEQ1_CLR = 1;  // Clear INT SEQ1 bit
// Acknowledge interrupt to PIE
PieCtrlRegs.PIEACK.all = PIEACK_GROUP1;
return;
}
/*=====*/

```



## References

- Abdin, Z., Webb, C. & Gray, E., 2015. Solar hydrogen hybrid energy systems for off-grid electricity supply: A critical review. *Renewable and Sustainable Energy Reviews*, Volume 52, pp. 1791-1808.
- Ackermann, T. & Soder, L., 2000. Wind energy technology and current status: a review. *Renewable and Sustainable Energy Reviews*, Volume 4, pp. 315 - 374.
- Afonso, J. L., Sepúlveda Freitas, M. J. & Martins, J. S., 2003. *p-q Theory Power Components Calculations*. Rio de Janeiro, IEEE International Symposium on Industrial Electronics.
- Aghajani, G., Shayanfar, H. & Shayeghi, H., 2015. Presenting a multi-objective generation scheduling model for pricing demand response rate in micro-grid energy management. *Energy Conversion and Management*, Volume 106, pp. 308-321.
- Ahmed, W. & Ali, S. M. U., 2013. *Comparative study of SVPWM (space vector pulse width modulation) & SPWM (sinusoidal pulse width modulation) based three phase voltage source inverters for variable speed drive*. s.l., IOPScience.
- Amatoul, F. Z., Lamchich, M. T. & Outzourhit, A., 2012. Design Control of DC/AC Converter for a Grid Connected PV Systems Using MATLAB/Simulink. *International Review on Modelling and Simulations*, 5(1974-9821), pp. 128 - 137.
- Aneke, M. & Wang, M., 2016. Energy storage technologies and real life applications – A state of the art review. *Applied Energy*, Volume 179, pp. 350-377.
- Bajpai, P. & Dash, V., 2012. Hybrid renewable energy systems for power generation in stand-alone applications: A review. *Renewable and Sustainable Energy Reviews*, Volume 16, pp. 2926-2939.
- Bakar, M. A., 2008. *Assessments for the impact of harmonic current distortion of non-linear load in power system harmonics*. Latin America, IEEE Xplore Conference Proceedings, pp. 1-6.
- Baker, J. & Collinson, A., 1999. Electrical energy storage at the turn of the Millennium. *Power Engineering Journal*, 13(3), pp. 107-112.
- Baroudi, J. A., Dinavahi, V. & Knight, A. M., 2007. A review of power converter topologies for wind generators. *Renewable Energy*, 32(0960-1481), pp. 2369 - 2385.
- Battistelli, C., 2013. *Generalized Microgrid-to-Smart Grid Interface Models for Vehicle-to-Grid*. Washington, DC, IEEE, pp. 1-6.
- Bhardwaj, M., 2013. *Software Phased-Locked Loop Design Using C2000™ Microcontrollers for Single Phase Grid Connected Inverter*, Texas: Texas Instruments Incorporated.
- Billings, K., 2003. *Advantages of Interleaving Converters*. [Online] Available at: <http://powerelectronics.com/content/advantages-interleaving-converters> [Accessed 20 05 2014].

Bode, G. H. & Holmes, D. G., 2000. *Implementation of three level hysteresis current control for a single phase voltage source inverter*. Galway, IEEE, pp. 33-38.

Bogaraj, T. & Kanakaraj, J., 2012. Development of MATLAB/SIMULINK Models for PV and Wind Systems and Review on Control Strategies for Hybrid Energy Systems. *International Review on Modelling and Simulations*, August, 5(1974-9821), pp. 1701-1710.

Bolognani, S. & Zampieri, S., 2013. A Distributed Control Strategy for Reactive Power Compensation in Smart Microgrids. *Automatic Control, IEEE Transactions on*, 20 June, pp. 2818-2833.

Cai, M., 2006. *The AC Motor Control Simulation and the Construction of an SVPWM Block via Simulink*, Taiwan: s.n.

Chao, K. H. & Lee, Y. H., 2011. A Maximum Power Point Tracker with Automatic Step Size Tuning Scheme for Photovoltaic Systems. *International Journal of Photoenergy*, Volume 2012, pp. 1-10.

Chau, K. T., Wong, Y. S. & Chan, C., 1998. An overview of energy sources for electric vehicles. *Energy Conversion & Management*, 40(0196-8904), pp. 1021 - 1039.

Chen, H., Cong, T. N., Yang, W., Tan, C., Li, Y. & Ding, Y., 2009. Progress in electrical energy storage system: A critical review. *Progress in Natural Science*, Volume 19, pp. 291-312.

Chicco, G. & Mancarella, P., 2009. Distributed multi-generation: a comprehensive view. *Renew Sustain Energy Review*, Volume 13, pp. 535-551.

Ciobotaru, M., Teodorescu, R. & Blaabjerg, T. a. F., 2006. *A New Single-Phase PLL Structure Based on Second Order Generalized Integrator*. s.l., IEEE Annual Power Electronics Specialists Conference.

Czarkowski, D., 2007. DC-DC Converters. In: M. H. Rashid, ed. *Power Electronics Handbook*. New York: Elsevier, pp. 245-259.

DailyHistory, 2015. *Weather History for Blackpool*. [Online] Available at: [http://www.wunderground.com/history/airport/EGNH/2015/12/6/DailyHistory.html?req\\_city=Lancaster&req\\_state=&req\\_statename=United+Kingdom&reqdb.zip=00000&reqdb.magic=19&reqdb.wmo=03214&MR=1](http://www.wunderground.com/history/airport/EGNH/2015/12/6/DailyHistory.html?req_city=Lancaster&req_state=&req_statename=United+Kingdom&reqdb.zip=00000&reqdb.magic=19&reqdb.wmo=03214&MR=1) [Accessed 10 12 2015].

Danish Wind Industry Association, 2013. [Online] Available at: <http://www.windpower.org/en/news/news.html#727> [Accessed 23 10 2013].

Davidson, P., 2008. *The impact of changing energy use patterns in buildings on peak electricity demand in the UK*, Garston: Department of Energy & Climate Change.

DECC, 2014. *2012 UK Greenhouse Gas Emissions Final Figures*, s.l.: Department of Energy & Climate Change.

Doostabad, H. H., Keypour, R., Khalghani, M. R. & Khooban, M. H., 2013. A new approach in MPPT for photovoltaic array based on Extremum Seeking Control under uniform and non-uniform irradiances. *Solar Energy*, Volume 94, pp. 28-36.

Dylan, D. L. & Quang, N. N., 2012. A photovoltaic panel emulator using a buck-boost DC/DC converter and a low cost micro-controller. *Solar Energy*, Volume 86, pp. 1477-1484.

Eltawil, A. M. & Zhao, Z., 2010. Grid-connected photovoltaic power systems: Technical and potential problems - A review. *Renewable and Sustainable Energy Reviews*, pp. 112-129.

Eltawil, A. M. & Zhao, Z., 2010. Grid-connected photovoltaic power systems: Technical and potential problems—A review. *Renewable and Sustainable Energy Reviews*, 14(1), pp. 112-129.

Eltawil, A. M. & Zhao, Z., 2010. Grid-connected photovoltaic power systems: Technical and potential problems—A review. *Renewable and Sustainable Energy Reviews*, 14(1), pp. 112-129.

Energy Networks Association, 2012. *Engineering Recommendation G83*, London: Energy Networks Association.

Espinoza, J. R., 2001. Inverters. In: M. H. Rashid, ed. *Power Electronics Handbook*. Florida: ACADEMIC PRESS, pp. 225-269.

Fan, Z., 2012. *Mathematical Modelling of Grid Connected Fixed-Pitch Variable-Speed Permanent Magnet Synchronous Generators for Wind Turbines*, Preston: UCLAN.

Fan, Z. & Liu, X., 2015. Smart Inverter with Active Power Control and Reactive Power Compensation. *Journal of Electrical and Electronic Engineering*, pp. 139-145.

Farhan, H. M. & Matti, L., 2016. A review: Agents in smart grids. *Electric Power System Research*, pp. 71-79.

Fedele, G., 2012. Non-adaptive Second-order generalized integrator for sinusoidal parameters estimation. *Electrical Power and Energy Systems*, November, 42(0142-0615), pp. 314-320.

Femia, N., Lisi, G., Petrone, G., Spagnuolo, G. & Vitelli, M., 2008. Distributed Maximum Power Point Tracking of Photovoltaic Arrays: Novel Approach and System Analysis. *Industrial Electronics, IEEE Transactions on*, July, 55(7), pp. 2610 - 2621.

Fthenakis, V., Mason, J. E. & Zweibel, K., 2009. The technical, geographical, and economic feasibility for solar energy to supply the energy needs of the US. *Energy Policy*, Volume 37, pp. 387-399.

Ganesh, A., Dahiya, R. & Singh, K. G., 2014. A Novel Robust STATCOM Control Scheme for Stability Enhancement in Multimachine Power System. *ELEKTRONIKA IR ELEKTROTECHNIKA*, 26 January, pp. 22-28.

Gardner, F. M., 2005. *Phaselock techniques*. Third Edition ed. Palo Alto: John Wiley.

Glasner, I. & Appelbaum, J., 1996. *Advantage of Boost VS. Buck Topology for Maximum Power Point Tracker in Photovoltaic Systems*. Israel, IEEE, pp. 355-358.

Golestan, S., Monfared, M. & Guerrero, J. M., 2013. *Second Order Generalized Integrator Based Reference Current Heneration Method for Single-Phase Shunt Active Power Filters Under Adverse Grid Conditions*. Tehran, IEEE, pp. 510-517.

Guo, X.-Q., Wu, W.-Y. & Gu, H.-R., 2011. Phase locked loop and synchronization methods for grid-interfaced converters: a review. *PRZEGLĄD ELEKTROTECHNICZNY (Electrical Review)*, Issue 0033-2097, pp. 182-187.

Gyugyi, L., Schauder, C. D. & Sen, K. K., 1997. static synchronous series compensator a solid state aproch to the series compensation of transmission lines. *IEEE Transactions on Power Delivery*, 12(1), pp. 406-417.

Hasegawa, T., Aoshima, Y., Sato, T., Kondo, O & Matsukawa, T., 1997. *Development of 60 MVA SVC (static VAr compensator) using large capacity 8 kV and 3 kA thyristors*. Nagaoka, IEEE, pp. 725-730.

Herbert, G. M. H., Iniyan, S., Sreevalsan, E. & Rajapandian, S., 2007. A review of wind energy technologies. *Renewable & Sustainable Energy Reviews*, 11(1364-0321), pp. 1117 - 1145.

Hingorani, N. G., 1988. Power Electronics in Electric Utilities: Role of Power Electronics in Future Power Systems. *Proceedings of the IEEE*, 76(4), pp. 481-482.

Hingorani, N. G., 1993. Flexible AC Transmission Systems. *IEEE Spectrum*, Apr., pp. 40-45.

Ho, B. M. T. & Chung, H. S.-H., 2005. An Integrated Inverter With Maximum Power Tracking for Grid-Connected PV Systems. *IEEE TRANSACTIONS ON POWER ELECTRONICS*, 20(0885-8993), pp. 953 -962.

IEA International Energy Agency, 2013. *Trends 2013 in Photovoltaic applicattions*, St. Ursen, Switzerland: IEA-PVPS.

Infineon Technologies AG, 2006. *XC164 Different PWM Waveforms Generation for 3-Phase AC Induction Motor with XC164CS*, München, Germany: Infineon Technologies AG.

Jain, S. & Agarwal, V., 2007. A Single-Stage Grid Connected Inverter Topology for Solar PV Systems With Maximum Power Point Tracking. *IEEE TRANSACTIONS ON POWER ELECTRONICS*, 22(0885-8993), pp. 1928 - 1940.

Jaiswal, M., Kaur, P. & Jaiswal, P., 2012. Review and Analysis of Voltage Collapse in Power System. *International Journal of Scientific and Reasearch Publications*, January.

Jang, D. & Yoon, D., 2003. Space-Vector PWM Technique for Two-Phase Inverter-Fed Two-Phase Induction Motors. *IEEE TRANSACTIONS ON INDUSTRY APPLICATIONS*, Volume 39, pp. 542-549.

Kale, M. & Ozdemir, E., 2005. An adaptive hysteresis band current controller for shunt active power filter. *Electric Power System Research*, pp. 113-119.

Kamankesh, H., Agelidis, V. G. & Abdollah , K.-F., 2016. Optimal scheduling of renewable micro-grids considering plug-in hybrid electric vehicle charging demand. *Energy*, Volume 100, pp. 285-297.

- Kedjar, B., Kanaan, Y. H. & Al-Haddad, K., 2014. Vienna Rectifier With Power Quality Added Function. *IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS*, 61(8), pp. 3847 - 3856.
- Kerekes, T., Teodorescu, R. & Borup, U., 2007. *Transformerless Photovoltaic Inverters Connected to the Grid*. Anaheim, CA, USA, IEEE, pp. 1733-1737.
- Kerekes, T., Teodorescu, R., Rodriguez, P., Vazquez, G. & Aldabas, E., 2011. A New High-Efficiency Single-Phase Transformerless PV Inverter Topology. *IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS*, JANUARY, 58(1), pp. 184 - 191.
- Khadmun, W. & Subsingha, W., 2013. High Voltage Gain Interleaved DC Boost Converter Application for Photovoltaic Generation System. *Energy Procedia*, Volume 34, pp. 390-398.
- Kjaer, S. B., Pedersen, J. K. & Blaabjerg, F., 2005. A Review of Single-Phase Grid-Connected Inverters for Photovoltaic Modules. *IEEE TRANSACTIONS ON INDUSTRY APPLICATIONS*, 41(0093-9994), pp. 1292 - 1306.
- Kojabadi, H. M., Yu, B., Gadoura, I., Chang, L. & Ghribi, M., 2006. A novel DSP-based current-controlled PWM strategy for single phase grid connected inverters. *Power Electronics, IEEE Transaction on*, 21(4), pp. 985-993.
- Kousksou, T., Bruel, P., Jamil, A., Rhafiki, T. El. & Zeraouli, Y., 2014. Energy storage: Applications and challenges. *Solar Energy Materials & Solar Cells*, Volume 120, pp. 59-80.
- Koutroulis, E. & Kalaitzakis, K., 2006. Design of a Maximum Power Tracking System for Wind-Energy-Conversion Applications. *IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS*, April, Volume 53, pp. 486-494.
- Laaksonen, H., Kauhaniemi, K. & Voima, S., 2011. *Microgrid voltage level management and role as part of smart grid voltage control*. Trondheim, s.n.
- Layate, Z., Bahi, T., Abadlia, I., Bouzeria, H. & Lekhchine, S., 2015. Reactive power compensation control for three phase grid-connected photovoltaic generator. *INTERNATIONAL JOURNAL OF HYDROGEN ENERGY*, 40(37), pp. 12619-12626.
- Lee, T.-L., Hu, S.-H. & Chan, Y.-H., 2013. D-STATCOM with Positive-Sequence Admittance and Negative-Sequence Conductance to Mitigate Voltage Fluctuations in High-Level Penetration of Distributed-Generation Systems. *IEEE TRANSCATION ON INDUSTRIAL ELECTRONICS*, April, pp. 1417-1428.
- Lena, G., 2013. *Rural Electrification with PV Hybrid System*, St. Ursen: IEA-PVPS.
- Liu, D.-h., Yang, J., Qu, Q. & Wu, T., 2007. Research on Method of Parallel Software PLL. *Journal of System Simulation*.
- Liu, F. R., Duan, S., Liu, Fei., Liu, B. & Kang, Y., 2008. A Variable Step Size INC MPPT Method for PV Systems. *IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS*, July, Volume 55, pp. 2622-2682.
- Liu, L., Wu, Z. & Li, H., 2010. *A Single-stage Grid-connected Inverter with Wide Range Reactive Power Compensation using Energy Storage System (ESS)*. Applied Power Electronics Conference and Exposition (APEC), 2010 Twenty-Fifth Annual IEEE, IEEE.

- Llaria, A., Curea, O., Jiménez, J. & Camblong, H., 2011. Survey on microgrids: Unplanned islanding and related inverter control techniques. *Renewable Energy*, 36(0960-1481), pp. 2052-2061.
- Luo, X., Wang, J., Dooner, M. & Clarke, J., 2015. Overview of current development in electrical energy storage technologies and the application potential in power system operation. *Applied Energy*, Volume 137, pp. 511-536.
- Luque, A. & Hegedus, S., 2003. *Handbook of Photovoltaic Science and Engineering*. s.l.:John Wiley & Sons Ltd.
- Majumder, R., 2013. Reactive Power Compensation in Single-Phase Operation of Microgrid. *IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS*, 60(4), pp. 1403 - 1414.
- Maniktala, S., 2006. *Switching Power Supplies A to Z*. Oxford : Elsevier .
- Medina, A., Mendonca, H. & Martinez, S., 2016. *Study of voltage fluctuations caused in a distribution grid by the connection of a wave energy converter and corrective actions based on reactive power compensation*. s.l., Procedia Computer Science, pp. 832-838.
- Microsemi, 2013. *Park, Inverse Park and Clarke, Inverse Clarke Transformations MSS Software Implentation User Guide*, Aliso Viejo: Microsemi Corporation.
- Milosevic, M., 2003. *Decoupling control of d and q current components in three-phase voltage source inverter*. Atlanta, USA, s.n.
- Mithulananthan, M., Canizares, C. A., Reeve, J. & Rogers, G. J., 2002. Comparison of PSS,SVC and STATCOM Controllers for Damping Power System Oscillations. *IEEE Trans. Power Systems*, October, pp. 1-8.
- Miwa, B. A., Otten, D. M. & Schlecht, M. F., 1992. *High Efficiency Power Factor Correction Using Interleaving Techiques*. Boston, IEEE.
- MK, 2013-11-05. *Technology information of FF75R12RT4*. Munich: Infineon .
- Moulin, E., 2002. Measurring Reactive Power in Energy Meters. *Metering International*, Issue 1, pp. 52 - 54.
- Moungkhum, N. & Subsingha, W., 2013. *Voltage Control by DQ Frame Technique of SVPWM AC-DC Converter*. s.l., SciVerse ScienceDirect, pp. 341-350.
- Murali, D., Rajaram, M. & Reka, N., 2010. Comparison of FACTS Devices for Power System Stability Enhancement. *International Journal of Computer Applications*, October, pp. 30-35.
- Myrzik, J. M. A. & Calais, M., 2003. *String and Module Integraed Inverters for Single-Phase Grid Connected Photovoltaic Systems - A Review*. Bologna, Italy, IEEE Bologna PowerTech Conference.
- Nayar, C. V., Islam , S. M., Dehbonei, H. & Tan, K., 2007. Power Electronics for Reneable Energy Sources. In: *Power Electronic Handbook*. Perth, Western-Austrlia: Elsevier Inc., pp. 673-716.

NEWS, B., 2015. *Substation flooding leaves 55,000 Lancaster homes without power*. [Online] Available at: <http://www.bbc.com/news/uk-england-lancashire-35020049> [Accessed 10 12 2015].

Nogueira, C. E. C., Vidotto, M. L., Niedzialkoski, R. K., Nelson, S., Souza, M. D., Chaves, L. I., Edwiges, T., Santos, D. B. D. & Werncke, I., 2013. Sizing and simulation of a photovoltaic-wind energy system using batteries, applied for a small rural property located in the south of Brazil. *Renewable and Sustainable Energy Reviews*, Volume 29, pp. 151 - 157.

NXP Semiconductors, 2012. *LPC2131/2/46/8 User manual*, Eindhoven: NXP Semiconductors.

Obi, M. & Bass, R., 2016. Trends and challenges of grid-connected photovoltaic systems – A review. *Renewable and Sustainable Energy Reviews*, pp. 1082-1094.

Ogata, K., 1995. *Discrete-time Control Systems*. 2nd ed. New Jersey: Prentice-Hall International, Inc.

Panwar, L. K., Reddy, K. S., Kumar, R., Panigrahi, B. K. & Vyas, S., 2015. Strategic Energy Management (SEM) in a micro grid with modern grid interactive electric vehicle. *Energy Conversion and Management*, Issue 106, pp. 41-52.

Patel, H. & Agarwal, V., 2008. MATLAB-Based Modeling to study the Effects of Partial Shading on PV Array Characteristics. *IEEE TRANSACTIONS ON ENERGY CONVERSION*, Volume 23, pp. 302-310.

Peaks, J., 2009. *Lancaster University Wind Turbine Development Scoping Opinion*, Lancaster: SEGEN LTD.

Pelland, S., Remund, J., Kleissl, J., Oozeki, T. & Brabandere, K. D., 2013. *Photovoltaic and Solar Forecasting: State of the Art*, St. Usen: IEA International Energy Agency.

Prasad, B. S., Jain, S. & Agarwal, V., 2008. Universal Single-Stage Grid-Connected Inverter. *IEEE TRANSACTIONS ON ENERGY CONVERSION*, 23(March 2008), pp. 128-137.

Reddy, K. S., Kumar, M., Mallick, T. K., Sharon, H. & Lokeswaran, S., 2014. A review of Integration, Control, Communication of renewable energy based smart grid. *Renewable and Sustainable Energy Reviews*, 38(1364-0321), pp. 180-192.

Renukadevi, V. & Jayanand, B., 2015. *Harmonic and Reactive Power Compensation of Grid Connected Photovoltaic System*. s.l., Procedia Technology, pp. 438-442.

Renukadevi, V. & Jayanand, B., 2015. Harmonic and Reactive Power Compensation of Grid-connected Photovoltaic System. *SMART GRID Technologies*, Volume 21, pp. 438-442.

Rodrigues, E., Godina, R., Santos, S. F., Bizuayehu, A. W., Contreras, J. & Catalao, J. P. S., 2014. Energy storage systems supporting increased penetration of renewables in islanded systems. *Energy*, Volume 75, pp. 265-280.

Rodriguez, J. F., Bueno, E., Aredes, M., Rolim, L. G. B., Neves, F. A. S. & Cavalcanti, M. C., 2008. *Discrete-time implementation of second order generalised integrators for grid converters*. Orlando, FL, IEEE, pp. 176-181.

- Rodriguez, J. R., Moreno, E. L., Venegas, V. V., Campos, D., Felix, R. & Ugalde, L. E., 2016. Current-sensorless control of an SPWM H-Bridge-based PFC rectifier designed considering voltage sag condition. *Electric Power Systems Research*, pp. 181-191.
- Rodriguez, P., Luna, A., Etxeberria, I., Hermoso, J. R. & Teodorescu, R., 2009. *Multiple Second Order Generalized Integrators for Harmonic Synchronization of Power Converters*. San Jose, CA, IEEE, pp. 2239 - 2246.
- Rouzbehi, K., Miranian, A. & Candela, J. I., 2014. A Generalized Voltage Droop Strategy for Control of Multiterminal DC Grids. *IEEE Transactions on Industry Applications*, 51(1), pp. 607 - 618.
- Ru, Y., Kleissl, J. & Martinez, S., 2013. Exact sizing of capacity for photovoltaic systems. *European Journal of Control*, pp. 1 - 14.
- Samadi, A., Ebrahim, S., Robert, E., Barry, R. & Lennart, S., 2014. Multi-objective coordinated droop-based voltage regulation in distribution grids with PV systems. *Renewable Energy*, 71(0960-1481), pp. 315-323.
- Sampaio, L. P., Brito, M. A. d., Melo, G. d. A. e. & Canesin, C. A., 2016. Grid-tie three-phase inverter with active power injection and reactive power compensation. *Renewable Energy*, 85(0960-1481), pp. 854-864.
- Sbordone, D., Martirano, L., Falvo, M. C., Chiavaroli, L., Pietra, B. Di, Bertini, I. & Genovese, A., 2016. Reactive power control for an energy storage system : A real implementation in a Micro-Grid. *Journal of Network and Computer Applications*, Volume 59, pp. 250-263.
- Seyedalipour, S. S. & Adabi, J., 2016. An active control technique for integration of distributed generation resources to the power grid. *Electrical Power and Energy Systems*, pp. 353 - 359.
- Shaaban, M. & J.O.Petinrin, 2013. Renewable energy potentials in Nigeria:Meeting rural energy needs. *Renewable and Sustainable Energy Reviews*, Volume 29, pp. 72 - 84.
- Shaon, S. A. & Salam, K. M. A., 2014. *Study of Vienna Rectifier and a Highly Efficient Single Phase Two Stage Inverter with low THD*. Dhaka, IEEE, pp. 619-622.
- Singh, G., 2013. Solar power generation by PV (photovoltaic) technology: A review. *Energy*, Volume 53, pp. 1-13.
- Smith, J. W., Sunderman, W., Dugan, R. & Seal, B., 2011. *Smart Inverter Volt/Var Control Functions for High Penetration of PV on Distribution Systems*. s.l., IEEE/PES, pp. 1-6.
- Sode-Yome, A. & Mithulanathan, N., 2004. Comparison of shunt capacitor, SVC and STATCOM in static voltage stability margin enhancement. *International Journal of Electrical Engineering Education*, 41/2(0020-7209), pp. 158-171.
- Sode-Yome, A. & Mithulanathan, N., 2004. Comparison of shunt capacitor, SVC and STATCOM in static voltage stability margin enhancement. *International Journal of Electrical Engineering Education*, Volume 41(2), pp. 158-171.



Sofla, A. M. & King, R., 2012. *Control Method for Multi-Microgrid Systems in Smart Grid Environment—Stability, Optimization and Smart Demand participation*. Washington, DC, IEEE, pp. 1-5.

Sridevi, J., 2013. A New Active Power Factor Correction Controller using Boost Converter. *Research Journal of Engineering Sciences*, 2(8)(2278 - 9472), pp. 7 - 11.

Suberu, M. Y., Mustafa, M. W. & Bashir, N., 2014. Energy storage systems for renewable energy power sector integration and mitigation of intermittency. *Renewable and Sustainable Energy Reviews*, Volume 35, pp. 499-514.

Ting, N. S., Yasa, Y. & Aksoy, I., 2015. *Comparison of SVPWM, SPWM and HCC control techniques in power control of PMSG used in wind turbine systems*. s.l., IEEE.

Toma, P., Dorin, P., Radu, E. & Daniel, M., 2014. *Sizing Photovoltaic-wind Smart Microgrid with Battery Storage and Grid Connection*. Cluj-Napoca, IEEE, pp. 1-5.

UKELA, n.d. *Effects of Climate Change*. [Online] Available at: <http://www.environmentlaw.org.uk/rte.asp?id=189> [Accessed 14 11 2013].

Vijayakumari, A., Devarajan, A. T. & Devarajan, N., 2015. Decoupled control of grid connected inverter with dynamic online grid impedance measurements for micro grid applications. *Electrical Power and Energy Systems*, Volume 68, pp. 1-14.

Wang, B., Sechilariu, M. & Locment, F., 2012. Intelligent DC Microgrid with Smart Grid Communication: Control Strategy Consideration and Design. *IEEE TRANSACTIONS ON SMART GRID*, 3(4), pp. 2148-2156.

Wang, H., Li, Q. & Wu, M., 2007. Investigation on a New Algorithm for Instantaneous Reactive and Harmonic Currents Detection Applied to Intensive Nonlinear Loads. *IEEE Transactions on Power Delivery*, 22(4), pp. 2312 - 2318.

Watanabe, E. H., Aredes, M., Barbosa, P. G., Lima, F. K. D. & ., 2007. Flexible AC Transmission Systems. In: M. H. Rashid, ed. *Power Electronic Handbook*. Florida: Elsevier Inc., pp. 797-822.

Yu, G., Jung, Y., Choi, J. Y. & Kim, G., 2004. A novel two-mode MPPT control algorithm based on comparative study of existing algorithms. *Solar Energy*, Volume 76, pp. 455-463.

Zarina, P. P., Mishra, S. & Sekhar, P. C., 2012. *Deriving Inertial Response from a Non-Inertial PV System for Frequency Regulation*. Bengaluru, India, IEEE.

Zheng, Z., Cai, K., Gao, Z., Li, G. & Wang, N., 2010. *Research on a Fast Algorithm for a Three-phase SVPWM Rectifier*. Wuhan, IEEE, pp. 4054 - 4058.

Zhong, Q.-C. & Hornik, T., 2013. *Control of Power Inverters in Renewable Energy and Smart Grid Integration*. First ed. Sheffield: John Wiley & Sons.